

2009 JUN 10 10:02

APPROVED

**BUREAU OF PUBLIC WATER SUPPLY**  
**CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT**  
**CERTIFICATION FORM**

Town of Falkner/Blackjack Water Assn.  
Public Water Supply Name

0700005 & 0050016  
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

***Please Answer the Following Questions Regarding the Consumer Confidence Report***

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper
  - On water bills
  - Other \_\_\_\_\_

Date customers were informed: 5 / 28 / 09

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:  
Date Mailed/Distributed:  / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*  
Name of Newspaper: Southern Sentinel  
Date Published: 6 / 10 / 09

- CCR was posted in public places. *(Attach list of locations)*  
Date Posted:  / /

- CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Doyle Duffin Mayson  
Name/Title (President, Mayor, Owner, etc.)

6/16/09  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

TOWN OF FALKNER WATER  
 P O BOX 117  
 FALKNER, MS 38629-0117  
 (662)837-4740 (662)837-4792

1 ED HOPPER HILLMAN				
TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
WA SW	10363	10303	10	1300 506
METER READ	NET DUE		AFTER THIS DATE	PAY GROSS
050403	1806		081007	1987

A COPY OF THE ANNUAL CCR IS  
 AVAILABLE AT CITY HALL



First-Class Mail
U.S. POSTAGE
Paid 1 oz.
Permit No.

RETURN THIS PORTION WITH PAYMENT

041009 1806 1987

-PRE AUTHORIZED DRAFT-  
 PRESORTED 1 20

RETURN SERVICE REQUESTED

HOPPER HILLMAN

P O BOX 886  
 RIPLEY MS 38669-0886

# Proof of Publication

*The State of Mississippi*  
*Tippah County*

Personally appeared before me a Notary Public in and for said County and State, the undersigned

Tim Watson

who, after being duly sworn, deposes and says that he is the Publisher of the SOUTHERN SENTINEL, a newspaper published in the City of Ripley, in said County and State, and that the *2008 Water Report*

## LEGAL NOTICE

a true copy of which is hereto attached, was published for 1X consecutive weeks in said newspaper as follows:

VOLUME	NO.	DATE
<i>131</i>	<i>29</i>	<i>6-10-09</i>

And further, that said newspaper has been published in Ripley, Tippah County, Mississippi for more than one year next preceding the first insertion of the above-mentioned legal notice.

*Tim Watson*

Tim Watson

Sworn to and subscribed before me this the

11 day of June 2009

*Jessica L Davis*

Notary Public, Tippah County, Mississippi

My Commission expires: **05/05/2013**





**Inorganic Contaminants**

10. Barium	N	2006*	.145	.139-.145	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
14. Copper	N	2008	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2008	13	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

**Disinfection By-Products**

Chlorine	N	2008	.8	.63 - .8	ppm	0	MDRL=4	Water additive used to control microbes
----------	---	------	----	----------	-----	---	--------	---

**PWS ID#: 0050016**

**TEST RESULTS**

Contamination	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of samples exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
---------------	---------------	----------------	----------------	--	------------------	------	-----	--------------------------------

**Inorganic Contaminants**

10. Barium	N	2007	.072	.038-.072	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
14. Copper	N	2008	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2008	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

**Disinfection By-Products**

Chlorine	N	2008	.9	.7 - .9	ppm	0	MDRL=4	Water additive used to control microbes
----------	---	------	----	---------	-----	---	--------	---

*\*Most recent sample. No sample required for 2008.*

As you can see by the table, our system has no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected, however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system #0700005 failed to complete these monitoring requirements in for 10/04 - 12/04; 2/05 - 10/06 and on system #0050016 for 11/04 - 12/04; 12/05 - 10/06. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant woman and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

**\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Labrotary, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

NOTICE: The report will not be mailed to each customer, however a copy can be obtained at our office.