

APPROVED

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

CALHOUN CITY WATER DEPARTMENT
Public Water Supply Name

0070004

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: 06 / 01 / 2009

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: MONITOR HERALD

Date Published: 06/04/2009


- CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www._____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.



Name/Title (President, Mayor, Owner, etc.)

6-9-2009

Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

ACCOUNT NO.	SERVICE FROM	SERVICE TO
04-0654500	04/25	05/25

SERVICE ADDRESS
105 HILL STREET

CURRENT	METER READINGS PREVIOUS	USED
1641	1621	20

CHARGE FOR SERVICES		

RETURN THIS STUB WITH PAYMENT TO:
CALHOUN CITY WATER DEPARTMENT
P.O. BOX E
CALHOUN CITY, MS 38916

PHONE
628-8345

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 20
CALHOUN CITY, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/15/2009	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
29.00	4.35	33.35

CCR REPORT AVAILABLE CITY HALL

WTR 10.00
SWR 5.00
GRB 14.00
NET DUE >>> 29.00
SAVE THIS >> 4.35
GROSS DUE >> 33.35

RETURN SERVICE REQUESTED
04-0654500
QUAY WOLFE
105 HILL ST
CALHOUN CITY MS 38916-7719
|||

2008 Annual Drinking Water Quality Report
Calhoun City Water Department
PW98: 0070004
May 2008

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three wells drawing from the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential contamination. The general susceptibility rankings assigned to each well of the system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Calhoun City Water Department have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact J. R. Denton, Mayor at 662-628-8345. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:30 PM at the Calhoun City City Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2008. In cases where monitoring wasn't required in 2008, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes maximum levels for the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Drawing	Unit Measure	MCLG	MCL	Likely Source of Contamination	
Inorganic Contaminants									
8. Arsenic	N	2008	3	0-3	ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes	
10. Barium	N	2008	.186	.119 - .166	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
14. Copper	N	2008	2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; discharge from metal refineries	
16. Fluoride**	N	2008	1.48	0.44 - 1.48	ppm	4	4	Erosion of natural deposits; water additives which promote strong teeth; discharge from fluorine and uranium factories	
17. Lead	N	2008	3	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits	
19. Nitrate (as Nitrogen)	N	2008	.17	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
21. Selenium	N	2008	8	3-8	ppb	60	60	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines	
Disinfection By-Products									
Chlorine	N	2008	4.8	.48 - 4.8	ppm	0	MCL=4	Water additive used to control microbes	

* Most recent sample. No sample required for 2008.
** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l.
As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/leadinwater/>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.676.7882 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

***** A MESSAGE FROM MSOH CONCERNING RADIOLOGICAL SAMPLING *****

In accordance with the Radionuclide Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of infection by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.676.7518.

The Calhoun City Water Department works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

the Best!

Wh
Who se
Now is you
heard on
Categories
of Calhoun

The rules are simple. Just fill in your choice
Herald, P.O. Box 69, Calhoun City, MS 38916 or
from the newspaper will be accepted. No phot
Votes will be tallied and results will be
Deadline for entries is Friday, June 27 a

- People
- Woman of the Year _____
 - Man of the Year _____
 - Friendliest _____
 - Bank Teller _____
 - Best Public Official _____
 - Best Musician _____
 - Best Artist _____
 - Best Postal Worker _____
 - Best K-5 Teacher _____
 - Best 6-8 Teacher _____
 - Best 9-12 Teacher _____
 - Best Principal _____
 - Best Coach _____
 - Best Male Athlete _____
 - Best Female Athlete _____
 - Best Sports Fan _____
 - Best Cosmetologist/Salon _____
 - Best Barber _____
 - Best Cook _____
 - Best Boss _____
 - Best Mechanic _____
 - Best Doctor _____
 - Best Nurse _____
 - Best Dentist _____
 - Best Lawyer _____
 - Best Minister _____
 - Best Fireman _____
 - Best Waitress _____
 - Best Insurance Salesperson _____
- Best Pharmacist _____
- Best Plumber _____
- Best Electrician _____
- Best Accountant _____
- Best Dancer _____
- Best Salesperson _____
- Best Grocery Clerk _____
- Best Grocery Bagger _____
- Best Butcher _____
- Best Relay for Life Team _____
- Best Photographer _____
- Best County Official _____
- Best School Board Member _____
- Places
- Best Outdoor Equipment Store _____
 - Best Furniture Store _____
 - Best Appliance Store _____
 - Best Heat & Air Business _____
 - Best Bank _____
 - Best Place to Buy a Car _____
 - Best Quick Stop _____
 - Best Restaurant _____
 - Best Grocery Store _____
 - Best Drug Store _____
 - Best Flower Shop/Gift Shop _____