

RECEIVED-WATER SUPPLY
2009 JUN 30 AM 8:54

APPROVED

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

ReForm Water
Public Water Supply Name

0100007 / 0100009
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper
- On water bills
- Other mailed corrected notice

Date customers were informed: 6/27/09

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Choctaw Chronicle

Date Published: 6/17/09

CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

[Signature]
Name/Title (President, Mayor, Owner, etc.)

6-27-09
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2009 JUN 30 AM 8: 54

**Annual Drinking Water Quality Report
Reform Water Users Association
PWS ID # 0100007
June 30, 2009**

TO: OUR WATER CUSTOMERS

Our CCR Report for the year 2008 has been corrected. The chlorine residual was inadvertently left off of the report. For a copy of the corrected CCR report, contact your water system or 662-285-7243.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCL G	MCL	Likely Source of Contamination
-------------	------------------	----------------	----------------	--	------------------	-------	-----	--------------------------------

Disinfectants & Disinfection By Products

Chlorine [asCl ₂]	N	2008	0.39	0.27-1.40	ppm	4	4	water additive used to control microbes
-------------------------------	---	------	------	-----------	-----	---	---	---

Mailed 6-27-09
P.V. open
Will mail ^{news} PAPER TO YOU

Annual Drinking Water Quality Report
Reform Water Users Association
PWS ID # 0100007
June 30, 2009

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater, and our 4 wells draw from the Lower Wilcox Aquifer.

If you have any questions about this report or concerning your water utility, please contact Coyt Hunt at (662)387-4360. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Monday of each month at 7P.M. in the Sherwood Community Center.

Reform Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Our source water assessment has been completed. Our wells were ranked **Moderate** in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662.387-4360.

To help you better understand these terms we've provided the following definitions. In this table you will find many terms and abbreviations you might not be familiar with.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCL G	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	-------	-----	--------------------------------

Inorganic Contaminants

Cadmium	N	2008	.0001	0	ppm	5	5	Corrosion of galvanized pipe ; from metal refineries; deposits ; batteries & paint
Arsenic	N	2008	<0.0005	No Range	Ppb	n/a	50	Erosion of natural deposits ; Runoff from orchards , glass and electronics production wastes
Selenium	N	2008	<0.0005	0	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Barium	N	2008	0.003619	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Nitrate (as Nitrogen)	N	2008	0.01	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion from natural deposits
Antimony	N	2008	<0.0005	No Range	ppb	6	4	Discharge from petroleum ; fire retardants; ceramics; solder electronics ; test addition
Chromium	N	2008	<.0005	No Range	Ppb	100	100	Discharge from steel and pulp erosion of natural deposits
Cyanide	N	2008	<0.0005	0	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride	N	2008	0.12	0.670-1.080	ppm	4	4	Erosion of natural deposits; additive which water promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (inorganic)	N	2008	<.0002	No Range	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Beryllium	N	2008	.00001	No Range	ppb	4	14	Discharge from metal refineries coal burning factories; Discharge from electrical aerospace
Thallium	N	2008	<0.0005	No Range	ppb	0.5	2	Discharge from electronics ; ; leaching from ore-processing

Volatile Organic Contaminants

Toluene	N	2004 *	0.562	No Range	ppb	1000	1000	Discharge from petroleum factories
---------	---	--------	-------	----------	-----	------	------	------------------------------------

Disinfectants & Disinfection By Products

Chlorine [asC12]	N	2008	0.39	0.27-1.40	ppm	4	4	water additive used to control microbes
TTHMs Total	N	2007	1.44	No Range	ppb	0	100	By- product of drinking water chlorination

HAA5 Total	N	2007	2.1	No Range	ppb	0	80	By- product of drinking water chlorination
------------	---	------	-----	----------	-----	---	----	--

*** Most recent sample None required in 2008**

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Please call our office if you have questions. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Annual Drinking Water Quality Report Reform Water Users Association

PWS ID #: 0100007

June 30, 2009

to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater, and our 4 wells draw from the Meridian Upper Wilcox and the Lower Wilcox Aquifer.

If you have any questions about this report or concerning your water utility, please contact Coyt Howell at (662)285-7243. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Tuesday after the 1st Monday of each month at 7P.M. in the Sherwood Community Center.

The Town of Weir routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of these constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Our source water assessment has been completed. Our wells were ranked **Moderate** in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662.387.4360.

To help you better understand these terms we've provided the following definitions. In this table you will find many terms and abbreviations you might not be familiar with.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

RECEIVED - WATER SUPPLY
THE CHOCTAW CHRONICLE, Wednesday, June 17, 2009

Annual Drinking Water Quality Report Town of Weir

PWS ID #: 0100009

June 30, 2009

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater, and our two wells draw from the Meridian Upper Wilcox and the Lower Wilcox Aquifer.

If you have any questions about this report or concerning your water utility, please contact Ricky Howell at (662)285-7243. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Tuesday after the 1st Monday of each month at 5:30P.M. in the Town Hall.

The Town of Weir routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of these constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Our source water assessment has been completed. Our wells were ranked **Moderate** in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662.547.6123.

To help you better understand these terms we've provided the following definitions. In this table you will find many terms and abbreviations you might not be familiar with.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

RECEIVED-WATER SUPPLY

2009 JUN 29 AM 11:10

APPROVED

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

Town of Web
Public Water Supply Name

100009
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper
- On water bills
- Other Hand Delivered Distributed By

Date customers were informed: 6/28/09

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 1/1

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Choctaw Chronicle

Date Published: 6/17/09

CCR was posted in public places. *(Attach list of locations)*

Date Posted: 1/1

CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Richard [Signature]
Name/Title (President, Mayor, Owner, etc.)

6-28-09
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2009 JUN 29 AM 11:10

Drinking Water Quality Report
Town of Weir
PWS ID #: 0100009
June 30, 2009

The State of Mississippi
CHOCTAW COUNTY

AFFIDAVIT OF PUBLICATION

Before me, in and for said county, this day personally came the undersigned representative of **THE CHOCTAW CHRONICLE**, a newspaper published in the Town of Ackerman, of said county and state, who being duly sworn deposeth and says that the publication of a certain notice, a true copy of which is hereto affixed, has been made of weeks consecutively, to wit:

Dated June 17, 2009
 Dated _____, 2009


Said representative further certifies that the several numbers of the newspaper containing the above-mentioned notice have been produced and compared with the copy affixed, and that the publication thereof has been correctly made.

WITNESS MY HAND AND SEAL OF OFFICE, this the 22nd day of June, A.D., 2009

By: Don Sheadgill, Chancery Clerk
 Notary Public

by Janine Sheadgill

SEAL:



you this year's Annual Water Quality Report. This report is designed to water and services we deliver to you every day. Our constant goal is to dependable supply of drinking water. We want you to understand the efforts we the water treatment process and protect our water resources. We are lity of your water. Our water source is groundwater, and our two wells Wilcox and the Lower Wilcox Aquifer.

about this report or concerning your water utility, please contact Ricky want our valued customers to be informed about their water utility. If you and any of our regularly scheduled meetings. They are held on the 1st of each month at 5:30P.M. in the Town Hall.

monitors for constituents in your drinking water according to Federal s the results of our monitoring for the period of January 1st to December er the land or underground, it can pick up substances or contaminants ad organic chemicals, and radioactive substances. All drinking water, r, may be reasonably expected to contain at least small amounts of some remember that the presence of these constituents does not necessarily

t has been completed. Our wells were ranked **Moderate** in terms of sus- or a copy of the report, please contact our office at 662.547.6123.

d these terms we've provided the following definitions. In this table you viations you might not be familiar with.

Milligrams per liter (mg/l) - one part per million corresponds to one penny in \$10,000.

Micrograms per liter - one part per billion corresponds to one minute in \$10,000,000.

- picocuries per liter is a measure of the radioactivity in water.

ation of a contaminant which, if exceeded, triggers treatment or other stem must follow.

Level - The "Maximum Allowed" (MCL) is the highest level of a contami- g water. MCLs are set as close to the MCLGs as feasible using the best

Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking known or expected risk to health. MCLGs allow for a margin of safety.

Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measur eme nt	MCL G	MCL	Likely Source of Contamination
--	--------------------	-------	-----	--------------------------------

0	ppm	5	5	Corrosion of galvanized pipe ; from metal refineries; deposits ; batteries & paint
No Range	Ppb	n/a	50	Erosion of natural deposits ; Runoff from orchards , glass and electronics production wastes
0	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion from natural deposits
No Range	ppb	6	4	Discharge from petroleum ; fire retardants ; ceramics ; soder

2009 JUN 29 AM 11: 10

*Corrected
Copy***Annual Drinking Water Quality Report****Town of Weir****PWS ID # 0100009****June 30, 2009**

TO: OUR WATER CUSTOMERS

Our CCR Report for the year 2008 has been corrected. The chlorine residual was inadvertently left off of the report. For a copy of the corrected CCR report, contact your water system or 662-

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCL G	MCL	Likely Source of Contamination
-------------	------------------	----------------	----------------	--	------------------	-------	-----	--------------------------------

Disinfectants & Disinfection By Products

Chlorine [asCl ₂]	N	2008	0.40	0.30-0.50	ppm	4	4	water additive used to control microbes
-------------------------------	---	------	------	-----------	-----	---	---	---

*Hand Distributed
6-26-09*

2009 JUN 29 AM 11:10

Annual Drinking Water Quality Report**Town of Weir****PWS ID # 0100009****June 30, 2009**

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater, and our two wells draw from the Meridian Upper Wilcox and the Lower Wilcox Aquifer.

If you have any questions about this report or concerning your water utility, please contact Ricky Vowell at (662)285-7243. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Tuesday after the 1st Monday of each month at 5:30P.M. in the Town Hall.

The Town of Weir routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Our source water assessment has been completed. Our wells were ranked Moderate in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662.547.6123.

To help you better understand these terms we've provided the following definitions. In this table you will find many terms and abbreviations you might not be familiar with.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCL G	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	-------	-----	--------------------------------

Inorganic Contaminants

Cadmium	N	2008	.0001	0	ppm	5	5	Corrosion of galvanized pipe ; from metal refineries; deposits ; batteries & paint
Arsenic	N	2008	<0.0005	No Range	Ppb	n/a	50	Erosion of natural deposits ; Runoff from orchards , glass and electronics production wastes
Selenium	N	2008	0.000763	0	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Barium	N	2008	0.018448	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Nitrate (as Nitrogen)	N	2008	0.59	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion from natural deposits
Antimony	N	2008	<0.0005	No Range	ppb	6	4	Discharge from petroleum ; fire retardants; ceramics; solder electronics ; test addition
Chromium	N	2008	<.0005	No Range	Ppb	100	100	Discharge from steel and pulp erosion of natural deposits
Copper	N	2008	0.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Cyanide	N	2008	<0.0005	0	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride	N	2008	<0.1	0.670-1.080	ppm	4	4	Erosion of natural deposits; additive which water promotes strong teeth; discharge from fertilizer and aluminum factories
Lead	N	2008	0.001	No Range	ppb	0	AL=15	Corrosion of household plumbing erosion of natural deposits;
Mercury (inorganic)	N	2008	<.0002	No Range	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland

Beryllium	N	2008	0.0001	No Range	ppb	4	14	Discharge from metal refineries coal burning factories; Discharge from electrical aerospace
Thallium	N	2008	<0.0005	No Range	ppb	0.5	2	Discharge from electronics ; ; leaching from ore-processing

Disinfectants & Disinfection By Products

Chlorine [asCl ₂]	N	2008	0.40	0.30-0.50	ppm	4	4	water additive used to control microbes
-------------------------------	---	------	------	-----------	-----	---	---	---

[HAA5] Total	N	2008	<6.0	No Range	ppb	0	100	By- product of drinking water chlorination
TTHMs Total	N	2008	4.04	No Range	ppb	0	100	By- product of drinking water chlorination

Volatile Organic Contaminants

Toluene	N	2008	0.5	No Range	ppb	1000	1000	Discharge from petroleum factories
---------	---	------	-----	----------	-----	------	------	------------------------------------

* Most recent sample None required in 2008

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclids beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Please call our office if you have questions. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.