

APPROVED

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

Copiah-New Zion Water Association, Inc.
Public Water Supply Name

0150009
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper
- On water bills
- Other _____

Date customers were informed: 7/1/09

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: the Meteor, Inc.

Date Published: 6/10/09

CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Sandra Singleton
Name/Title (President, Mayor, Owner, etc.)

6/11/09
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2008 Drinking Water Quality Report

Copiah-New Zion Water Association

PWS ID# 0150009

Is my water safe?

Last year, we conducted tests for more than 80 contaminants. We only detected 7 of those contaminants, and found only 1 at a level higher than the EPA allows. As we told you at the time in August 2008, our water temporarily exceeded drinking water standards for the Total Coliform Rule. Additionally, due to an audit of the Mississippi State Department of Health Radiological Laboratory by the US Environmental Protection Agency, all public water systems in Mississippi including Copiah-New Zion Water Association incurred a Reporting Violation although this was not the result of inaction by the water system. For more information see the paragraph marked **Violations** on the bottom of this report. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water comes from five wells that draw groundwater from the Catahoula Formation Aquifer.

Source water assessment and its availability:

Our source water assessment plan is available for review at our office located at 12095 New Zion Road during normal business hours.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

How can I get involved?

Our monthly board meetings are held on the third Tuesday of each month at 7:00 p.m. at our office located at 12095 New Zion Road. We encourage all customers who have any concerns or questions to meet with us. Our association conducts its annual membership meeting on the third Tuesday of March each year at 7:00 p.m. This is a very important meeting in which all customers are encouraged to attend.

Other information:

For additional information about the quality of your drinking water, you may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address: <http://www.msdh.state.us/watersupply/index.htm> Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and Safe Drinking Water" may be obtained.

Copiah-New Zion Water Association

Contact Information:

Foster J. Topp, Certified Operator
12095 New Zion Road
Crystal Springs, MS 39059
(601) 892-1205

2008 Drinking Water Quality Report

Copiah-New Zion Water Association

PWS ID# 0150009

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi Department of Health requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Terms and Abbreviations used below:

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL,</u> <u>TT, or</u> <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Range</u> <u>Low</u> <u>High</u>	<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
Microbiological Contaminants							
# Total Coliform (# of monthly positive samples)	0	>1	2	0 2	July 08	Yes	Naturally present in the environment
Inorganic Contaminants							
Barium (ppm)	2	2	0.00372	0.0022 .00372		No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	49.6	0 49.6		No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Haloacetic Acids (HAA)							
Total Regulated Haloacetic Acids		60	12	- 12	2007	No	By-product of chlorination
Trihalomethane							
Total Trihalomethanes		80	8.91	- 8.91	2007	No	By-product of chlorination
<u>Contaminants</u>	<u>MCLG</u>	<u>AL*</u>	<u>Your</u> <u>Water</u>	<u>Sample</u> <u>Date</u>	<u># Samples</u> <u>Exceeding AL</u>	<u>Exceeds</u> <u>AL</u>	<u>Typical Source</u>
Inorganic Contaminants							
Copper - action level at consumer taps (ppm)	1.3	1.3	0.009	2000	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	2	2000	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

*AL : Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow

Units Description:

ppm: parts per million, or milligrams per liter (mg/l)
ppb: parts per billion, or micrograms per liter (µg/l)

Violations:

Total Coliform - Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

Reporting Violation - Regulations require that drinking water systems submit certain reports to MSDH as well as notify its customers of potential problems and other information. During an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH is required to issue a reporting violation. MSDH takes full responsibility for this violation and will answer any questions should customers need further information by calling:

(601) 576-7618

CCR Rule Notification Requirement:

The publication of the 2008 Copiah New Zion W.A. Annual Drinking Water Quality Report (Consumer Confidence Report) fully complies with the USEPA and MDH CCR Rule Requirements. Copies of this report WILL NOT be mailed to customers except by request. Copies may also be picked up at our office.

The METEOR[★], INC.

ESTABLISHED 1881
Crystal Springs, Mississippi 39059
State of Mississippi, Copiah County

Personally appeared before the undersigned NOTARY
PUBLIC in and for said County and State, HENRY
CARNEY, Publisher of The Crystal Springs Meteor, a newspaper
published at Crystal Springs, Mississippi, who on oath says the
notice a copy of which is hereto attached, was printed
ONE consecutive times in said paper as follows:

	Cost
<u>JUNE 10 2009</u>	<u>\$ 144.90</u>
_____	\$ _____
_____	\$ _____
_____	\$ _____
_____	\$ _____
_____	\$ _____


Notary \$ 3.00

Total Cost \$ 147.90

Henry Carney Publisher

Sworn to and subscribed before me this 10th day of
JUNE, 2009.

Gale Callman
Notary Public



2008 Drinking Water Quality Report

Copiah-New Zion Water Association

PWS ID# 0150009

Is my water safe?

Last year, we conducted tests for more than 80 contaminants. We only detected 7 of those contaminants, and found only 1 at a level higher than the EPA allows. As we told you at the time in August 2008, our water temporarily exceeded drinking water standards for the Total Coliform Rule. Additionally, due to an audit of the Mississippi State Department of Health Radiological Laboratory by the US Environmental Protection Agency, all public water systems in Mississippi including Copiah-New Zion Water Association incurred a Reporting Violation although this was not the result of inaction by the water system. For more information see the paragraph marked **Violations** on the bottom of this report. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water comes from five wells that draw groundwater from the Catahoula Formation Aquifer.

Source water assessment and its availability:

Our source water assessment plan is available for review at our office located at 12095 New Zion Road during normal business hours.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

How can I get involved?

Our monthly board meetings are held on the third Tuesday of each month at 7:00 p.m. at our office located at 12095 New Zion Road. We encourage all customers who have any concerns or questions to meet with us. Our association conducts its annual membership meeting on the third Tuesday of March each year at 7:00 p.m. This is a very important meeting in which all customers are encouraged to attend.

Other information:

For additional information about the quality of your drinking water, you may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address: <http://www.msdh.state.us/watersupply/index.htm> Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and Safe Drinking Water" may be obtained.

Copiah-New Zion Water Association

Contact Information:

Foster J. Topp, Certified Operator
12095 New Zion Road
Crystal Springs, MS 39059
(601) 892-1205

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi Department of Health requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Terms and Abbreviations used below:

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

Contaminant	MCLG	MCL	Year	Range		Sample Date	Violation	Typical Source
	or MRDLG	TT, or MRDL		Low	High			
Microbiological Contaminants								
# Total Coliform (# of monthly positive samples)	0	>1	2	0	2	July 08	Yes	Naturally present in the environment
Inorganic Contaminants								
Barium (ppm)	2	2	0.00372	0.0022	0.0372		No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	49.6	0	49.6		No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Haloacetic Acids (HAA)								
Total Regulated Haloacetic Acids	60	12		12	2007		No	By-product of chlorination
Tribromomethane								
Total Tribromomethanes	80	8.91		8.91	2007		No	By-product of chlorination
Contaminants								
Contaminant	MCLG	AL*	Year	Sample	# Samples	Exceeds	AL	Typical Source
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	0.009	2000	0	No		Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	2	2000	0	No		Corrosion of household plumbing systems; Erosion of natural deposits

*AL: Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Units Description:
ppm: parts per million, or milligrams per liter (mg/l)
ppb: parts per billion, or micrograms per liter (µg/l)

Violations:

Total Coliform - Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

Reporting Violation - Regulations require that drinking water systems submit certain reports to MSDH as well as notify its customers of potential problems and other information. During an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH is required to issue a reporting violation. MSDH takes full responsibility for this violation and will answer any questions should customers need further information by calling: (601) 576-7618

CCR Rule Notification Requirement:

The publication of the 2008 Copiah-New Zion W.A. Annual Drinking Water Quality Report (Consumer Confidence Report) fully complies with the USEPA and MDH CCR Rule Requirements. Copies of this report WILL NOT be mailed to customers except by request. Copies may also be picked up at our office.

2008 CCR Contact Information

Date: 6/15/09

Time: 4:15

PWSID: 150009

System Name: Copiah - New Zion

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) _____

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Spoke with Ruth Becker she will relay this
information to Sandra who prepared the CCR. I also
Fixed the 2008 Drinking Water Quality Report
She will call me 6/16/09 Per Ruth!

Spoke with Ruth Becker
(Operator, Owner, Secretary)

Clerk 601 892-1205

Fax # 601 892-3200

- CORRECTED COPY -
2008 Drinking Water Quality Report
Copiah-New Zion Water Association
PWS ID# 0150009

2008 11 16 11:22
APPROVED 04

Is my water safe?

Last year, we conducted tests for more than 80 contaminants. We only detected 7 of those contaminants, and found only 1 at a level higher than the EPA allows. As we told you at the time in August 2008, our water temporarily exceeded drinking water standards for the Total Coliform Rule. Additionally, due to an audit of the Mississippi State Department of Health Radiological Laboratory by the US Environmental Protection Agency, all public water systems in Mississippi including Copiah-New Zion Water Association incurred a Reporting Violation although this was not the result of inaction by the water system. For more information see the paragraph marked **Violations** on the bottom of this report. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water comes from five wells that draw groundwater from the Catahoula Formation Aquifer.

Source water assessment and its availability:

Our source water assessment plan is available for review at our office located at 12095 New Zion Road during normal business hours.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

How can I get involved?

Our monthly board meetings are held on the third Tuesday of each month at 7:00 p.m. at our office located at 12095 New Zion Road. We encourage all customers who have any concerns or questions to meet with us. Our association conducts its annual membership meeting on the third Tuesday of March each year at 7:00 p.m. This is a very important meeting in which all customers are encouraged to attend.

Other information:

For additional information about the quality of your drinking water, you may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address: <http://www.msdh.state.us/watersupply/index.htm> Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and Safe Drinking Water" may be obtained.

**Copiah-New Zion Water Association
Contact Information:**

Foster J. Topp, Certified Operator
12095 New Zion Road
Crystal Springs, MS 39059
(601) 892-1205

2008 Drinking Water Quality Report

Copiah-New Zion Water Association

PWS ID# 0150009

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi Department of Health requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Terms and Abbreviations used below:

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL,</u> <u>TT, or</u> <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Range</u> <u>Low</u> <u>High</u>		<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
Microbiological Contaminants								
# Total Coliform (# of monthly positive samples)	0	>1	2	0	2	July 08	Yes	Naturally present in the environment
Disinfectants & Disinfection By-Products								
Chlorine (as Cl ₂) (ppm)	4	4	0.86	0.54	1.06		No	Water additive used to control microbes
Total Regulated Haloacetic Acids	60	60	12	-	12	2007	No	By-product of chlorination
Total Trihalomethanes	80	80	8.91	-	8.91	2007	No	By-product of chlorination
Inorganic Contaminants								
Barium (ppm)	2	2	0.00372	0.0022	.00372		No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	49.6	0	49.6		No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
<u>Contaminants</u>	<u>MCLG</u>	<u>AL*</u>	<u>Your</u> <u>Water</u>	<u>Sample</u> <u>Date</u>	<u># Samples</u> <u>Exceeding AL</u>	<u>Exceeds</u> <u>AL</u>	<u>Typical Source</u>	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	0.009	2000	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	2	2000	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

*AL : Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow

Units Description:

ppm: parts per million, or milligrams per liter (mg/l)
ppb: parts per billion, or micrograms per liter (µg/l)

Additional Information for Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Copiah New Zion Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you want to have your water tested.

Violations:

Total Coliform - Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

Reporting Violation - Regulations require that drinking water systems submit certain reports to MSDH as well as notify its customers of potential problems and other information. During an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH is required to issue a reporting violation. MSDH takes full responsibility for this violation and will answer any questions should customers need further information by calling:

(601) 576-7618

CCR Rule Notification Requirement:

The publication of the 2008 Copiah New Zion W.A. Annual Drinking Water Quality Report (Consumer Confidence Report) fully complies with the USEPA and MDH CCR Rule Requirements. Copies of this report WILL NOT be mailed to customers except by request. Copies may also be picked up at our office.

Copiah-New Zion Water Association, Inc.
12095 New Zion Road
Crystal Springs, MS
39059-8961
601-892-1205

2009 JUN 19 AM 9:04

June 18, 2009

Bureau of Public Water Supply
PO Box 1700
Jackson, MS 39215-1700

RE: CORRECTED COPY 2008 CONSUMER CONFIDENCE REPORT

Copiah-New Zion Water Association, Inc.'s corrected copy of the 2008 Consumer Confidence Report is attached. We will send a copy of a customer's July 1st billing statement with the availability of the report printed on it for your records after the statements are processed. This should correct the inconsistencies of the first report. If you have any questions please call 601-892-1205.

Sincerely,



Sandra Singletary, Association Manager

15/9

RECEIVED-WATER SUPPLY

2009 JUL -1 PM 1:24

Copiah-New Zion Water Association, Inc.
12095 New Zion Road
Crystal Springs, MS
39059-8961
601-892-1205

June 29, 2009

Bureau of Public Water Supply
PO Box 1700
Jackson, MS 39215-1700

**RE: Availability of "Corrected Copy" 2008 CCR Notice
on billing statement**

Attached you will find a copy of two Copiah-New Zion Water Association members' June billing statement with the notice of availability of the "Corrected Copy" 2008 Consumer Confidence Report printed at the bottom. This should complete the requirements of the 2008 certification form. If you have any questions, please call 601-892-1205.

Sincerely,



Sandra Singletary
Association Manager

RECEIVED-WATER SUPPLY

2009 JUL -1 PM 1:24



COPIAH - NEW ZION WATER ASSOCIATION
12095 NEW ZION RD.
CRYSTAL SPRINGS, MISSISSIPPI 39059-8961
(601) 892-1205

RETURN SERVICE REQUESTED

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
CRYSTAL SPRINGS MS
PERMIT NO. 5

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	1876000	1870000	6,000	35.50
Credit				(3.76)

CUSTOMER		PAY GROSS AMOUNT AFTER THIS DATE
ROUTE	ACCOUNT	
1	1013	7/15/09
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID
31.74		34.91

MAIL THIS STUB WITH YOUR PAYMENT



Service From 5/5/2009 TO 6/4/2009 ACCOUNT 1013 6/29/2009

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
6	4	1	31.74	3.17	34.91

JOELENA HARRIS
1109 S RAYMOND RD
HAZLEHURST MS
39083-9044

[CORRECTED COPY] 2008 Annual Drinking
Water Quality Report Available Upon Request



COPIAH - NEW ZION WATER ASSOCIATION
12095 NEW ZION RD.
CRYSTAL SPRINGS, MISSISSIPPI 39059-8961
(601) 892-1205

RETURN SERVICE REQUESTED

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
CRYSTAL SPRINGS MS
PERMIT NO. 5

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	1373000	1369000	4,000	27.50

CUSTOMER		PAY GROSS AMOUNT AFTER THIS DATE
ROUTE	ACCOUNT	
1	78	7/15/09
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID
27.50		30.25

MAIL THIS STUB WITH YOUR PAYMENT



PAID BY BANK DRAFT! THANK YOU!

Service From 5/1/2009 TO 6/1/2009 ACCOUNT 78 6/29/2009

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
6	1	1	27.50	2.75	30.25

WILBERT JOHNSON
PO BOX 24
Crystal Springs MS 39059-0024

[CORRECTED COPY] 2008 Annual Drinking
Water Quality Report Available Upon Request