

2009 JUL 16 AM 9: 12

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORMDAYS WATER ASSOC
Public Water Supply Name017005
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
- Advertisement in local paper
 On water bills
 Other _____

Date customers were informed: ___/___/___

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Do Sole TimesDate Published: 7/10/09

- CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Tony Perkins (President)
Name/Title (President, Mayor, Owner, etc.)

7/13/09
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

PROOF OF PUBLICATION

THE STATE OF MISSISSIPPI

COUNTY OF DESOTO

Diane Smith personally appeared before me the undersigned in and for said County and State and states on oath that she is the CLERK of the DeSoto Times-Tribune, a newspaper published in the town of Hernando, State and County aforesaid, and having a general circulation in said county, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper 1 consecutive times, as follows, to-wit:

Volume No. 114 on the 9 day of July, 2009

Volume No. on the day of , 2009

Volume No. on the day of , 2009

Volume No. on the day of , 2009

Volume No. on the day of , 2009

Volume No. on the day of , 2009

Diane Smith

Sworn to and subscribed before me, this 9 day of July, 2009

BY Judy H. Douglas

NOTARY PUBLIC STATE OF MISSISSIPPI AT LARGE
MY COMMISSION EXPIRES: JANUARY 16, 2013
BONDED THRU DIXIE NOTARY SERVICE, INCORPORATED



4 x 13 @ 6.48

A. Single first insertion of words @ .12 \$ 336.96

B. subsequent insertions of words @ .10 \$

C. Making proof of publication and deposing to same \$ 3.00

TOTAL PUBLISHER'S FEE: \$ 339.96

2008 Annual Drinking Water Quality Report
Days Water Association
PWS# 0170005
June 2009

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Meridian Upper Witcox and Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Days Water Association have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Marie Pounders at 662-781-0350. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the annual meeting scheduled for Monday, 11/02/08 at 7:00 PM at 4877 Starland Rd.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2008. In cases where monitoring wasn't required in 2008, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity. Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production; and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Contaminant	Violation Y/N	Date Collected	Level Detected	TEST RESULTS		
				Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure	Likely Source of Contamination
				MCLG	MCL	

Inorganic Contaminants

8. Arsenic	N	2008	103	No Range	ppb	mta	10
10. Barium	N	2008	330	No Range	ppm	2	2
16. Fluoride**	N	2008	553	No Range	ppm	4	4
17. Lead	N	2008	1	0	ppb	0	AL=15
19. Nitrate (as Nitrogen)	N	2008	11	No Range	ppm	10	10

Disinfection By-Products

82. THM [Total trihalomethanes]	N	2008	8.89	No Range	ppb	0	80
Chlorine	N	2008	1.45	1.15-1.45	ppm	0	MRDL = 4

* Most recent sample. No sample required for 2008.

** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radiocides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The Days Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

0170005

APPROVED

2008 Annual Drinking Water Quality Report
Days Water Association
FWS# 0170005
June 2008

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to bring you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to consistently improve the water treatment process and protect our water resources. We are committed to bettering the quality of your water. Our water comes from two wells drawing from the Mendocino Aquifer and Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to chemical potential sources of contamination. The general susceptibility ranking assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility designations were made has been furnished to our public water utility and is available for viewing upon request. This well for the Days Water Association has received a Moderate susceptibility ranking in combination.

If you have any questions about this report or concerning your water utility, please contact Marie Pounds at 609-784-0920. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the annual meeting scheduled for Monday, 7:00PM at 4677 Sycamore Ave.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table lists some of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2008. It does not include everything we've tested in 2008, but it does reflect the most recent results. As water flows over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances of concern from the presence of wildlife or from human activities. Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as nitrates and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and natural organic chemicals, which are by-products of petroleum processes and petroleum production, and chemicals used in gas extraction and other industrial processes; and radon, which can be naturally occurring in the veins of oil and gas production and mining activities. Inorganic chemicals and radon are not safe to drink. EPA prescribes regulations that limit the amount of certain inorganic chemicals in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and acronyms that you may not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is compelling evidence that addition of a disinfectant is necessary for control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,500 years or a single penny in \$10,000,000.

TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detectable # of Samples Exceeding MCL/MRDL	Last Measured	MCLG	MCL	MRDL	Other Source of Contamination

DESOTO TIMES-TRIBUNE

PROOF OF PUBLICATION

THE STATE OF MISSISSIPPI
COUNTY OF DESOTO

Diane Smith personally appeared before me the undersigned in and for said County and State and states on oath that she is the **CLERK** of the DeSoto Times-Tribune, a newspaper published in the town of Hernando, State and County aforesaid, and having a general circulation in said county, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper 1 consecutive times, as follows, to-wit:

- Volume No. 114 on the 9 day of July, 2009
- Volume No. _____ on the _____ day of _____, 2009
- Volume No. _____ on the _____ day of _____, 2009
- Volume No. _____ on the _____ day of _____, 2009
- Volume No. _____ on the _____ day of _____, 2009
- Volume No. _____ on the _____ day of _____, 2009

Diane Smith

Sworn to and subscribed before me, this 9 day of July, 2009

BY Jerry H. Douglas

NOTARY PUBLIC STATE OF MISSISSIPPI AT LARGE
MY COMMISSION EXPIRES: JANUARY 16, 2013
BONDED THRU DIXIE NOTARY SERVICE, INCORPORATED



4 x 13 @ 6.48

A. Single first insertion of _____ words @ .12 \$ 336.96

B. _____ subsequent insertions of _____ words @ .10 \$ _____

C. Making proof of publication and deposing to same \$ 3.00

TOTAL PUBLISHER'S FEE: \$ 339.96

To: MS Dept of Health

Attn: Joan Cockrell

From: TREMONT WATER

4 PAGES

Revised
CCR

for

Town of Tremont

2008 Annual Drinking Water Quality Report
 Days Water Association
 PWS#: 0170005
 June 2009

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Meridian Upper Wilcox and Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Days Water Association have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Marie Pounders at 662-781-0350. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the annual meeting scheduled for Monday, 11/02/09 at 7:00 PM at 4877 Starlanding Rd.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2008. In cases where monitoring wasn't required in 2008, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								

8. Arsenic	N	2008	.193	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2008	.030	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
16. Fluoride**	N	2008	.593	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2008	.11	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2008	8.99	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2008	1.45	1.15 – 1.45	ppm	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2008.

** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The Days Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.