

Rec'd
6/23/09

APPROVED

Annual Drinking Water Quality Report 2008 Country Living Mobile Home Park PWS 0240213

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is *the Undifferentiated Terrace Aquifer*. I'm pleased to report that our drinking water meets all federal and state requirements. This table shows the results of our monitoring for the period of 01/01/08-12/31/08. At one time during the year our monitoring indicated a chlorine level above the MCL. This was quickly corrected and does not pose a threat to the quality of our water supply.

If you have any questions concerning your water utility, please contact **Ron Ramos** at 228-323-0761

Country Living Mobile Home Park routinely monitors for constituents in your drinking water according to Federal and State laws. The date of last testing is shown for those contaminants not requiring annual testing. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances.

Definitions used in this Table:

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Some people who drink water containing trihalomethanes in excess of the MCL over many years experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

A Message From MSDH Concerning Radiological Sampling

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December, 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Mellissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Contaminant	Violatio Y/N	Date Collected RAA=Running Annual Ave.	Level Detected Your Water	# Samples exceed MCL/ACL or Range of Detects	Unit Measure	MCGL	MCL	Likely source
Haloacetic Acids (HAA5)	N	09/29/08	10.0	0	Ppb	NA	60	By-product of drinking water chlorination
Trihalomethanes (THM)	N	09/29/08	19.23	0	Ppb	NA	80	By-product of drinking water chlorination
Chlorine (as Cl ₂)(ppm) RAA	N	12/31/08 RAA	1.42	1	Mg/L	NA	4.0	Water additive used to control microbes
Inorganic Contaminants								
7. Antimony	N	04/23/08	0.0005	0	Ppm	0.0006	0.0006	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
8. Arsenic	N	04/23/08	0.0005	0	Ppm	n/a	.010	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	04/23/08	0.004607	0	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
11. Beryllium	N	04/23/08	0.0001	0	Ppm	0.004	0.004	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
12. Cadmium	N	04/23/08	0.0001	0	Ppm	0.005	0.005	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
13. Chromium	N	04/23/08	0.001305	0	Ppm	0.1	0.1	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	07/22/08	0.0264	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N	04/16/08	0.005	0	Ppm	0.2	0.2	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
16. Fluoride	N	04/23/08	0.324	0	Ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	07/22/08	0.0072	0	Ppm	0.015	AL=.015	Corrosion of household plumbing systems, erosion of natural deposits
18. Mercury (inorganic)	N	04/23/08	0.0002	0	Ppm	0.002	0.002	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
19. Nitrate (as Nitrogen)	N	06/09/08	0.08	0	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
20. Nitrite (as Nitrogen)	N	06/09/08	0.02	0	ppm	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	04/23/08	0.0005	0	Ppm	0.05	0.05	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
22. Thallium	N	04/23/08	0.0005	0	Ppm	0.002	0.002	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories