



RECEIVED-WATER SUPPLY  
2009 JUN 30 PM 12: 18

MISSISSIPPI STATE DEPARTMENT OF HEALTH

APPROVED

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2007 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM

North Hinds Water Assn.

Public Water Supply Name

0250015

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

*Please Answer the Following Questions Regarding the Consumer Confidence Report*

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper
  - On water bills
  - Other \_\_\_\_\_

Date customers were informed: \_\_\_ / \_\_\_ / \_\_\_

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 6/26/09

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_ / \_\_\_ / \_\_\_

- CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_ / \_\_\_ / \_\_\_

- CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Manager  
Doug Barker / Doug Barker  
Name/Title (President, Mayor, Owner, etc.)

6/30/09  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

2009 JUL 13 AM 11:48

**Is my water safe?**

In 2008, as in years past, North Hinds Water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

**Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

**Where does my water come from?**

Our 3 wells draw from the Cockfield Aquifer.

**Source water assessment.**

Well #1 Moderate

Well #2 Lower

Well #3 Moderate

**Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

**How can I get involved?**

Please contact our office with any comments or questions you may have.

**Conservation Tips**

Did you know that the average U.S. household uses approximately 350 gallons of water per day? Luckily, there are many low-cost or no-cost ways to conserve water. Water your lawn at the least sunny times of the day. Fix toilet and faucet leaks. Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath. Turn the faucet off while brushing your teeth and shaving; 3-5 gallons go down the drain per minute. Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!

**\*\*\*\*A Message From MSDH Concerning Radiological Sampling\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau Of Public Water Supply, at 601-576-7518.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. North Hinds Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Laboratory offers lead testing for \$10.00 per sample. Please contact 601-576-7582 if you wish to have your water tested.

**Maximum Residual Disinfectant Level.**

During the monitoring period the MCL was not exceeded.

**Water Quality Data Table**

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b> (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl <sub>2</sub> ) (ppm)	4	4	0.96	NA		2008	No	Water additive used to control microbes
<b>Inorganic Contaminants</b>								
Antimony (ppb)	6	6	0.5	NA		2008	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	0.664	NA		2008	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.006096	NA		2008	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	4	4	0.1	NA		2008	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	0.1	NA		2008	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	2.721	NA		2008	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	5	NA		2008	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Fluoride (ppm)	4	4	0.271	NA		2008	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury [Inorganic] (ppb)	2	2	0.2	NA		2008	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nitrate [measured as Nitrogen] (ppm)	10	10	0.08	NA		2008	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.02	NA		2008	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	50	50	2.368	NA		2008	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	NA		2008	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
<b>Volatile Organic Contaminants</b>								
1,1,1-Trichloroethane (ppb)	200	200	0.5	NA		2008	No	Discharge from metal degreasing sites and other factories
1,1-Dichloroethylene (ppb)	7	7	0.5	NA		2008	No	Discharge from industrial chemical factories
1,2,4-Trichlorobenzene (ppb)	70	70	0.5	NA		2008	No	Discharge from textile-finishing factories
1,2-Dichloroethane (ppb)	0	5	0.5	NA		2008	No	Discharge from industrial chemical factories
1,2-Dichloropropane (ppb)	0	5	0.5	NA		2008	No	Discharge from industrial chemical factories
Benzene (ppb)	0	5	0.5	NA		2008	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	0.5	NA		2008	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	NA		2008	No	Discharge from chemical and agricultural chemical factories

cis-1,2-Dichloroethylene (ppb)	70	70	0.5	NA	2008	No	Discharge from industrial chemical factories
Dichloromethane (ppb)	0	5	0.5	NA	2008	No	Discharge from pharmaceutical and chemical factories
Ethylbenzene (ppb)	700	700	0.5	NA	2008	No	Discharge from petroleum refineries
o-Dichlorobenzene (ppb)	600	600	0.5	NA	2008	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	NA	2008	No	Discharge from industrial chemical factories
Styrene (ppb)	100	100	0.5	NA	2008	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	0.5	NA	2008	No	Discharge from factories and dry cleaners
Toluene (ppm)	1	1	0.0005	NA	2008	No	Discharge from petroleum factories
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	NA	2008	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	NA	2008	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	0	2	0.5	NA	2008	No	Leaching from PVC piping; Discharge from plastics factories
Xylenes (ppm)	10	10	0.5	NA	2008	No	Discharge from petroleum factories; Discharge from chemical factories

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
<b>Inorganic Contaminants</b>							
Copper - action level at consumer taps (ppm)	1.3	1.3	0.3	2008	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	3	2008	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Jeff Jones  
Address:  
P. O. Drawer 300  
Flora, MS 39071  
601-981-1657

## 2008 North Hinds Water Assn. CCR 0250015; 06/09/09

**Is my water safe?**

In 2008, as in years past, North Hinds Water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

**Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

**Where does my water come from?**

Our 3 wells draw from the Cockfield Aquifer.

**Source water assessment.**

Well #1 Moderate

Well #2 Lower

Well #3 Moderate

**Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

**How can I get involved?**

Please contact our office with any comments or questions you may have.

**Conservation Tips**

Did you know that the average U.S. household uses approximately 350 gallons of water per day? Luckily, there are many low-cost or no-cost ways to conserve water. Water your lawn at the least sunny times of the day. Fix toilet and faucet leaks. Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath. Turn the faucet off while brushing your teeth and shaving; 3-5 gallons go down the drain per minute. Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!

**\*\*\*\*A Message From MSDH Concerning Radiological Sampling\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau Of Public Water Supply, at 601-576-7518.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. North Hinds Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Laboratory offers lead testing for \$10.00 per sample. Please contact 601-576-7582 if you wish to have your water tested.

**Maximum Residual Disinfectant Level.**

During the monitoring period the MCL was not exceeded.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants	MCLG or MRDLG	MCL, TL, or MRDL	Your Water	Range Low High	Sample Date	Violation	Typical Source
<b>Inorganic Contaminants</b>							
Antimony (ppb)	6	6	0.5	NA	2008	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	0.664	NA	2008	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.006096	NA	2008	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	4	4	0.1	NA	2008	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	0.1	NA	2008	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	2.721	NA	2008	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	5	NA	2008	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Fluoride (ppm)	4	4	0.271	NA	2008	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury [Inorganic] (ppb)	2	2	0.2	NA	2008	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nitrate [measured as Nitrogen] (ppm)	10	10	0.08	NA	2008	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.02	NA	2008	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	50	50	2.368	NA	2008	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	NA	2008	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
<b>Volatile Organic Contaminants</b>							
1,1,1-Trichloroethane (ppb)	200	200	0.5	NA	2008	No	Discharge from metal degreasing sites and other factories
1,1-Dichloroethylene (ppb)	7	7	0.5	NA	2008	No	Discharge from industrial chemical factories
1,2,4-Trichlorobenzene (ppb)	70	70	0.5	NA	2008	No	Discharge from textile-finishing factories

1,2-Dichloroethane (ppb)	0	5	0.5	NA	2008	No	Discharge from industrial chemical factories
1,2-Dichloropropane (ppb)	0	5	0.5	NA	2008	No	Discharge from industrial chemical factories
Benzene (ppb)	0	5	0.5	NA	2008	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	0.5	NA	2008	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	NA	2008	No	Discharge from chemical and agricultural chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	0.5	NA	2008	No	Discharge from industrial chemical factories
Dichloromethane (ppb)	0	5	0.5	NA	2008	No	Discharge from pharmaceutical and chemical factories
Ethylbenzene (ppb)	700	700	0.5	NA	2008	No	Discharge from petroleum refineries
o-Dichlorobenzene (ppb)	600	600	0.5	NA	2008	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	NA	2008	No	Discharge from industrial chemical factories
Styrene (ppb)	100	100	0.5	NA	2008	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	0.5	NA	2008	No	Discharge from factories and dry cleaners
Toluene (ppm)	1	1	0.0005	NA	2008	No	Discharge from petroleum factories
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	NA	2008	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	NA	2008	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	0	2	0.5	NA	2008	No	Leaching from PVC piping; Discharge from plastics factories
Xylenes (ppm)	10	10	0.5	NA	2008	No	Discharge from petroleum factories; Discharge from chemical factories

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
<b>Inorganic Contaminants</b>							
Copper - action level at consumer taps (ppm)	1.3	1.3	0.3	2008	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	3	2008	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter ( $\mu\text{g/L}$ )
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Jeff Jones  
 Address:  
 P. O. Drawer 300  
 Flora, MS 39071  
 601-981-1657

RECEIVED-WATER SUPPLY  
2009 JUN 30 PM 12: 19

Flora  
Flora, Mississippi  
390719998  
2737860071 -0098  
06/26/2009 (601)879-3101 08:55:40 AM

Product Description	Sales Receipt		Final Price
	Sale Qty	Unit Price	

Permit Type: Permit Imprint  
Permit Number: 6  
Customer Name: NORTH HINDS WATER ASSN.

Amount of Deposit: \$1,165.21  
New Balance: \$1,165.21  
Confirmation #: 200917708545098D  
Total: \$1,165.21  
Paid by: Personal Check \$1,165.21

Order stamps at USPS.com/shop or call 1-800-Stamp24. Go to USPS.com/clicknship to print shipping labels with postage. For other information call 1-800-ASK-USPS.

Bill#: 1000200824364  
Clerk: 03

All sales final on stamps and postage  
Refunds for guaranteed services only  
Thank you for your business  
\*\*\*\*\*  
HELP US SERVE YOU BETTER

Go to: <http://gx.gallup.com/pos>

TELL US ABOUT YOUR RECENT  
POSTAL EXPERIENCE

YOUR OPINION COUNTS  
\*\*\*\*\*  
\*\*\*\*\*


Customer Copy

RECEIVED-WATER SUPPLY  
2009 JUN 30 PM 12: 19




[Feedback](#) | [Personal Profile](#) | [Logout](#)


Restricted Information



Today's Date: 06/26/2009

Transactions > Postage Statement Processing  
First-Class Mail - Permit Imprint ▶ Receipt

			<b>Final</b>															
3600	POSTAL SERVICE STATEMENT OF MAILING/3607 WEIGHING AND DISPATCH CERTIFICATE	TRANS # 200917712031259M0  CAPS TRANS NO: N/A																
Postage Statement: 71371352	Mailer's Job#:	Mailing accepted at: BMEU FLORA - '39071-9998'																
NORTH HINDS WATER ASSN. PO BOX 300 FLORA MS 39071-0300		FINANCE NUMBER: 272691																
STATION OR UNIT:	Flora BMEU (01)	PERMIT NO: 6																
DATE OF MAILING 06/26/2009	CLASS First-Class	PROC CAT Letter	TYPE PI															
WEIGHT OF SINGLE PIECE (LBS) 0.0065	TOTAL PIECES 2809	TOTAL POUNDS 18.2600	Customer Reference ID  CAPS Acct No: _____															
MAILED FOR: PERMIT NO. _____ NAME: _____																		
CONTAINERS 7	FULL SERVICE N/A	AMOUNT FROM TRUST: \$1,165.21																
EEL/PFC:																		
VERIFICATION SUMMARY: <table border="1"> <thead> <tr> <th>Verification</th> <th>Performance Status</th> <th>Disposition</th> <th>Performance Percent</th> <th>Additional Postage</th> </tr> </thead> <tbody> <tr> <td>Weigh Entire Mailing</td> <td>Performed</td> <td></td> <td>100%</td> <td></td> </tr> <tr> <td>Manual Presort</td> <td>Performed</td> <td></td> <td>100%</td> <td>\$ 0.00</td> </tr> </tbody> </table>				Verification	Performance Status	Disposition	Performance Percent	Additional Postage	Weigh Entire Mailing	Performed		100%		Manual Presort	Performed		100%	\$ 0.00
Verification	Performance Status	Disposition	Performance Percent	Additional Postage														
Weigh Entire Mailing	Performed		100%															
Manual Presort	Performed		100%	\$ 0.00														
DT INITIATING EMPLOYEE	DT FINALIZING EMPLOYEE	 RECEIVED FOR PROCESSING BY																
COMMENTS:		BEGINNING BALANCE: \$1,165.21 ENDING BALANCE: \$0.00																
mailing has been inspected concerning: (1) eligibility for postage prices claimed; (2) proper preparation (and presort where required); (3) proper completion of postage statement; and (4) payment of annual fee (if required).																		





RECEIVED-WATER SUPPLY  
2009 JUN 30 PM 12:19

[Feedback](#) | [Personal Profile](#) | [Logout](#)

Restricted Information

Transactions > Postage Statement Processing  
First-Class Mail - Permit Imprint ▶ Review

Today's Date: 06/26/2009

Please verify the information below.  
If you need to make any changes press the *Back* button at the bottom of the page.  
Press **Submit** at the bottom of this page to submit the information you have entered.

Statement Information

PS Form 3600-R - First-Class Mail - Permit Imprint

**Planned**

Permit Holder:	NORTH HINDS WATER ASSN. PO BOX 300 FLORA, MS 39071-0300 Contact: DOUG BARKER (601) 981 - 1657	Mailing Agent:		Org. For Mailing is Prepared:	
	Customer Number: 082708918				
Permit Holder's Permit:	Permit Imprint 6	Mailing Agent's Permit:		Processing Category:	Letters (may include Cards)
Post Office Of Mailing:	Post Office Flora MS 39071-9998	Mailing Date:	06/26/2009	Weight of Single Piece:	0.0065 lbs.
Total Pieces:	2,809 pcs.	Total Weight:	18.2585 lbs.	Total Postage:	\$ 1,165.21
No of Containers:	1' MM Trays: 1	2' MM Trays: 6	2' EMM Trays:	Flat Trays:	Sacks: Pallets: Other:

Part B : Nonautomation Prices

Line Number	Title	Description	Price	Quantity	Postage
B3	Presorted	Letters	0.414	2721 pcs.	\$ 1,126.4940
B4	Single-Piece	Letters	0.440	88 pcs.	\$ 38.7200
				Part B Postage:	\$ 1,165.2140
				<b>Total Postage From All Parts:</b>	<b>\$ 1,165.2140</b>

USPS Use Only

Verification	Request Source	Performance Status	Disposition	Performance Type	Performance Percentage	Additional Postage	Cost Avoidance
eMIR Cursory review		Not Performed	N/A		N/A		
Weigh Entire Mailing	System Requested - Initial mailing schedule	Performed	N/A	Weigh Verification Error	100%	N/A	N/A
Manual Presort	System Requested - Initial mailing schedule	Performed	N/A	Presort	100%	N/A	N/A
<b>Total:</b>						<b>\$0.00</b>	<b>\$0.00</b>

Postage Summary and Comments

Total Postage: \$ 1,165.21  
Total Additional Postage: \$ 0.00  
Total Cost Avoidance: \$ 0.00  
Total Adjusted Postage: \$ 1,165.21

Comments:

(Comments must be under 255 characters)

Statement Processing - Initiation Employee's Initials:

Statement Processing - Finalization Employee's Initials:

RECEIVED-WATER SUPPLY

2009 JUN 30 PM 12: 19

Restricted Information

Feedback | Personal Profile | Logout



Transactions > Postage Statement Processing
First-Class Mail - Permit Imprint > Permit Entry

Today's Date: 06/26/2009

Mailer Information

Permit Location

No other finance number found in user's profile, other permit location option is not available

Permit Information

Permit Holder

Mailing Agent

Mail Owner

\* Number: 6 Search

Search

Search

\* Type: Permit Imprint

Permit Imprint

-- Select Type --

General Information

Post Office of Mailing: Post Office Flora MS 39071-9998
Acceptance Facility: BMEU FLORA - 39071

Check the appropriate checkboxes:

- Mailing contains automation prices:
Mailing contains windowed letters or flats:
Mailing contains pieces with alternative address format:
Statement reentered following a reversal:
This is a Political Campaign mailing:
This is a consolidated statement:
Mailing includes Permit Reply Mail:

Select a postage payment system (if applicable):

- Mailing satisfying an Alternative Mailing System (AMS) agreement:
Mailing satisfying an Optional Procedure (OP) agreement:
An itemized manifest is supplied:
A batch manifest is supplied:
None:

Mailer Job Number:

\* Processing Category: Letters (may include Cards)

Move Update Method: -- Select a Move Update Method --

Container Information

\* Number of Containers

1' MM Trays: 1

2' MM Trays: 6

2' EMM Trays:

Flat Trays:

Sacks:

Pallets:

Mailing contains bundles not in sacks/trays:

Other:

Piece/Weight Information

\* Mailer Declared Total Pieces: 2809

\* Mailer Declared Total Weight: 18.26 lbs.

USPS Determined Piece-Weight: 0.0065 lbs.

If non-identical, leave blank. (Must be less than .8125 pound.)

\* Mailing Date: 06/26/2009

Perform voluntary weigh verification:

RECEIVED-WATER SUPPLY

2009 JUN 30 PM 12: 19

[Feedback](#) | [Personal Profile](#) | [Logout](#) |

Restricted Information



[Transactions](#) > Postage Statement Processing   
First-Class Mail - Permit Imprint ▶ Weigh Verification

Today's Date: 06/26/2009

Weigh Verification Required

Mailer Declared:

Piece-Weight:  
\* Total Pieces:   
\* Total Weight:  lbs.

USPS Determined:

lbs.  
\*   
\*  lbs.

Check this box if the Percent of Difference exceeded 1%  
(PS8040):

Previous Step: *Bad Address*

Next Step: *Account Verification Information*

[Permit Entry](#) --> [Bad Address](#) --> Weigh Verification

[Feedback](#) | [Logout](#) |

Copyright © 1999-2009 USPS. All Rights Reserved.

[Terms of Use](#)



RECEIVED-WATER SUPPLY

2009 JUN 30 PM 12: 19

[Feedback](#) | [Personal Profile](#) | [Logout](#)

[Transactions](#) > Postage Statement Processing   
First-Class Mail - Permit Imprint > Postage Statement Entry

Today's Date: 06/26/2009

Mailing Group ID: 70383721 Postage Statement ID: 71371352  
Mailing Information

\* denotes required fields.

Mailing Date: 06/26/2009  
Post Office of Mailing: Post Office Flora MS 39071-9998  
Statement Sequence No.:   
Federal Agency Cost Code:   
Customer Reference ID:

Is this mailpiece an enclosure within another class of mail?  
If yes, select the enclosing class:

Line Items

Part B - Nonautomation Prices

Presort/Automation Discount		Number of Pieces	Price
<b>Cards</b>			
B1	Presorted	<input type="text"/>	0.245
B2	Single-Piece	<input type="text"/>	0.280
<b>Letters</b>			
B3	Presorted	<input type="text" value="2721"/>	0.414
B4	Single-Piece	<input type="text" value="88"/>	0.440
<b>Nonmachinable Letters</b>			
B5	Presorted	<input type="text"/>	0.414
B6	Single-Piece	<input type="text"/>	0.440
B7	Nonmachinable Surcharge (for presorted letters)	<input type="text"/>	0.200
B8	Nonmachinable Surcharge (for single-piece letters)	<input type="text"/>	0.200
<b>Permit Reply Mail</b>			
B17	Single-Piece Letter (1 oz. or less)	<input type="text"/>	0.440

Previous Step: [Account Verification Information](#)

Next Step: [Mail Verification](#)

[< Back](#)

[Abandon](#)

[Save and Continue](#)

[Permit Entry](#) --> [Bad Address](#) --> [Weigh Verification](#) --> [Verify Account](#) --> Postage Statement Entry

[Feedback](#) | [Logout](#)

Copyright © 1999-2009 USPS. All Rights Reserved.

[Terms of Use](#)

RECEIVED-WATER SUPPLY

2009 JUN 30 PM 12: 20

Restricted Information

| [Feedback](#) | [Personal Profile](#) | [Logout](#) |



[Transactions](#) > Postage Statement Processing   
 First-Class Mail - Permit Imprint ▶ [Mail Verification](#)

Today's Date: 06/26/2009

Statement Information  
 PS Form 3600-R - First-Class Mail - Permit Imprint

**Planned**

Permit Holder:	NORTH HINDS WATER ASSN. PO BOX 300 FLORA, MS 39071-0300 Contact: DOUG BARKER (601) 981 - 1657	Mailing Agent:		Org. For Mailing is Prepared:	
	Customer Number: 082708918				
Permit Holder's Permit:	Permit Imprint 6	Mailing Agent's Permit:		Processing Category:	Letters (may include Cards)
Post Office Of Mailing:	Post Office Flora MS 39071-9998	Mailing Date:	06/26/2009	Weight of Single Piece:	0.0065 lbs.
Total Pieces:	2,809 pcs.	Total Weight:	18.2585 lbs.	Total Postage:	\$ 1,165.21
No of Containers:	1' MM Trays: 1	2' MM Trays: 6	2' EMM Trays:	Flat Trays:	Sacks: Pallets: Other:

Part B : Nonautomation Prices

Line Number	Title	Description	Price	Quantity	Postage
B3	Presorted	Letters	0.414	2721 pcs.	\$ 1,126.4940
B4	Single-Piece	Letters	0.440	88 pcs.	\$ 38.7200
				Part B Postage:	\$ 1,165.2140
				<b>Total Postage From All Parts:</b>	<b>\$ 1,165.2140</b>

Verification Results Information

Sample Selection Matrix

Please click [here](#) to view the Sample Selection Matrix

Manual Presort Verification 

Primary reason for non-performance of verification:

Results:  %

Pending Additional Postage or Cost Avoidance: \$

Select A/R/C:

Previous Step: [Postage Statement Entry](#)

Next Step: [Review](#)

[< Back](#)

[Abandon](#)

[Save and Continue](#)

[Permit Entry](#) --> [Bad Address](#) --> [Weigh Verification](#) --> [Verify Account](#) --> [Postage Statement Entry](#) --> [Mail Verification](#)

| [Feedback](#) | [Logout](#) |

Copyright © 1999-2009 USPS. All Rights Reserved.

[Terms of Use](#)