

# Annual Water Quality Report

## South Central Water Association, Inc.

CORRECTED  
June 26, 2009  
PWN ID: 0250022

RECEIVED-WATER SUPPLY  
2009 AUG 10 AM 9:36

This report is designed to inform you about the quality water and services we deliver to you each day. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Last year, as in years past, we test for many inorganic contaminants and organic chemical contaminants. We detected SCWA had a higher level than the state allows in HAA5 for the first quarter of 2008. The amount was .065 and the allowance is .060. For more information, see the paragraph on the back marked **HAA5 Violation**.

If you have any questions about this report or concerning your water utility, please contact Buddy Hand, General Manager, at 601-878-9639 during regular business hours from 8:00 am to 4:30 pm. If you want to learn more about the system, please attend our Annual Meeting on Tuesday, September 22, 2009, at 7:30 pm at the Mississippi Rural Water Association office; 5400 Midway Road at Highway 18.

Our water is drawn from the Forest Hill Sand Aquifer and Sparta Aquifer. SCWA routinely monitors for constituents in your drinking water according to Federal and State laws. As water travels over the land or underground, it may pick up substances or contaminants such as microbes, inorganic or organic chemicals, and radioactive substances. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these constituents does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Our source water assessment has been completed and our wells were ranked from Lower to Moderate in terms of susceptibility to contamination. To see a copy of the report please contact our office at 601-878-9639.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions.

### Contaminants that may be present in source water before we treat it include:

- **Microbial contaminants**, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses.
- **Radioactive contaminants**, which are naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm-water runoff, and septic systems.

### Terms & Abbreviations Used Below:

- **MCLG**-Maximum Contaminant Level Goal: the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL**-Maximum Contaminant Level: the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **AL**-Action Level: the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **MRDLG**-Maximum Residual Disinfection Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **MRDL**-Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **NA**: not applicable
- **ppb**: parts per billion or micrograms per liter
- **ppm**: parts per million or milligrams per liter
- **pCi/L**: picocuries per liter is a measure of the radioactivity in water
- **ug/L**: Number of micrograms of substance in one liter of water

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants(units)	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range Low High	Sample Date	Violation	Typical Source
<b>Disinfection By-Products</b>							
Chlorine (as C12)(ppm)	4	4	.94	0.69 - 1.18	2008	No	Water additive used to control microbes
TTHMs [Total Trihalomethanes](ppb)	NA	80	0.070	NA	Average for year 2008	No	By product of drinking water chlorination
HAA5 [Haloacetic Acids](ppb)	NA	60	0.055	NA		Yes	By product of drinking water disinfection
<b>Inorganic Contaminants</b>							
Barium (ppm)	2	2	0.0132	NA	2008	No	Discharge of drilling wastes, discharge from metal refineries; erosion of natural deposits
Chromium [total] (ppb)	100	100	.00134	NA	2008	No	Discharge from steel and pulp mills; Erosion of natural deposits
Copper (ppm)	1.3	AL=1.3	0.7	NA	2007	No	Corrosion of household plumbing systems; erosion of natural deposits, leaching from wood preservations
Fluoride (ppm)	4	4	0.289	NA	2008	No	Erosion of natural deposits; Water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead(ppb)	0	AL=.015	0.004 (MPL)	NA	2007	No	Corrosion of household plumbing systems, erosion of natural deposits
Selenium(ppb)	50	50	.00061	NA	2008	No	Discharge from petroleum metal refineries; Erosion of natural deposits; Discharge from mines
<b>Radioactive Contaminants</b>							
Alpha emitters(pCi/L)	0	15	0.121	NA	2008	No	Erosion of natural deposits
Radium (226/228)(pCi/L)	0	5	0.109	NA	2008	No	Erosion of natural deposits
Uranium (ug/L)	0	30	0.273	0.025 - 0.273	2008	No	Erosion of natural deposits

**About HAA5 Violation:** Some people who drink water containing HAA5 in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. We are working closely with our Engineer and the State Health Department to resolve this issue.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). Please call our office at 601-878-9639 if you have any questions.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10.00 per sample. Please contact 601-576-7582 if you wish to have your water tested.

**\*\*\*\*\* A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING \*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. **Although this was not the result of inaction by the public water supply**, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any question, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

# SOUTH CENTRAL WATER ASSOCIATION, INC.

14525 MIDWAY ROAD • TERRY, MS 39170  
P.O. BOX 1228 • RAYMOND, MS 39154  
PHONE (601) 878-9639 • FAX (601) 878-9642

August 7, 2009

Joan Cockrell  
Division of Water Supply  
PO Box 1700  
Jackson, MS 39215-1700

Re: Corrected Copy CCR and Current Bill

Ms. Cockrell:

Enclosed is a bill we mailed out to our customers on July 26, 2009, with a message about the corrected copy of the Consumer Confidence Report. Also is a corrected copy of the CCR.

If you have any questions concerning this matter, please call me.

Sincerely,



Louis C Hand  
General Manager

LCH:mdh

Enclosure

RECEIVED - WATER SUPPLY  
2009 AUG 10 AM 9:36



# SOUTH CENTRAL WATER ASSOCIATION

14525 MIDWAY ROAD  
(601) 878.9639

OFFICE HOURS:  
8:00 A.M. - 4:30 P.M.  
Monday - Friday

PO BOX 1228  
RAYMOND, MS 39154

SERVICE PERIOD	ACCOUNT NUMBER	CUSTOMER NAME	SERVICE ADDRESS
06/05/2009 TO 07/07/2009	077700	LOUIS C HAND	6108 PARSONS ROAD
SERVICE	PREVIOUS READING	PRESENT READING	USAGE
PREVIOUS AMOUNT THANK YOU - PAYMENT WATER	928990	930440	1450
			CHARGES
			15.62 -15.62 14.50

**DELINQUENT CHARGE**

- \$30.00 reconnect charge - weekdays from 8:00 am to 4:30 pm
- Reconnection for delinquent accounts will not be performed after hours
- \$50.00 tampering fee

Your Account is Paid Via Automatic Bank Draft:  
This statement is for Informational Purposes Only.  
\*\*\*\*\* Please Do Not Pay \*\*\*\*\*

**NO OTHER NOTICE WILL BE SENT**

- Allow ample time for delivery before the due date when mailing your payment
- Outside depository is available after hours for your convenience
- No adjustment for water leaks or large usage
- Payments must be in the office by 4:30 the 15th to avoid a late fee
- Non-payment of this account may result in interruption of water service after the 19th of the month

**TOTAL AMOUNT DUE**

14.50

**DUE DATE**

08/10/2009

**AFTER**

08/15/2009


**PAY**

19.50

**Account History**

Your Water Use this Period: 1450 Gallons  
Water Usage Same Period Last Year: 59830 Gallons  
Average Water Usage: 4873 Gallons

**Your Water Usage During Previous 12 Months**



RECEIVED - WATER SUPPLY  
2009 AUG 10 AM 9:36

\*\*\*\* ATTENTION\*\*\*\*

HAS BEEN CORRECTED TO INCLUDE INFORMATION REGARDING HAA5 RESULTS.

PLEASE CONTACT THE OFFICE FOR A COPY.

PLEASE BRING ENTIRE BILL IF PAYING IN PERSON. PLEASE DETACH AND RETURN BOTTOM PORTION IF PAYING BY MAIL.



SOUTH CENTRAL WATER ASSOC  
PO BOX 1228  
RAYMOND, MS 39154


Return Service Requested

<b>ACCOUNT #</b>	<b>BILLING DATE</b>	07/26/2009
077700	<b>CURRENT BILL</b>	14.50
<b>DUE DATE</b>	<b>PREV. BALANCE</b>	0.00
08/10/2009	<b>TOTAL DUE</b>	14.50
<b>AFTER</b>	08/15/2009	<b>PAY</b>
		19.50
<b>PLEASE ENTER AMOUNT PAID \$</b>		



\*\*AUTO \*\*\*AUTO\*\*5-DIGIT 39170  
LOUIS C HAND  
6185 PARSONS ROAD  
TERRY MS 39170-7154

SOUTH CENTRAL WATER ASSOC  
PO BOX 1228  
RAYMOND, MS 39154-1228



## Annual Water Quality Report

### South Central Water Association, Inc.

CORRECTED  
June 26, 2009  
PWN ID: 0250022

This report is designed to inform you about the quality water and services we deliver to you each day. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Last year, as in years past, we test for many inorganic contaminants and organic chemical contaminants. We detected SCWA had a higher level than the state allows in HAA5 for the first quarter of 2008. The amount was .065 and the allowance is .060. For more information, see the paragraph on the back marked HAA5 Violation.

If you have any questions about this report or concerning your water utility, please contact Buddy Hand, General Manager, at 601-878-9639 during regular business hours from 8:00 am to 4:30 pm. If you want to learn more about the system, please attend our Annual Meeting on Tuesday, September 22, 2009, at 7:30 pm at the Mississippi Rural Water Association office, 5400 Midway Road at Highway 18.

Our water is drawn from the Forest Hill Sand Aquifer and Sparta Aquifer. SCWA routinely monitors for constituents in your drinking water according to Federal and State laws. As water travels over the land or underground, it may pick up substances or contaminants such as microbes, inorganic or organic chemicals, and radioactive substances. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these constituents does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Our source water assessment has been completed and our wells were ranked from Lower to Moderate in terms of susceptibility to contamination. To see a copy of the report please contact our office at 601-878-9639.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions.

#### Contaminants that may be present in source water before we treat it include:

- **Microbial contaminants**, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses.
- **Radioactive contaminants**, which are naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm-water runoff, and septic systems.

#### Terms & Abbreviations Used Below:

- **MCLG**-Maximum Contaminant Level Goal: the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL**-Maximum Contaminant Level: the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **AL**-Action Level: the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **MRDLG**-Maximum Residual Disinfection Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **MRDL**-Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **NA**: not applicable
- **ppb**: parts per billion or micrograms per liter
- **ppm**: parts per million or milligrams per liter
- **pCi/L**: picocuries per liter is a measure of the radioactivity in water
- **ug/L**: Number of micrograms of substance in one liter of water

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants(units)	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range Low High	Sample Date	Violation	Typical Source
<b>Disinfection By-Products</b>							
Chlorine (as Cl <sub>2</sub> )(ppm)	4	4	.94	0.69 - 1.18	2008	No	Water additive used to control microbes
THMs (Total Trihalomethanes)(ppb)	NA	80	0.070	NA	Average for year 2008	No	By product of drinking water chlorination
HAA5 (Haloacetic Acids)(ppb)	NA	80	0.055	NA		Yes	By product of drinking water disinfection
<b>Inorganic Contaminants</b>							
Barium (ppm)	2	2	0.0132	NA	2008	No	Discharge of drilling wastes, discharge from metal refineries; erosion of natural deposits
Chromium [total] (ppb)	100	100	.00134	NA	2008	No	Discharge from steel and pulp mills; Erosion of natural deposits
Copper (ppm)	1.3	AL=1.3	0.7	NA	2007	No	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride (ppm)	4	4	0.289	NA	2008	No	Erosion of natural deposits; Water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead(ppb)	0	AL=0.15	0.004 (MFL)	NA	2007	No	Corrosion of household plumbing systems, erosion of natural deposits
Selenium(ppb)	50	50	.00061	NA	2008	No	Discharge from petroleum metal refineries; Erosion of natural deposits; Discharge from mines
<b>Radioactive Contaminants</b>							
Alpha emitters(pCi/L)	0	15	0.121	NA	2008	No	Erosion of natural deposits
Radium (226/228)(pCi/L)	0	5	0.109	NA	2008	No	Erosion of natural deposits
Uranium (ug/L)	0	30	0.273	0.025 - 0.273	2008	No	Erosion of natural deposits

**About HAA5 Violation:** Some people who drink water containing HAA5 in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. We are working closely with our Engineer and the State Health Department to resolve this issue.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). Please call our office at 601-878-9639 if you have any questions.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10.00 per sample. Please contact 601-576-7582 if you wish to have your water tested.

\*\*\*\*\* A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING \*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any question, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

**SOUTH CENTRAL WATER ASSOCIATION, INC.**

---

14525 MIDWAY ROAD • TERRY, MS 39170  
P.O. BOX 1228 • RAYMOND, MS 39154  
PHONE (601) 878-9639 • FAX (601) 878-9642

**FAX COVER SHEET**

**DATE:** July 29, 2009 **FAX NO:** (601) 576-7822

**COMPANY:** Mississippi State Department of Health  
**Attention:** Joan Cockrell

**FROM:** Louis C. Hand  
South Central Water

**NO. OF PAGES INCLUDING COVER SHEET (3)**

I am faxing a corrected copy of the CCR and will mail you a copy with a new bill with the message. If there is a problem please let me know or ask for Martha. Thanks

2009 JUN 29 AM 11:09

APPROVED

## BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORMSouth Central Water Association, Inc.

Public Water Supply Name

0250022

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

*Please Answer the Following Questions Regarding the Consumer Confidence Report*

- Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)
- Advertisement in local paper
- On water bills
- Other Sent with monthly bills

Date customers were informed: 7 / 01 / 09

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 6 / 26 / 09

- CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: \_\_\_\_\_

Date Published:  / /


- CCR was posted in public places. (*Attach list of locations*)

Date Posted:  / /

- CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

 General Manager  
Name/Title (President, Mayor, Owner, etc.)

June 26, 2009

Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

2009 JUN 29 AM 11:09  
**Annual Water Quality Report**  
**South Central Water Association, Inc.**

June 26, 2009  
 PWN ID: 0250022

This report is designed to inform you about the quality water and services we deliver to you each day. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Buddy Hand, General Manager, at 601-878-9639 during regular business hours from 8:00 am to 4:30 pm. If you want to learn more about the system, please attend our Annual Meeting on Tuesday, September 22, 2009, at 7:30 pm at the Mississippi Rural Water Association office; 5400 Midway Road at Highway 18.

Our water is drawn from the Forest Hill Sand Aquifer and Sparta Aquifer. SCWA routinely monitors for constituents in your drinking water according to Federal and State laws. As water travels over the land or underground, it may pick up substances or contaminants such as microbes, inorganic or organic chemicals, and radioactive substances. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these constituents does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Our source water assessment has been completed and our wells were ranked from Lower to Moderate in terms of susceptibility to contamination. To see a copy of the report please contact our office at 601-878-9639.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions.

**Contaminants that may be present in source water before we treat it include:**

- **Microbial contaminants**, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses.
- **Radioactive contaminants**, which are naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm-water runoff, and septic systems.

**Terms & Abbreviations Used Below:**

- **MCLG**-Maximum Contaminant Level Goal: the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL**-Maximum Contaminant Level: the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **AL**-Action Level: the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **MRDLG**-Maximum Residual Disinfection Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **MRDL**-Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **NA**: not applicable
- **ppb**: parts per billion or micrograms per liter
- **ppm**: parts per million or milligrams per liter
- **pCi/L**: picocuries per liter is a measure of the radioactivity in water
- **ug/L**: Number of micrograms of substance in one liter of water

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.


Contaminants(units)	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range Low High	Sample Date	Violation	Typical Source
<b>Disinfection By-Products</b>							
Chlorine (as C12)(ppm)	4	4	.94	0.69 - 1.18	2008	No	Water additive used to control microbes
TTHMs [Total Trihalomethanes](ppb)	NA	80	0.070	NA	Average for year 2008	No	By product of drinking water chlorination
HAA5 [Haloacetic Acids](ppb)	NA	60	0.055	NA		No	By product of drinking water disinfection
<b>Inorganic Contaminants</b>							
Barium (ppm)	2	2	0.0132	NA	2008	No	Discharge of drilling wastes, discharge from metal refineries; erosion of natural deposits
Chromium [total] (ppb)	100	100	.00134	NA	2008	No	Discharge from steel and pulp mills; Erosion of natural deposits
Copper (ppm)	1.3	AL=1.3	0.7	NA	2007	No	Corrosion of household plumbing systems; erosion of natural deposits, leaching from wood preservations
Fluoride (ppm)	4	4	0.289	NA	2008	No	Erosion of natural deposits; Water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead(ppb)	0	AL=.015	0.004 (MPL)	NA	2007	No	Corrosion of household plumbing systems, erosion of natural deposits
Selenium(ppb)	50	50	.00061	NA	2008	No	Discharge from petroleum metal refineries; Erosion of natural deposits; Discharge from mines
<b>Radioactive Contaminants</b>							
Alpha emitters(pCi/L)	0	15	0.121	NA	2008	No	Erosion of natural deposits
Radium (226/228)(pCi/L)	0	5	0.109	NA	2008	No	Erosion of natural deposits
Uranium (ug/L)	0	30	0.273	0.025 - 0.273	2008	No	Erosion of natural deposits

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). Please call our office at 601-878-9639 if you have any questions.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10.00 per sample. Please contact 601-576-7582 if you wish to have your water tested.

\*\*\*\*\* A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING \*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. **Although this was not the result of inaction by the public water supply**, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any question, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.



# INVOICE

# COPY

365 Martin Farm Road  
Lawrenceville, GA 30024  
Fax: 770-263-8856  
Phone: 770-263-8827  
Toll Free: 1-866-899-8827

**Invoice:** 116884  
**Invoice Date:** 6/18/2009  
**Order Date:** 6/12/2009

**Job:** 82022  
**Salesperson:** Rich Printing  
**Purchase Order:**  
**Form Number:**

**Bill To:** SOU122  
South Central Water Assoc.  
P.O. Box 1228  
Raymond MS 39154

**Contact:** Martha Hand

Visit our Website, [www.richprintinginc.com](http://www.richprintinginc.com) for Promotional Products!

Qty Ordered	Qty Shipped	Description	Amount
4,300	4,800	CCR Report	426.00
200	200	CCR Report Samples Shipped to South Central Water Association, Terry, MS.	
		Freight charges for shipment to South Central Water Association, Terry, MS.	11.61
		<b>Net Sales:</b>	426.00
		<b>Freight - Taxable:</b>	11.61
		<b>Invoice Total:</b>	<u>437.61</u>

Terms: Due in 30 days

**BUREAU OF PUBLIC WATER SUPPLY**  
**CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT**  
**CERTIFICATION FORM**

South Central Water Association, Inc.  
 Public Water Supply Name

0250022

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

***Please Answer the Following Questions Regarding the Consumer Confidence Report***

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
- Advertisement in local paper  
 On water bills  
 Other Sent with monthly bills

Date customers were informed: 7/01/09

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 6/26/09

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_ / \_\_\_ / \_\_\_


- CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_ / \_\_\_ / \_\_\_

- CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

 General Manager  
 Name/Title (President, Mayor, Owner, etc.)

June 26, 2009  
 Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
 Phone: 601-576-7518

## Annual Water Quality Report

### South Central Water Association, Inc.

June 26, 2009  
PWN ID: 0250022

This report is designed to inform you about the quality water and services we deliver to you each day. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Buddy Hand, General Manager, at 601-878-9639 during regular business hours from 8:00 am to 4:30 pm. If you want to learn more about the system, please attend our Annual Meeting on Tuesday, September 22, 2009, at 7:30 pm at the Mississippi Rural Water Association office; 5400 Midway Road at Highway 18.

Our water is drawn from the Forest Hill Sand Aquifer and Sparta Aquifer. SCWA routinely monitors for constituents in your drinking water according to Federal and State laws. As water travels over the land or underground, it may pick up substances or contaminants such as microbes, inorganic or organic chemicals, and radioactive substances. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these constituents does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Our source water assessment has been completed and our wells were ranked from Lower to Moderate in terms of susceptibility to contamination. To see a copy of the report please contact our office at 601-878-9639.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions.

#### Contaminants that may be present in source water before we treat it include:

- **Microbial contaminants**, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses.
- **Radioactive contaminants**, which are naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm-water runoff, and septic systems.

#### Terms & Abbreviations Used Below:

- **MCLG**-Maximum Contaminant Level Goal: the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL**-Maximum Contaminant Level: the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **AL**-Action Level: the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **MRDLG**-Maximum Residual Disinfection Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **MRDL**-Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **NA**: not applicable
- **ppb**: parts per billion or micrograms per liter
- **ppm**: parts per million or milligrams per liter
- **pCi/L**: picocuries per liter is a measure of the radioactivity in water
- **ug/L**: Number of micrograms of substance in one liter of water

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants(units)	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range Low High	Sample Date	Violation	Typical Source
<b>Disinfection By-Products</b>							
Chlorine (as Cl <sub>2</sub> )(ppm)	4	4	.94	0.69 - 1.18	2008	No	Water additive used to control microbes
THMs [Total Trihalomethanes](ppb)	NA	80	0.070	NA	Average for year 2008	No	By product of drinking water chlorination
HAA5 [Haloacetic Acids](ppb)	NA	60	0.055	NA		No	By product of drinking water disinfection
<b>Inorganic Contaminants</b>							
Barium (ppm)	2	2	0.0132	NA	2008	No	Discharge of drilling wastes, discharge from metal refineries; erosion of natural deposits
Chromium [total] (ppb)	100	100	.00134	NA	2008	No	Discharge from steel and pulp mills; Erosion of natural deposits
Copper (ppm)	1.3	AL=1.3	0.7	NA	2007	No	Corrosion of household plumbing systems; erosion of natural deposits, leaching from wood preservatives
Fluoride (ppm)	4	4	0.289	NA	2008	No	Erosion of natural deposits; Water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead(ppb)	0	AL=0.15	0.004 (MPL)	NA	2007	No	Corrosion of household plumbing systems, erosion of natural deposits
Selenium(ppb)	50	50	.00061	NA	2008	No	Discharge from petroleum metal refineries; Erosion of natural deposits; Discharge from mines
<b>Radioactive Contaminants</b>							
Alpha emitters(pCi/L)	0	15	0.121	NA	2008	No	Erosion of natural deposits
Radium (226/228)(pCi/L)	0	5	0.109	NA	2008	No	Erosion of natural deposits
Uranium (ug/L)	0	30	0.273	0.025 - 0.273	2008	No	Erosion of natural deposits

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). Please call our office at 601-878-9639 if you have any questions.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10.00 per sample. Please contact 601-576-7582 if you wish to have your water tested.

\*\*\*\* A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING \*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. **Although this was not the result of inaction by the public water supply**, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any question, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

**SOUTH CENTRAL WATER ASSOCIATION, INC.**

---

14525 MIDWAY ROAD • TERRY, MS 39170  
P.O. BOX 1228 • RAYMOND, MS 39154  
PHONE (601) 878-9639 • FAX (601) 878-9642

**FAX COVER SHEET**

**DATE:** June 26, 2009 **FAX NO:** (601) 576-7822

**COMPANY:** Mississippi State Department of Health  
Attention: Melissa Parker  
Water supply

**FROM:** Louis C. Hand  
South Central Water

**NO. OF PAGES INCLUDING COVER SHEET (4)**

# 2008 CCR Contact Information

Date: 7/1/09 Time: 10:16

PWSID: 250022

System Name: South Central

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) TTHM (MCL) 1st qtr 2008  
*Health effect language*

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Will call Christi for more information of violation.  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Spoke with Buddy 601 946-8547  
(Operator, Owner, Secretary)  
2