

2009 JUN 24 AM 9:16

**BUREAU OF PUBLIC WATER SUPPLY**  
**CORRECTED**  
**CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT**  
**CERTIFICATION REPORT**

**APPROVED**

TOWN OF TERRY  
PWS ID # 0250025

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

***Please Answer the Following Questions Regarding the Consumer Confidence Report***

- Customers were informed of availability of CORRECTED CCR by: *(Attach copy of publication, water bill, or other)*
- Advertisement in local paper
- On water bills
- Other \_\_\_\_\_

Date customers were informed: 6/24/09

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date mailed/distributed: \_\_\_\_\_

- CCR was published in local newspaper. *(Attach copy of published CCR and proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_\_\_

- CCR was posted in public places. *(Attach list of locations)*

Date posted: \_\_\_\_\_

- CCR was posted on a publicly accessible internet site at the address: www: \_\_\_\_\_


**CERTIFICATION:**

I hereby certify that a Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

  
Name/Title (President, Mayor, Owner, etc.)

6/24/09  
Date

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

  
Signature

6-10-09  
Date

**Mail completed form to: Bureau of Public Water Supply ~ P O Box 1700 ~ Jackson, MS 39215**  
**Phone: 601-576-7518**

**CORRECTED**  
**Annual Drinking Water Quality Report**  
**Town of Terry**  
**PWS ID # 0250025**  
**June, 2009**

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well that draws from the Forest Hill Sand Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. A report containing detailed information has been received by our office and will be made available for review upon request. The water supply for the Town of Terry received a low susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mary Smith at 601-878-5521. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at the Terry Community Center at 7:00 pm.

The Town of Terry routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

**\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Terry is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N		0.007	No Range	Pprn	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N		0.8	No Range	Ppt	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N		0.2	None	pprn	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N		1.18	No Range	pprn	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N		2	None	ppt	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Volatile Organic Contaminants</b>								
73. TTHM [Total trihalomethanes]	Y		78 - 119	Three	ppt	0	80	By-product of drinking water chlorination
HAA5	Y		65 - 112	Four	ppt	0	60	By-product of drinking water chlorination
<b>Disinfectants &amp; Disinfection By-Products</b>								
Chlorine (as Cl <sub>2</sub> )	N	Jan - Dec 2008		None	pprn	4	4	Water additive used to control microbes

(73) TTHMs [Total Trihalomethanes]. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

# BUREAU OF PUBLIC WATER SUPPLY

## CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT CERTIFICATION REPORT

TOWN OF TERRY  
PWS ID # 0250025

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

### *Please Answer the Following Questions Regarding the Consumer Confidence Report*

Customers were informed of availability of CCR by: (*Attach copy of publication, water bill, or other*)

- Advertisement in local paper  
 On water bills  
 Other \_\_\_\_\_

Date customers were informed: JUNE 2009

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date mailed/distributed: \_\_\_\_\_

CCR was published in local newspaper. (*Attach copy of published CCR and proof of publication*)

Name of Newspaper: HINDS COUNTY GAZETTE

Date Published: JUNE 2009

CCR was posted in public places. (*Attach list of locations*) TERRY CITY HALL

Date posted: JUNE 19, 2009

CCR was posted on a publicly accessible internet site at the address: www: \_\_\_\_\_

### **CERTIFICATION:**

I hereby certify that a Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Roderick S. Nichol, Mayor  
Name/Title (President, Mayor, Owner, etc.)

6-4-09  
Date

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Susan Bayless  
Signature

5/30/09  
Date

**Mail completed form to: Bureau of Public Water Supply ~ P O Box 1700 ~ Jackson, MS 39215  
Phone: 601-576-7518**

Annual Drinking Water Quality Report  
Town of Terry  
PWS ID # 0250025  
May, 2009

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well that draws from the Forest Hill Sand Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. A report containing detailed information has been received by our office and will be made available for review upon request. The water supply for the Town of Terry received a low susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mary Smith at 601-878-5521. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at the Terry Community Center at 7:00 pm.

The Town of Terry routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Terry is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N		0.007	No Range	Ppb	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N		0.8	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N		0.2	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N		1.18	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N		2	None	ppt	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Volatile Organic Contaminants</b>								
73. THM [Total trihalomethanes]	Y		78 - 119	Three	ppt	0	80	By-product of drinking water chlorination
HAA5	Y		65 - 112	Four	ppb	0	60	By-product of drinking water chlorination

(73) TTHMs [Total Trihalomethanes]. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Some people who drink water containing trihalomethanes and haloacetic acids in excess of the MCL over many years experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

STATE OF MISSISSIPPI )  
 )  
COUNTY OF HINDS )

PERSONALLY CAME before me, a notary public in and for the State of Mississippi at Large, the CLERK of the *HINDS COUNTY GAZETTE*, a newspaper published in the City of Raymond, Second Judicial District of Hinds County, in said state, who being duly sworn, deposes and says that the *HINDS COUNTY GAZETTE* is a newspaper as defined and prescribed in the Mississippi Code of 1972, and the publication of a notice of which the annexed is a copy, in the matter of:

*Steven G. Terry*  
*Annual Drinking Water Quality Report*

Has been made in said paper 1 times consecutively, to-wit:

On the 11 day of June, 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_, 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_, 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_, 2009

SWORN TO and SUBSCRIBED before me, this

11 day of June, 2009

*Mary Ann Keith*  
Notary Public

*Heather Ripton*  
Clerk

To *HINDS COUNTY GAZETTE* Dr.

TO PUBLISHING

Case of \_\_\_\_\_

Word space \_\_\_\_\_ Weeks \_\_\_\_\_ Proof Charge \$3.00 – Total \$ \_\_\_\_\_

RECEIVED OF \_\_\_\_\_

Check No. \_\_\_\_\_ Date \_\_\_\_\_

Annual Drinking Water Quality Report  
Town of Terry  
PWS ID # 0250025  
May, 2009

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well that draws from the Forest Hill Sand Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. A report containing detailed information has been received by our office and will be made available for review upon request. The water supply for the Town of Terry received a low susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mary Smith at 601-878-5521. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at the Terry Community Center at 7:00 pm.

The Town of Terry routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Terry is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N		0.007	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N		0.8	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N		0.2	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N		1.18	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N		2	None	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
<b>Volatile Organic Contaminants</b>								
73. TTHM [Total trihalomethanes]	Y		78 - 119	Three	ppb	0	80	By-product of drinking water chlorination
HAA5	Y		65 - 112	Four	ppb	0	60	By-product of drinking water chlorination

(73) TTHMs [Total Trihalomethanes]. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Some people who drink water containing trihalomethanes and haloacetic acids in excess of the MCL over many years experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other



TOWN OF TERRY WATER DEPARTMENT  
 PO BOX 327  
 TERRY, MS 39170  
 (601) 878-5521

FIRST-CLASS MAIL  
 U.S. POSTAGE PAID  
 TERRY  
 PERMIT NO. 4  
 TERRY MS  
 PERMIT NO. 4

TYPE OF SERVICE	METER READING		WATER USED	CHARGES
	PRESENT	PREVIOUS		
Late Fee				10.00
Past Due				25.00

CUSTOMER		PAY GROSS AMOUNT
ROUTE	ACCOUNT	AFTER THIS DATE
1	732	7/15/09
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID
35.00		45.00

MAIL THIS STUB WITH YOUR PAYMENT

METER READ			ACCOUNT 732 6/22/09		
MONTH	DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
3	20	6	35.00	10.00	45.00

Test Bill  
 DOWNTOWN TERRY  
 TERRY MS 39170

JOIN US FOR THE TERRY FLEA MARKET JULY 4 2009  
 A CORRECTED COPY OF THE 2008 CCR REPORT IS  
 AVAILABLE AT THE TERRY CITY HALL UPON REQUEST

# 2008 CCR Contact Information

Date: 6/25/09 Time: 3:53

PWSID: 250025

System Name: Town of Terry

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) \_\_\_\_\_

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Will Publish (Cheaper) and send us a copy  
Must mail or  
publish in  
newspaper

Spoke with William Taylor 601 750-4152  
(Operator, Owner, Secretary)

Population  
1942

9/3/09 601 845-2156  
Mr Taylor will speak with Sylvia McDaniel  
who prepared the CCR on 9/4/09

9/3/09  
SECOND ATTEMPT

STATE OF MISSISSIPPI )

COUNTY OF HINDS )

PERSONALLY CAME before me, a notary public in and for the State of Mississippi at Large, the CLERK of the HINDS COUNTY GAZETTE, a newspaper published in the City of Raymond, Second Judicial District of Hinds County, in said state, who being duly sworn, deposes and says that the HINDS COUNTY GAZETTE is a newspaper as defined and prescribed in the Mississippi Code of 1972, and the publication of a notice of which the annexed is a copy, in the matter of:

Leann G. Terry  
Annual Drinking Water Quality Report

Has been made in said paper 1 times consecutively, to-wit:

On the 11 day of June, 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_, 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_, 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_, 2009

SWORN TO and SUBSCRIBED before me, this

11 day of June, 2009

Mary Ann Keith  
Notary Public

Heather Rupton  
Clerk



To HINDS COUNTY GAZETTE Dr.

TO PUBLISHING

Case of \_\_\_\_\_

Word space \_\_\_\_\_ Weeks \_\_\_\_\_ Proof Charge \$3.00 - Total \$ \_\_\_\_\_

RECEIVED OF \_\_\_\_\_

Check No. \_\_\_\_\_ Date \_\_\_\_\_