

2009 JUN 29 AM 9:47

APPROVED

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

City of Gautier
Public Water Supply Name

300004

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: 6/23/09

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: EA

Date Published: / /

- CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Joe Shust White Manger
Name/Title (President, Mayor, Owner, etc.)

6-25-09
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

30/04

Mayor
Pete Pope

City of Gautier

City Manager
Sidney M. Runnels

City Clerk
Linda M Green

Council
At Large Jeff
Wilkinson
Ward 1 Ginger Lay
Ward 2 Hurley Ray
Guillotte
Ward 3 Dick Paul
Ward 4 Don Hansford



3330 Highway 90
Gautier, MS 39553
1-228-497-8000 phone
1-228-497-8023 fax
Email:
gautier@gautier-ms.gov

2008 Annual Drinking Water Quality Report City of Gautier June 2009

During 2008, the City continued its program to expand water service to the areas annexed in February 2002. In September 2007, the City received construction bids for the extension of the water and sanitary sewer systems in the Old Spanish Trail area west of Shell Landing Boulevard. The project, awarded in January 2008, has installed approximately 4 miles of water lines and will be accepted for service in July 2009. Other service enhancements were completed throughout the water system in 2008.

The City of Gautier is pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our system pumps groundwater from eight deep groundwater wells. The water is extracted from the Miocene system, which includes the Graham Ferry and Pascagoula aquifer formations.

WELL LOCATION

Martin Bluff on Lark Street
Westgate Parkway in Westgate Estates
Martin Bluff (West) on Lark Street
Behind Singing River Mall (North of Hwy. 90)
Public Works Office
Honduras Drive and Merida Road – Point Clear
½ Mile West of Mall (South of Hwy. 90)
MS 57 vicinity Robinson Still Road

AQUIFER

Lower Graham Ferry Formation
Lower Graham Ferry Formation
Upper Pascagoula Formation
Lower Graham Ferry Formation
Lower Graham Ferry Formation
Lower Graham Ferry Formation
Lower Graham Ferry Formation
Upper Pascagoula Formation

The Bottom-Line: Is our water safe to drink? ABSOLUTELY!

Throughout 2008, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and Mississippi Department of Health (MSDH) drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about what your water contains, and how it compares to standards set by regulatory agencies. We want our valued customers to be informed about our water service.

If you have any questions about this report or concerning your water utility, please contact the **Utility Division at 497-4283**.

The Mississippi Department of Environmental Quality (MDEQ), under contract from the Mississippi State Department of Health (MSDH), has completed a source water assessment. MDEQ's rankings of groundwater wells in Mississippi range from low to moderate to high susceptibility to contamination. The City's wells were all ranked as moderate susceptibility; however, no contamination problems were noted.

The City routinely monitors for constituents in our drinking water according to Federal and State laws. The following table is a snapshot of our water quality and shows the results of our monitoring for the period of January 1st to December 31st, 2008, except as noted. As water travels over the land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity, microbial contaminants, inorganic contaminants, pesticides and herbicides, and organic chemical contaminants. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. **It's important to remember that the presence of these constituents does not necessarily pose a health risk.**

How do I read the following “Detected Contaminant Table”?

It's easier than it appears! Our water is tested to assure that it is safe and healthy. The City performed tests for over 30 contaminants during the year. If the contaminants were not found in the water supply, they were not included in the table. The column marked "Your Water" shows the highest test results detected during the year. The column headed "Likely Source of Contamination" indicates where this substance usually originates. Footnotes explain important details.

In the following table you will find many terms and abbreviations with which you might not be familiar. To help you better understand these terms we provide the following definitions:

Action Level (AL) – the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL) – The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Micrograms per liter (ug/l) – micrograms per liter is a measure of uranium in water.

Monitoring Not Required (MNR) – Monitoring is not required; however, utilities may elect to monitor.

Not Applicable (NA).

Non-Detect (ND) – laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter – one part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000.

Picocuries per liter (pCi/l) – picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) – A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Sampling Results

As you can see from the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that **YOUR WATER IS SAFE** at these levels.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water (slightly more than one quart) every day at the MCL level for a lifetime to have a one-in-a-million chance of having a health effect.

More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

A Message from MSDH Concerning Radiological Sampling

In accordance with the Radionuclides Rules, all community public water supplies were required to sample quarterly for radionuclides January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological sampling and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Maximum Residual Disinfectant Levels (MRDL)

Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water samplings indicated non-compliant chlorine residual results in February 2004, October 2004, December 2004, June 2005 and December 2008. Other monitoring requirements in these months were within standard. [JULY 2009 CORRECTION]

Detected Contaminant Table

The City regularly monitors for contaminants in the water as regulated by MSDH. Of the many contaminants tested, only these few were identified above the level of detection. Except for lead and copper, Gautier was not required to sample/test for Inorganic Contaminants in 2008; therefore, those results presented are from sampling/testing in 2006. All other sampling/testing results are from 2008. **No detected contaminant violated the established MCL.**

<u>Contaminants (units)</u>	<u>MCLG</u>	<u>MCL</u>	<u>YOUR WATER</u>	<u>Range</u>		<u>Violation</u>	<u>Typical Source</u>
				<u>Low</u>	<u>High</u>		
<u>Inorganic Contaminants</u>							
Arsenic (ppm)	0.05	0.05	0.0009	ND	0.0009	No	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.0098	0.0067	0.0098	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Cadmium (ppm)	0.005	0.005	0.0002	ND	0.0002	No	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries & paints
Chromium [Total] (ppm)	0.1	0.1	0.01	0.0025	0.0100	No	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride (ppm)	4	4	0.813	0.438	0.813	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (ppm)	0.002	0.002	0.0002	ND	0.0002	No	Erosion of natural deposits; discharge from refineries & factories; runoff from landfills & croplands
Selenium (ppm)	0.05	0.05	0.0024	0.0019	0.0024	No	Discharge from petroleum refineries; erosion of natural deposits; discharge from mines
Thallium (ppm)	0.0005	0.002	0.0008	ND	0.0008	No	Leaching from ore-processing sites; discharge from electronics, glass & drug factories
Lead (mg/l)	AL = 0.015 at 90 th percentile		0.003	---	---	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper (mg/l)	AL = 1.3 at 90 th percentile		0.5	---	---	No	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
<u>Radioactive Contaminants</u>							
Alpha Particles (pCi/l)	0	15	1.73	ND	1.73	No	Erosion of natural deposits of certain minerals
Radium 226 (pCi/l)	0	5	0.363	ND	0.363	No	Erosion of natural deposits
Radium 228 (pCi/l)	0	5	0.499	ND	0.499	No	Erosion of natural deposits
Uranium (ug/l)	0	30	0.253	0.042	0.253	No	Erosion of natural deposits
<u>Volatile Organic Contaminants</u>							
Carbon Tetrachloride (ppb)	5	5	0.857	ND	0.857	No	Discharge from chemical plants and other industrial activities
<u>Contaminants (units)</u>	<u>MCLG</u>	<u>MCL</u>	<u>Your Water</u>	<u>Range</u>		<u>Violation</u>	<u>Typical Source</u>
<u>Disinfection Byproducts</u>							
Total Trihalomethanes [TTHM] (ppb)	NA	80	24.59			No	By-product of drinking water disinfection
Haloacetic Acids [HAA5] (ppb)	NA	60	18.00			No	By-product of drinking water disinfection
Chlorine Residual (mg/l) [JULY 2009 CORRECTION]	NA	4	0.41	0.21	0.47	No	Water additive used to control microbes – This entry reports Maximum Residual Disinfectant Level (MRDL) Running Annual Average ("Your Water") and Monthly Average ("Range - Low & High")

Other Educational Information

Total Trihalomethanes (TTHM) – Some people who drink water that contains trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Gautier is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

Additional Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and some infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection from microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Summary

The City of Gautier operates a community water system that is fully compliant with all National Primary Drinking Water Regulations. We provide water to each customer that meets or exceeds the standards established by EPA and the State of Mississippi. We ask all customers assist us in protecting our water system. Please dispose of all chemicals in accordance with the procedures outlined on their containers. Be vigilant of our system's wells, elevated water storage tanks and fire hydrants and report any suspicious activity at these facilities to the police.

Please call our office at 497-4283 if you have any questions.

2008 CCR Contact Information

Date: 7/16/09 Time: 10:49

PWSID: 300004

System Name: Gautier

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) _____

2/04
10/04
12/04
6/05
12/08

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

_____ WILL DO CORRECTED COPY AND NOTIFY
_____ CUSTOMERS OF AVAILABLE CORRECTED
_____ REPORT ON WATER BILL OR LETTER
_____ AND SEND US A COPY. _____

_____ I e-mailed Jere Shuster the needed info on
_____ the CCR @ JSHUSTER@GAUTIER-MS.GOV
_____ 7/17/09 _____

Spoke with Jere Shuster 228 219-7022
(Operator, Owner, Secretary) 228 497-4283

Mayor
DeLoe Pope

Council
At Large Jeff Wilkinson
Ward 1 Ginger Loy
Ward 2 Hanky Ray Gualletti
Ward 3 Dick Paul
Ward 4 Don Casford
Ward 5 Matt Feathers

City of Gautier

Gautier, Mississippi

300004



RECEIVED-WATER SUPPLY
2009 AUG 20 AM 9:31

City Manager
Shirley W. Rundles

City Clerk
Linda W. Green

2320 Highway 90
Gautier, MS 39553
1-228-497-8000 phone
1-228-497-8028 fax
Email: gautier@gaulier-ms.gov

2008 Annual Drinking Water Quality Report City of Gautier June 2009

During 2008, the City continued its program to expand water service to the areas annexed in February 2002. In September 2007, the City received construction bids for the extension of the water and sanitary sewer systems in the Old Spanish Trail area west of Shell Landing Boulevard. The project, awarded in January 2008, has installed approximately 4 miles of water lines and will be accepted for service in July 2009. Other service enhancements were completed throughout the water system in 2008.

The City of Gautier is pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our system pumps groundwater from eight deep groundwater wells. The water is extracted from the Miocene system, which includes the Graham Ferry and Pascagoula aquifer formations.

WELL LOCATION

Martin Bluff on Lark Street
Westgate Parkway in Westgate Estates
Martin Bluff (West) on Lark Street
Behind Singing River Mall (North of Hwy. 90)
Public Works Office
Honduras Drive and Merida Road -- Point Clear
½ Mile West of Mall (South of Hwy. 90)
MS 57 vicinity Robinson Still Road

AQUIFER

Lower Graham Ferry Formation
Lower Graham Ferry Formation
Upper Pascagoula Formation
Lower Graham Ferry Formation
Lower Graham Ferry Formation
Lower Graham Ferry Formation
Lower Graham Ferry Formation
Upper Pascagoula Formation

The Bottom-Line: Is our water safe to drink? ABSOLUTELY!

Throughout 2008, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and Mississippi Department of Health (MSDH) drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about what your water contains, and how it compares to standards set by regulatory agencies. We want our valued customers to be informed about our water service.

If you have any questions about this report or concerning your water utility, please contact the **Utility Division at 497-4283**.

The Mississippi Department of Environmental Quality (MDEQ), under contract from the Mississippi State Department of Health (MSDH), has completed a source water assessment. MDEQ's rankings of groundwater wells in Mississippi range from low to moderate to high susceptibility to contamination. The City's wells were all ranked as moderate susceptibility; however, no contamination problems were noted.

The City routinely monitors for constituents in our drinking water according to Federal and State laws. The following table is a snapshot of our water quality and shows the results of our monitoring for the period of January 1st to December 31st, 2008, except as noted. As water travels over the land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity, microbial contaminants, inorganic contaminants, pesticides and herbicides, and organic chemical contaminants. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. **It's important to remember that the presence of these constituents does not necessarily pose a health risk.**

How do I read the following “Detected Contaminant Table”?

It's easier than it appears! Our water is tested to assure that it is safe and healthy. The City performed tests for over 30 contaminants during the year. If the contaminants were not found in the water supply, they were not included in the table. The column marked “Your Water” shows the highest test results detected during the year. The column headed “Likely Source of Contamination” indicates where this substance usually originates. Footnotes explain important details.

In the following table you will find many terms and abbreviations with which you might not be familiar. To help you better understand these terms we provide the following definitions:

Action Level (AL) – the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL) – The “Maximum Allowed” is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Micrograms per liter (ug/l) – micrograms per liter is a measure of uranium in water.

Monitoring Not Required (MNR) – Monitoring is not required; however, utilities may elect to monitor.

Not Applicable (NA).

Non-Detect (ND) – laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter – one part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000.

Picocuries per liter (pCi/l) – picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) – A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Sampling Results

As you can see from the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that **YOUR WATER IS SAFE** at these levels.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water (slightly more than one quart) every day at the MCL level for a lifetime to have a one-in-a-million chance of having a health effect.

More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

A Message from MSDH Concerning Radiological Sampling

In accordance with the Radionuclides Rules, all community public water supplies were required to sample quarterly for radionuclides January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological sampling and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Maximum Residual Disinfectant Levels (MRDL)

Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water samplings indicated non-compliant chlorine residual results in February 2004, October 2004, December 2004, June 2005 and December 2008. Other monitoring requirements in these months were within standard. [JULY 2009 ADDITION]

Detected Contaminant Table

The City regularly monitors for contaminants in the water as regulated by MSDH. Of the many contaminants tested, only these few were identified above the level of detection. Except for lead and copper, Gautier was not required to sample/test for Inorganic Contaminants in 2008; therefore, those results presented are from sampling/testing in 2006. All other sampling/testing results are from 2008. **No detected contaminant violated the established MCL.**

<u>Contaminants (units)</u>	<u>MCLG</u>	<u>MCL</u>	<u>YOUR WATER</u>	<u>Range</u>		<u>Violation</u>	<u>Typical Source</u>
				<u>Low</u>	<u>High</u>		
<u>Inorganic Contaminants</u>							
Arsenic (ppm)	0.05	0.05	0.0009	ND	0.0009	No	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.0098	0.0067	0.0098	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Cadmium (ppm)	0.005	0.005	0.0002	ND	0.0002	No	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries & paints
Chromium [Total] (ppm)	0.1	0.1	0.01	0.0025	0.0100	No	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride (ppm)	4	4	0.813	0.438	0.813	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (ppm)	0.002	0.002	0.0002	ND	0.0002	No	Erosion of natural deposits; discharge from refineries & factories; runoff from landfills & croplands
Selenium (ppm)	0.05	0.05	0.0024	0.0019	0.0024	No	Discharge from petroleum refineries; erosion of natural deposits; discharge from mines
Thallium (ppm)	0.0005	0.002	0.0008	ND	0.0008	No	Leaching from ore-processing sites; discharge from electronics, glass & drug factories
Lead (mg/l)	AL = 0.015 at 90 th percentile		0.003	---	---	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper (mg/l)	AL = 1.3 at 90 th percentile		0.5	---	---	No	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
<u>Radioactive Contaminants</u>							
Alpha Particles (pCi/l)	0	15	1.73	ND	1.73	No	Erosion of natural deposits of certain minerals
Radium 226 (pCi/l)	0	5	0.363	ND	0.363	No	Erosion of natural deposits
Radium 228 (pCi/l)	0	5	0.499	ND	0.499	No	Erosion of natural deposits
Uranium (ug/l)	0	30	0.253	0.042	0.253	No	Erosion of natural deposits
<u>Volatile Organic Contaminants</u>							
Carbon Tetrachloride (ppb)	5	5	0.857	ND	0.857	No	Discharge from chemical plants and other industrial activities
<u>Contaminants (units)</u>	<u>MCLG</u>	<u>MCL</u>	<u>Your Water</u>	<u>Range</u>		<u>Violation</u>	<u>Typical Source</u>
				<u>Low</u>	<u>High</u>		
<u>Disinfection Byproducts</u>							
Total Trihalomethanes [TTHM] (ppb)	NA	80	24.59			No	By-product of drinking water disinfection
Haloacetic Acids [HAA5] (ppb)	NA	60	18.00			No	By-product of drinking water disinfection
Chlorine Residual (mg/l) [JULY 2009 ADDITION]	NA	4	0.41	0.21	0.47	No	Water additive used to control microbes – This entry reports Maximum Residual Disinfectant Level (MRDL) Running Annual Average (“Your Water”) and Monthly Average (“Range - Low & High”)

Other Educational Information

Total Trihalomethanes (TTHM) – Some people who drink water that contains trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Gautier is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

Additional Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and some infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection from microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Summary

The City of Gautier operates a community water system that is fully compliant with all National Primary Drinking Water Regulations. We provide water to each customer that meets or exceeds the standards established by EPA and the State of Mississippi. We ask all customers assist us in protecting our water system. Please dispose of all chemicals in accordance with the procedures outlined on their containers. Be vigilant of our system's wells, elevated water storage tanks and fire hydrants and report any suspicious activity at these facilities to the police.

Please call our office at 497-4283 if you have any questions.

CITY OF GAUTIER

P.O. BOX 670 • GAUTIER, MS 39553

* ACCOUNT NUMBER REQUIRED ON CHECKS

BILLING DATE	DELINQUENT DATE	CUT-OFF DATE	ROUTE	
08/08/09	09/02/09	09/03/09	20	110
RATE CLASS	CODE	SERVICE THROUGH	ACCOUNT NUMBER	
GSW	R	06/26 - 07/28	041373	
TYPE	PRESENT READING	PREVIOUS READING	CONSUMPTION	AMOUNT
BF				
S				
G				

TOTAL AMOUNT DUE

CCR REVISED COPY AVAILABLE UPON REQUEST

LAST DAY TO PAY
09/02/09

PAY →

LATE AMOUNT

RETURN SERVICE REQUESTED

ROUTE	DELINQUENT DATE	
20 110	09/02/09	
ACCOUNT NUMBER	BILL AMOUNT	LATE AMOUNT
041373		

PRESORTED
FIRST CLASS
MAIL
U.S. POSTAGE
PAID
GAUTIER, MS
PERMIT # 10

PLEASE RETURN THIS STATEMENT

GREATHOUSE CASI L.
1504 HASTINGS
GAUTIER MS
39553