

APPROVED

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

j

Lily Rose Water Association
Public Water Supply Name

PWS ID # 330005 & 330009
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
Advertisement in local paper
On water bills
Other

Date customers were informed: 06/17 / 2009

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 6/22/09 Back of Billing card (Notice)

- CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: The Prentiss Headlight

Date Published: 06 /17 / 09

- CCR was posted in public places. (Attach list of locations)

Date Posted: 06 /15/09 : Office Lobby of Lily Rose Water Assn.

- CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above.

[Handwritten Signature]

Name/Title (President, Mayor, Owner, etc.)

6-22-09
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

PROOF OF PUBLICATION

THE PRENTISS HEADLIGHT
P.O. BOX 1257
PRENTISS, MS 39474
(601)792-4221

THE STATE OF MISSISSIPPI, COUNTY OF JEFFERSON DAVIS:

Personally appeared before me, the undersigned authority in and for the County and State aforesaid, Patsy Speights, who having been by me first duly sworn, states on oath that she is the General Manager of THE PRENTISS HEADLIGHT, a legal newspaper established and having a general circulation in the Town of Prentiss and said County and State aforesaid for more than twelve months prior to the first publication of the notice herein, a copy of which is hereto attached, and that said notice has been published in said newspaper _____ consecutive times with the respective numbers and dates as follows:


VOL. 103 NO. 40 ON THE 17th DAY OF June, 2009
VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____



Patsy Speights
General Manager

SWORN TO AND SUBSCRIBED BEFORE ME THIS 17th DAY OF June, 2009

NOTARY



Notary Public State of Mississippi At Large
My Commission Expires: November 5, 2009
Bonded Through Heinen, Brooks & Garland, Inc.

LILY ROSE WATER OFFICE HOURS
MONDAY - FRIDAY, 8:30 A.M. - 4:30 P.M.

PAYMENT IS DUE ON OR BEFORE
WEDNESDAY, JULY 15, 2009 TO AVOID
LATE FEES.

BILL MUST BE PAID TO A ZERO BALANCE
ON OR BEFORE MONDAY, JULY 27,
2009 TO AVOID LOCK-UP.

IF YOU HAVE A PREVIOUS BALANCE ON
THIS BILL, LOCK UP FOR THAT BALANCE
IS MONDAY, JUNE 29, 2009.

ALL WATER PROJECT AREA CONTINUE
TO BOIL DRINKING WATER UNTIL
FURTHER NOTICE DURING
CONSTRUCTION.

CCR REPORT IS PUBLISHED IN THE
LAWRENCE COUNTY PRESS AND THE
PRENTISS HEADLIGHT ALSO A COPY IS
AVAILABLE IN THE OFFICE

**2008 Annual Drinking Water Quality Report
Lily Rose Water Association
PWS #330005/330009
June 10, 2009**

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Lily Rose Water vigilantly safeguards its water supplies and once again we are proud to report that our system has never violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Lily Rose Water Association routinely draws from 2 wells that draws from the Miocene Series Aquifer. I am pleased to report that our drinking water meets all federal and state requirements.

Source water assessment and its availability

Source Water Assessment Plan is available for review at the water office Monday-Friday from 8:30 a.m. - 4:30 p.m.

How can I get involved?

Lily Rose Water conducts monthly board meetings at the water office and the annual meeting is on the second Tuesday of December at 7:00 p.m. at a designated location.

**For more information contact:
Lily Rose Water Association, Inc.
Attn: Corky Holliman
P.O. Box 1042
1705 Columbia Avenue
Prentiss, Ms 39474-1042
Office Phone: 601-792-8699
Cell Phone: 601-750-9711
Fax: 601-792-4835
Email: lrwa2005@windstream.net**

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lily Rose Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system failed to complete these monitoring requirements on **Well 09** in February 2004, April 2004, November 2004, January 2006, April 2006, and April 2007; on **Well 05** in April 2006 and April 2007. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2008 - December 2008. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Important Drinking Water Definitions:

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

WELL 05/WELL 09

Contaminants (units)	MCLG	MCL	Your Water	Range Low High	Sample Date	Violatio	Typical Source	
Inorganic Contaminants								
Barium (ppm)	Well 05 (Hwy 84)	2	2	0.006470	0 2	----	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
	Well 09 (Hwy 42)	2	2	0.011723	0 2			
	Well 09 (Hwy 13)	2	2	0.014435	0 2			
Nitrate [meas	Well 05 (Hwy 84)	10	10	0.40	0 10	----	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrogen] (ppm)	Well 09 (Hwy 42)	10	10	0.40	0 10			
	Well 09 (Hwy 13)	10	10	0.08	0 10			

Contaminant(s) (units)	MCLG	AL	Your Water	# of Samples > AL	Sample Date	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper (ppm)	Well 05 (Hwy 84) 1.3	1.3	0.9	0	12/31/2008	No	Erosion of natural deposits; Leaching	
	Well 09	1.3	1.3	0.5	0	12/31/2008	from wood preservatives; Corrosion of household plumbing systems	
Lead (ppb)	Well 05 (Hwy 84) 0	15	0.004	0	12/31/2008	No	Corrosion of household plumbing systems; Erosion of natural deposits	
	Well 09	0	15	0.004	0	12/31/2008		
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Haloacetic Acids (HAAs) (ppb)	Well 09	NA	60	1.8	NA	08/09/2007	No	By-product of drinking water chlorination
	Well 05	NA	60	0.0	NA	08/09/2007		
TTHMs [Total Trihalomethanes]	Well 09	NA	80	0.0	NA	08/09/2007	No	By-product of drinking water chlorination
	Well 05	NA	80	0.0	NA	08/09/2007		

Units Description:

NA: Not applicable

ND: Not detected

NR: Not reported

MNR: Monitoring not required, but recommended.

ppm: parts per million, or milligrams per liter (mg/l)

ppb: parts per billion, or micrograms per liter (µg/l)

2008 Annual Drinking Water Quality Report
Lily Rose Water Association
PWS #330005/330009
June 10, 2009

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Lily Rose Water vigilantly safeguards its water supplies and once again we are proud to report that our system has never violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Lily Rose Water Association routinely draws from 2 wells that draws from the Miocene Series Aquifer. I am pleased to report that our drinking water meets all federal and state requirements.

Source water assessment and its availability

Source Water Assessment Plan is available for review at the water office Monday-Friday from 8:30 a.m. - 4:30 p.m.

How can I get involved?

Lily Rose Water conducts monthly board meetings at the water office and the annual meeting is on the second Tuesday of December at 7:00 p.m. at a designated location.

For more information contact:
Lily Rose Water Association, Inc.
Attn: Corky Holliman
P.O. Box 1042
1705 Columbia Avenue
Prentiss, Ms 39474-1042
Office Phone: 601-792-8699
Cell Phone: 601-750-9711
Fax: 601-792-4835
Email: lrwa2005@windstream.net

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lily Rose Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing

methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system failed to complete these monitoring requirements on **Well 09** in February 2004, April 2004, November 2004, January 2006, April 2006, and April 2007; on **Well 05** in April 2006 and April 2007. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

*******A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2008 - December 2008. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiologicla compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Important Drinking Water Definitions:

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

WELL 05/WELL 09

Contaminants (units)	MCLG	MCL	Your Water	Range Low High	Sample Date	Violatio	Typical Source
Inorganic Contaminants							
Barium (ppm)	Well 05 (Hwy 84) 2	2	0.006470	0 2	----	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
	Well 09 (Hwy 42) 2	2	0.011723	0 2			
	Well 09 (Hwy 13) 2	2	0.014435	0 2			
Nitrate [meas Nitrogen] (ppm)	Well 05 (Hwy 84) 10	10	0.40	0 10	----	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
	Well 09 (Hwy 42) 10	10	0.40	0 10			
	Well 09 (Hwy 13) 10	10	0.08	0 10			

Contaminant(s) (units)	MCLG	AL	Your Water	# of Samples > AL	Sample Date	Exceeds AL	Typical Source
Inorganic Contaminants							
Copper (ppm)	Well 05 (Hwy 84) 1.3	1.3	0.9	0	12/31/2008	No	Erosion of natural deposits; Leaching

2008 Annual Drinking Water Quality Report
Lily Rose Water Association
PWS #330005/330000
June 10, 2009

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Lily Rose Water vigilantly safeguards its water supplies and once again we are proud to report that our system has never violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Lily Rose Water Association routinely draws from 2 wells that draws from the Miocene Series aquifer. I am pleased to report that our drinking water meets all federal and state requirements.

Source water assessment and its availability

Source Water Assessment Plan is available for review at the water office Monday-Friday from 8:00 a.m. - 4:30 p.m.

How can I get involved?

Lily Rose Water conducts monthly board meetings at the water office and the annual meeting is on the second Tuesday of December at 7:00 p.m. at a designated location.

For more information contact:
Lily Rose Water Association, Inc.
Attn: Corky Holliman
P.O. Box 1042
1705 Columbia Avenue
Prentiss, Ms 39474-1042
Office Phone: 601-792-8699
Cell Phone: 601-750-9711
Fax: 601-792-4835
Email: lrwa2005@windstream.net

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lily Rose Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing

methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.5882 if you wish to have your water tested.

We are required to monitor your drinking water for specific constituents on a monthly basis. Benefits of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system failed to complete these monitoring requirements on Well 09 in February 2004, April 2004, November 2004, January 2005, April 2006, and April 2007; on Well 05 in April 2006 and April 2007. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

*******A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2008 - December 2008. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentration of these contaminants do not change frequently.

Important Drinking Water Definitions:

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

WELL 05/WELL 09

Contaminants (units)	MCLG	MCL	Year Water	Range Low High	Sample Date	Violatio	Typical Source
Inorganic Contaminants							
Barium (ppm)	Well 05 (Hwy 84) 2	2	06/470	0 2	----	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
	Well 09 (Hwy 42) 2	2	01/723	0 2			
	Well 09 (Hwy 13) 2	2	01/435	0 2			
Nitrate [meas Nitrogen] (ppm)	Well 05 (Hwy 84) 10	10	0.40	0 10	----	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
	Well 09 (Hwy 42) 10	10	0.40	0 10			
	Well 09 (Hwy 13) 10	10	0.08	0 10			

Contaminant(s) (units)	MCLG	AL	Year Water	# of Samples > AL	Sample Date	Exceeds AL	Typical Source
Inorganic Contaminants							
Copper (ppm)	Well 05 (Hwy 84) 1.3	1.3	06/08	0	12/31/2008	No	Erosion of natural deposits; Leaching

Your Contaminants (units)	MCLG	MCL	Water	Range		Sample Date	Violatio	Typical Source
				Low	High			
				0.5	0	12/31/2008		from well reservatives; Corrosion of household plumbing systems
Lead (ppb)	Well 05 (Hwy 84)	0	15	0.004	0	12/31/2008	No	Corrosion of household plumbing systems; leachon of natural deposits
	Well 09	0	15	0.004	0	12/31/2008		

Disinfectants & Disinfection By-Products

(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)

Haloacetic Acids (HAA5) (ppb)	Well 09	NA	60	0	NA	08/09/2007	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes]	Well 09	NA	80	0	NA	08/09/2007	No	By-product of drinking water chlorination
Chlorine	Well 05	NA		1.12	1.32	12/31/2008		Water additive used to control microbes
Chlorine	Well 09	NA		1.15	1.37	12/31/2008		Water additive used to control microbes

Units Description:

NA: Not applicable

ND: Not detected

NR: Not reported

MNR: Monitoring not required, but recommended.

ppm: parts per million, or milligrams per liter (mg/l)

ppb: parts per billion, or micrograms per liter (µg/l)

PROOF OF PUBLICATION

THE PRENTISS HEADLIGHT

P.O. BOX 1257

PRENTISS, MS 39474

(601)792-4221

THE STATE OF MISSISSIPPI, COUNTY OF JEFFERSON DAVID S:

Personally appeared before me, the undersigned authority in and for the County and State aforesaid, Patsy Speights, who having been by me first duly sworn, states on oath that she is the General Manager of THE PRENTISS HEADLIGHT, a legal newspaper established and having a general circulation in the Town of Prentiss and said County and State aforesaid for more than twelve months prior to the first publication of the notice herein, a copy of which is hereto attached, and that said notice has been published in said newspaper _____ consecutive times with the respective numbers and dates as follows:

- VOL. 103 NO. 40 ON THE 17th DAY OF June, 2009
- VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
- VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
- VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
- VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
- VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____

Patsy Speights

Patsy Speights
General Manager

SWORN TO AND SUBSCRIBED BEFORE ME THIS 17th DAY OF June, 2009

NOTARY

Gracy Warts

Notary Public State of Mississippi At Large
My Commission Expires: November 5, 2009
Bonded Thru Heiden, Eerooks & Gardner, Inc.

LILY ROSE WATER ASSOCIATION, INC
P.O. BOX 1042
PRENTISS, MS 39474
601-792-8699/ FAX 601-792-4835

FAX COVER SHEET

DATE: July 1, 2009

COMPANY NAME: Lily Rose Water Assn.

TO: Joan Cockrell

FAX NUMBER (601) 576-7800

FROM: Maria Bridges

COMMENTS :

NUMBER OF SHEETS: 5 including cover

2008 CCR Contact Information

Date: 6/30/09 Time: 12:49

PWSID: 330005/330009

System Name: Lily Rose

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) _____

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Will do corrected copy and notify customers
of available corrected copy on water bill and
send us a copy.

Spoke with Mason Holliman 601 750-9711
(Operator, Owner, Secretary)

Mr. Holliman
Also have
330008
Rural Water prepared
Call him on this system if
a correction is need he will contact Rural Water.

2008 Annual Drinking Water Quality Report
Lily Rose Water Association
PWS #330005/330009
June 10, 2009

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Lily Rose Water vigilantly safeguards its water supplies and once again we are proud to report that our system has never violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Lily Rose Water Association routinely draws from 2 wells that draws from the Miocene Series Aquifer. I am pleased to report that our drinking water meets all federal and state requirements.

Source water assessment and its availability

Source Water Assessment Plan is available for review at the water office Monday-Friday from 8:30 a.m. - 4:30 p.m.

How can I get involved?

Lily Rose Water conducts monthly board meetings at the water office and the annual meeting is on the second Tuesday of December at 7:00 p.m. at a designated location.

For more information contact:
Lily Rose Water Association, Inc.
Attn: Corky Holliman
P.O. Box 1042
1705 Columbia Avenue
Prentiss, Ms 39474-1042
Office Phone: 601-792-8699
Cell Phone: 601-750-9711
Fax: 601-792-4835
Email: lrwa2005@windstream.net

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lily Rose Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water testing

methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7182 if you wish to have your water tested.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system failed to complete these monitoring requirements on **Well 09** in February 2004, April 2004, November 2004, January 2005, April 2006, and April 2007; on **Well 05** in April 2006 and April 2007. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

*******A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2008 - December 2008. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Important Drinking Water Definitions:

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

WELL 05/WELL 09

Contaminants (units)	MCLG	MCL	Year	Range		Sample Date	Violation	Typical Source
				Low	High			
Inorganic Contaminants								
Barium (ppm)								
Well 05 (Hwy 84)	2	2	0.05470	0	2	---	No	Discharge of drilling wastes.
Well 09 (Hwy 42)	2	2	0.11723	0	2			Discharge from metal refineries
Well 09 (Hwy 13)	2	2	0.04435	0	2			Erosion of natural deposits
Nitrate [meas								
Well 05 (Hwy 84)	10	10	0.40	0	10	---	No	Runoff from fertilizer use; Leaching
Nitrogen] (ppm)								
Well 09 (Hwy 42)	10	10	0.40	0	10			from septic tanks, sewage; Erosion of
Well 09 (Hwy 13)	10	10	0.08	0	10			natural deposits

Contaminant(s) (units)	MCLG	AL	Year	# of Samples > AL	Sample Date	Exceeds AL	Typical Source
Inorganic Contaminants							
Copper (ppm)							
Well 05 (Hwy 84)	1.3	1.3	0.0	0	12/31/2008	No	Erosion of natural deposits; Leaching

Your Contaminants (units)	MCLG	MCL	Water	Range		Sample Date	Violatio	Typical Source
				Low	High			
		1.3	1.3	0.5	0	12/31/2008		from wood preservatives; Corrosion of household plumbing systems
Lead (ppb)	Well 05 (Hwy 84)	0	15	0.004	0	12/31/2008	No	Corrosion of household plumbing systems
	Well 09	0	15	0.004	0	12/31/2008		Corrosion of household plumbing systems; Deposition of natural deposits
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Haloacetic Acids (HAA5) (ppb)	Well 09	NA	60	ND	NA	08/09/2007	No	By-product of drinking water chlorination
	Well 05	NA	60	ND	NA	08/09/2007		
TTHMs [Total	Well 09	NA	80	ND	NA	08/09/2007	No	By-product of drinking water chlorination
Trihalomethanes]	Well 05	NA	80	ND	NA	08/09/2007		
Chlorine	Well 05	NA		1.12	1.32	12/31/2008		Water additive used to control microbes
Chlorine	Well 09	NA		1.15	1.37	12/31/2008		Water additive used to control microbes

Units Description:

NA: Not applicable

ND: Not detected

NR: Not reported

MNR: Monitoring not required, but recommended.

ppm: parts per million, or milligrams per liter (mg/l)

ppb: parts per billion, or micrograms per liter (µg/l)

2008 CCR Contact Information

Date: 6/30/09

Time: 12:49

PWSID: 330005/330009

System Name: Lily Rose

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) _____

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Will do corrected copy and notify customers
of available corrected copy on water bill and
send us a copy.

Spoke with Macon Holliman 601 750-9711
(Operator, Owner, Secretary)

Mr. Holliman

Also have

330008

Floral Water prepared

Call him on this system IF

problem is need he will contact Rural Water.

Copy

BUREAU OF PUBLIC WATER SUPPLY
CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

Lily Rose Water Association
 Public Water Supply Name

PWS ID # 330005 & 330009
 List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and disseminate a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers in person.

e a consumer
 tem, this CCR
 request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: 06/17 / 2009

- CCR was distributed by mail or other direct delivery. Specify other direct delivery method: _____

Date Mailed/Distributed: 6/22/09 *Back of Billing card (Notice)*

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Prentiss Headlight

Date Published: 06 /17 / 09

- CCR was posted in public places. *(Attach list of locations)*


Date Posted: 06 /15 /09 : Office Lobby of Lily Rose Water Assn.

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true, correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

water system in
 correct and is
 ssissippi State



 Name/Title (President, Mayor, Owner, etc.)

6-22-09
 Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39201
 Phone: 601-576-7518

RECEIVED-WATER SUPPLY
2009 JUN 11 8:58

2008 Annual Drinking Water Quality Report
Lily Rose Water Association
PWS #330005/330009
June 10, 2009

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Lily Rose Water vigilantly safeguards its water supplies and once again we are proud to report that our system has never violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Lily Rose Water Association routinely draws from 2 wells that draws from the Miocene Series Aquifer. I am pleased to report that our drinking water meets all federal and state requirements.

Source water assessment and its availability

Source Water Assessment Plan is available for review at the water office Monday-Friday from 8:30 a.m. - 4:30 p.m.

How can I get involved?

Lily Rose Water conducts monthly board meetings at the water office and the annual meeting is on the second Tuesday of December at 7:00 p.m. at a designated location.

**For more information contact:
Lily Rose Water Association, Inc.
Attn: Corky Holliman
P.O. Box 1042
1705 Columbia Avenue
Prentiss, Ms 39474-1042
Office Phone: 601-792-8699
Cell Phone: 601-750-9711
Fax: 601-792-4835
Email: lrwa2005@windstream.net**

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lily Rose Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing

methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system failed to complete these monitoring requirements on **Well 09** in February 2004, April 2004, November 2004, January 2006, April 2006, and April 2007; on **Well 05** in April 2006 and April 2007. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

*******A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2008 - December 2008. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiologicla compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants not change frequently.

Important Drinking Water Definitions:

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

RECEIVED - WATER SUPPLY
2009 JUL 13 AM 8:58

WELL 05/WELL 09

Contaminants (units)	MCLG	MCL	Your Water	Range Low	High	Sample Date	Violatio	Typical Source
Inorganic Contaminants								
Barium (ppm)	Well 05 (Hwy 84) 2	2	0.006470	0	2	----	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
	Well 09 (Hwy 42) 2	2	0.011723	0	2			
	Well 09 (Hwy 13) 2	2	0.014435	0	2			
Nitrate [meas Nitrogen] (ppm)	Well 05 (Hwy 84) 10	10	0.40	0	10	----	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
	Well 09 (Hwy 42) 10	10	0.40	0	10			
	Well 09 (Hwy 13) 10	10	0.08	0	10			

Contaminant(s) (units)	MCLG	AL	Your Water	# of Samples > AL	Sample Date	Exceeds AL	Typical Source
Inorganic Contaminants							
Copper (ppm)	Well 05 (Hwy 84) 1.3	1.3	0.9	0	12/31/2008	No	Erosion of natural deposits; Leaching

PROOF OF PUBLICATION

THE PRENTISS HEADLIGHT

P.O. BOX 1257

PRENTISS, MS 39474

(601)792-4221

RECEIVED-WATER SUPPLY

2009 JUL 13 AM 8:58

THE STATE OF MISSISSIPPI, COUNTY OF JEFFERSON DAVIS:

Personally appeared before me, the undersigned authority and for the County and State aforesaid, Patsy Speights, who having been by me first duly sworn, states on oath that she is the General Manager of THE PRENTISS HEADLIGHT, a legal newspaper established and having a general circulation in the Town of Prentiss and said County and State aforesaid for more than twelve months prior to the first publication of the notice herein, a copy of which is hereto attached, and that said notice has been published in said newspaper _____ consecutive times with the respective numbers and dates as follows:

- VOL. 103 NO. 40 ON THE 17th DAY OF June, 2009
- VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
- VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
- VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
- VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____
- VOL. _____ NO. _____ ON THE _____ DAY OF _____, 20____

Patsy Speights

Patsy Speights
General Manager

SWORN TO AND SUBSCRIBED BEFORE ME THIS 17th DAY OF June, 2009

NOTARY

Tracy Watts

Notary Public State of Mississippi At Large
My Commission Expires: November 5, 2009
Bonded Thru Heiden, Brooks & Garland, Inc.