

2009 JUN 29 AM 9:08

APPROVED

## BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORMSANDERS WATER ASSOCIATION  
Public Water Supply Name0360064  
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

*Please Answer the Following Questions Regarding the Consumer Confidence Report*

Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)

- Advertisement in local paper  
 On water bills  
 Other \_\_\_\_\_

Date customers were informed: 06/10/09

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed:  / /

CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: THE OXFORD EAGLE, OXFORD, MS 38655Date Published: 06/23/09

CCR was posted in public places. (*Attach list of locations*)

Date Posted:  / /

CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Craig McCormick, BOARD PRESIDENT  
Name/Title (President, Mayor, Owner, etc.)

06/25/09  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

# 2008 Drinking Water Quality Report

## Sanders Water Association

### PWS ID#: 360064 - June 2009

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. Our water source is presently two wells that draws ground water from the Ripley Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Sanders Water Association have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact James M. Coffey, 534-3261. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. The board typically meets bimonthly on the third Tuesday of February, April, June, August, October and December at the Philadelphia Fire Station at 7:00 p.m. Our annual meeting is held near the end of June each year. Notices are sent to all members announcing this meeting.

Sanders Water System routinely monitors for constituents in your drinking water according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2008. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

### Terms and Abbreviations used in the Table

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in 2 years, or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**MCLG:** Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MCL:** Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**AL:** Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

### TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely source of contaminant
<b>Inorganic Contaminants</b>								
Fluoride	N	02/27/06*	1.87	1.07 - 1.87	Ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Barium	N	02/27/06*	.01	.009 - .010	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	N	02/27/06*	.001	No range	ppm	100	100	Erosion of Natural deposits; Discharge from steel and pulp mills.
Copper	N	01/01/06-12/31/08	.000	0	ppm	1.3	AL= 1.3	Erosion of natural deposits; Leaching; Corrosion of household plumbing systems; from wood preservatives
Lead	N	01/01/06-12/31/08	.001	0	ppb	0	AL= 15	Corrosion of household plumbing systems; Erosion of natural deposits.
Nitrate (As Nitrogen)	N	06/16/08	.08	No Range	ppm	10	10	Runoff from fertilizer use, leaching from septic tanks, sewage; erosion from natural deposits.
Nitrite (As Nitrogen)	N	06/16/08	.02	No Range	ppm	1	1	Runoff from fertilizer use, leaching from septic tanks, sewage; erosion from natural deposits.

*\*Most recent sample, no sample required for 2008*

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however they are not above the level considered unsafe.

### **Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sanders Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

#### **\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public water supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders. Some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by crypto sporidium and other microbiological contaminants are available from the Safe Drinking Water Hot Line (800.426.4791).

We do our best to provide quality water at every tap. Should you notice a drop in pressure or observe a leak on the system, please call James M. Coffey, 534-3261 or Cary Cormick, 234-6859. We ask that all our customers help us protect our water sources.

A valuable part of our community is our water source and will be valuable for future generations.

# PROOF OF PUBLICATION

PRINTER'S FEE \$ 18445

THE STATE OF MISSISSIPPI  
LAFAYETTE COUNTY

Personally appeared before me, a notary public in and for said county and State, the undersigned

Tim Phillips

Who, after being duly sworn, deposes and says that he is the Co-Publisher of the Oxford Eagle, a newspaper published daily in the City of Oxford, in said county and State, and that the said newspaper has been published for more than one year and that *Sanders Water Assoc. 2008 Report - PWS - # 360064*

a true copy of which is hereto attached was published for 7 consecutive weeks in said newspaper as follows:

VOLUME  
141

NO.  
189

DATE  
June 23, 2009

**2008 Drinking Water Quality Report  
Sanders Water Association  
PWS ID#: 360064 - June 2009**

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. Our water source is presently two wells that draw ground water from the Ripley Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Sanders Water Association have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact James M. Coffey, 534-3261. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. The board typically meets bimonthly on the third Tuesday of February, April, June, August, October and December at the Philadelphia Fire Station at 7:00 p.m. Our annual meeting is held near the end of June each year. Notices are sent to all members announcing this meeting.

Sanders Water System routinely monitors for constituents in your drinking water according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2008. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

**Terms and Abbreviations used in the Table**

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in 2 years, or a single penny in \$10,000.  
Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.  
MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.  
MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as is feasible using the best available treatment technology.  
AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely source of contaminant
<b>Inorganic Contaminants</b>								
Fluoride	N	02/27/08*	1.87	1.07 - 1.87	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Boron	N	02/27/08*	.01	.009 - .010	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	N	02/27/08*	.001	No range	ppm	(0)	100	Erosion of Natural deposits; Discharge from steel and pulp mills.
Copper	N	01/21/08-12/21/08	.000	0	ppm	1.3	AL: 1.3	Erosion of natural deposits; Leaching; Corrosion of household plumbing systems; from wood preservatives.
Lead	N	01/21/08-12/21/08	.001	0	ppb	0	AL: 15	Corrosion of household plumbing systems; Erosion of natural deposits.
Nitrate (As Nitrogen)	N	06/16/08	.08	No Range	ppm	10	10	Runoff from fertilizer use, leaching from septic tanks, sewage; erosion from natural deposits.
Nitrite (As Nitrogen)	N	06/16/08	.02	No Range	ppm	1	1	Runoff from fertilizer use, leaching from septic tanks, sewage; erosion from natural deposits.

\*Most recent sample, no sample required for 2008

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however they are not above the level considered unsafe.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sanders Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

**\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders. Some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by crypto sporidium and other microbiological contaminants are available from the Safe Drinking Water Hot Line (800.426.4791).

We do our best to provide quality water at every tap. Should you notice a drop in pressure or observe a leak on the system, please call James M. Coffey, 534-3261 or Cary Cormick, 234-6859. We ask that all our customers help us protect our water sources. A valuable part of our community is our water source and will be valuable for future generations.

Published: June 23, 2009

*Tim Phillips*

Sworn to and subscribed before me this

23rd day of June, 2009

*Rita G. Vasilyev*

Notary Public, Lafayette County, Mississippi

My commission expires



ACCOUNT NUMBER	DATE BILL MAILED
6550	06/01/09
PRESENT READING	SERVICE FROM
1300	04/24/09
PREVIOUS READING	SERVICE TO
1300	05/26/09
UNITS USED	DAYS USED
0	32
DESCRIPTION	AMOUNT
WATER	17.00
CREDIT	-119.00

CURRENT BILL DUE DATE	AMOUNT DUE BY DUE DATE
06/10/09	-102.00
AMOUNT DUE AFTER DUE DATE	-102.00

SERVICE ADDRESS: PH: 534-3261  
 KEEP THIS STUB  
 FOR YOUR RECORDS

RETURN THIS STUB WITH PAYMENT TO:  
 SANDERS WATER ASSOCIATION  
 P.O. BOX 8  
 ETTA, MS 38627

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE PAID

CREDIT BALANCE \* DO NOT PAY

ACCOUNT NUMBER	DUE DATE	AMOUNT DUE AFTER DUE DATE	AMOUNT DUE BY DUE DATE
6550	06/10/09	-102.00	-102.00

THE 2008 CONSUMER CONFIDENCE REPORT IS  
 AVAILABLE ON REQUEST AND WILL BE PUBLISHED  
 IN THE OXFORD EAGLE PAPER.

RETURN SERVICE REQUESTED

1789 HWY 355  
 Etta, MS 38627

**2008 Drinking Water Quality Report**  
**Sanders Water Association**  
**PWS ID#: 360064 - June 2009**

RECEIVED-WATER SUPPLY  
2009 AUG -7 AM 8: 52

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. Our water source is presently two wells that draws ground water from the Ripley Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Sanders Water Association have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact James M. Coffey, 534-3261. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. The board typically meets bimonthly on the third Tuesday of February, April, June, August, October and December at the Philadelphia Fire Station at 7:00 p.m. Our annual meeting is held near the end of June each year. Notices are sent to all members announcing this meeting.

Sanders Water System routinely monitors for constituents in your drinking water according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2008. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

**Terms and Abbreviations used in the Table**

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in 2 years, or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**MCLG:** Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MCL:** Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**AL:** Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**TT:** Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

**MRDLG:** Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDGLs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**MRDL:** Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.



### TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely source of contaminant
<b>Inorganic Contaminants</b>								
Fluoride	N	02/27/06*	1.87	1.07 - 1.87	Ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Barium	N	02/27/06*	.01	.009 - .010	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	N	02/27/06*	.001	No range	ppm	100	100	Erosion of Natural deposits; Discharge from steel and pulp mills.
Copper	N	01/01/06-12/31/08	.000	0	ppm	1.3	AL= 1.3	Erosion of natural deposits; Leaching; Corrosion of household plumbing systems; from wood preservatives
Lead	N	01/01/06-12/31/08	.001	0	ppb	0	AL= 15	Corrosion of household plumbing systems; Erosion of natural deposits.
Nitrate (As Nitrogen)	N	06/16/08	.08	No Range	ppm	10	10	Runoff from fertilizer use, leaching from septic tanks, sewage; erosion from natural deposits.
Nitrite (As Nitrogen)	N	06/16/08	.02	No Range	ppm	1	1	Runoff from fertilizer use, leaching from septic tanks, sewage; erosion from natural deposits.

*\*Most recent sample, no sample required for 2008*

<u>Contaminants</u>	<u>MCLG</u>	<u>MCL,</u>	<u>Your</u>	<u>Range</u>		<u>Sample</u>	<u>Violation</u>	<u>Typical Source</u>
	<u>Or</u>	<u>TT, or</u>		<u>Low</u>	<u>High</u>			
	<u>MRDLG</u>	<u>MRDL</u>	<u>Water</u>			<u>Date</u>		
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl2) (ppm)	4	4	1.01	0.20	1.40	2008	No	Water additive used to control Microbes.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however they are not above the level considered unsafe.

### **Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sanders Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

#### **\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public water supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders. Some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by crypto sporidium and other microbiological contaminants are available from the Safe Drinking Water Hot Line (800.426.4791).

We do our best to provide quality water at every tap. Should you notice a drop in pressure or observe a leak on the system, please call James M. Coffey, 534-3261 or Cary Cormick, 234-6859. We ask that all our customers help us protect our water sources.

A valuable part of our community is our water source and will be valuable for future generations.

RETURN THIS STUB WITH PAYMENT TO:

SANDERS WATER ASSOCIATION  
 P.O. BOX 8  
 ETNA, MS 38627

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE PAID

CREDIT BALANCE \* DO NOT PAY

ACCOUNT NUMBER	DUE DATE	AMOUNT DUE AFTER DUE DATE	AMOUNT DUE BY DUE DATE
6550	08/10/09	-68.00	-68.00

A REVISED COPY OF THE 2008 CONSUMER CONFIDENCE REPORT THAT INCLUDES CHLORINE RESIDUALS IS AVAILABLE ON REQUEST.

RETURN SERVICE REQUESTED

~~PH: 534-3261~~  
 1789 HWY 355  
 ETNA, MS 38627

ACCOUNT NUMBER	DATE BILL MAILED
6550	08/01/09
PRESENT READING	SERVICE FROM
1600	06/25/09
PREVIOUS READING	SERVICE TO
1300	07/25/09
UNITS USED	DAYS USED
300	30
DESCRIPTION	AMOUNT

WATER 17.00  
 CREDIT -85.00

CURRENT BILL DUE DATE	AMOUNT DUE BY DUE DATE
08/10/09	-68.00
AMOUNT DUE AFTER DUE DATE	AMOUNT DUE AFTER DUE DATE
	-68.00

SERVICE ADDRESS: PH: 534-3261

KEEP THIS STUB FOR YOUR RECORDS

# 2008 CCR Contact Information

Date: 7/9/09 Time: 8:14

PWSID: 3600064

System Name: Sanders

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) \_\_\_\_\_

Will correct report & mail copy marked "**corrected copy**" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

WILL DO CORRECTED COPY AND NOTIFY CUSTOMERS OF AVAILABLE CORRECTED REPORT ON WATER BILL OR LETTER AND SEND US A COPY.

Mr. Coffey requested example on how to put the Chlorine on the CCR. I mailed him a Drinking Water Quality Report.

Spoke with James Coffey (Operator, Owner, Secretary) 662 534-3261