

APPROVED

RECEIVED

JUN 26 2009

BY _____

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

City of Humberton
Public Water Supply Name

0370005
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper
- On water bills
- Other _____

Date customers were informed: 5/28/09

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Lamar Times

Date Published: / /

CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

[Signature]
Name/Title (President, Mayor, Owner, etc.)

6-10-09
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

Hattiesburg Publishing Inc.

126 Westover Dr. ~ Hattiesburg, MS 39402 ~
(601) 268-2331 (601) 268-2965 fax

PROOF OF PUBLICATION

THE STATE OF MISSISSIPPI,
LAMAR COUNTY,

Personally appeared before me, the under-
signed, a notary public in and for Lamar
County, Mississippi, Tre Bischof,
for THE LAMAR TIMES, weekly newspaper
published in Lamar County, Mississippi who,
being duly sworn, says that the notice, a true
copy of which is hereto annexed, appeared in
the issues of said newspapers as follows:

DATE: 05-28-09

DATE: _____

DATE: _____

DATE: _____

DATE: _____

DISPLAY AD

Ad Size 4x16

Published 1 Times

TOTAL PRINTERS FEE \$ 704.00

(Signed) *Tre Bischof*
THE LAMAR TIMES

Sworn to and subscribed before me in my
Presence, this 28 day of May
2009, a Notary Public in and for the County
of Lamar, State of Mississippi.

(signed) Sonya James
Notary Public



ANNUAL DRINKING WATER QUALITY REPORT

City of Lumberton

PWS ID: 370005

June 10, 2009

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source consists of three wells. **Our wells draw from the Miocene Aquifer.**

A copy of this CCR Report will not be mailed to our customers.

Our source water assessment has been completed. Our wells were ranked **Moderate to High** in terms of susceptibility to contamination. For a copy of the report, please contact our office at 601-796-8341.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Lumberton is responsible for providing high quality drinking water, but cannot control the variety of materials and components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hot line or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage I Disinfection By-Products Rule. Our water system failed to complete these monitoring requirements in March of 2006. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007- December 2007. your public water supply completed sampling by the schedule deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

I'm please to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact **Danny Davis, at 601-796-8341**. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the **first and third Tuesday of every month at 6:00 pm**. The meeting will be conducted at City Hall, 102 East Main Avenue.

The City of Lumberton routinely monitors for constituents in your drinking water according to Federal and State Laws. This table shows the results of our monitoring for the period of January 1st to December 31, 2007. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions at the bottom of the page.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards.

Contaminant	MCLG	MCL	YOUR WATER	SAMPLE DATE	VIOLATION	Likely Source of Contamination
Microbiological Contaminants						
1.Total Coliform Bacteria	0	<1	0 pos	2008	no	presence of Coliform bacteria in 5% of monthly samples Naturally present in the environment.
2. Fecal Coliform and Ecolab	0	5	0 pos	2008	no	A routine sample and repeat sample are total Coliform positive, and one is also fecal Coliform or E. coli positive Human and animal fecal waste
Radioactive Contaminant						
3. Gross Alpha(pCi/l)	0	15	ND	1/25/99	no	Decay of Natural and man-made deposits
4. Beta(pCi/l) calculated from Gross Alpha	0	50	ND	1/25/99	no	Erosion of natural ppm deposits
Inorganic Contaminants						
5. Antimony(ppm)	0.006	0.006	<0.0005	3/1/2006	no	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
6. Arsenic(ppm)	0.05	0.05	<0.0005	3/1/2006	no	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
7. Barium(ppm)	2.0	2.0	0.003038	3/1/2006	no	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
8. Beryllium(ppm)	0.004	0.004	<0.0001	3/1/2006	no	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
9. Cadmium(ppm)	0.005	0.005	<0.0001	3/1/2006	no	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
10. Chromium(ppm)	0.1	0.1	<0.0005	3/1/2006	no	Discharge from steel and pulp mills; erosion of natural deposits
11. cyanide (ppm)	0.2	0.2	<0.005	3/1/2006	no	Discharge from plastic and fertilizer factories; Discharge from steel and metal factories.
12. Fluoride(ppm)	4	4	0.160838	3/1/2006	no	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
13. Mercury ppm	0.002	0.002	<0.0002	3/1/2006	no	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
14. Nickel(ppm)	0.1	0.1	ND	09/19/2000	no	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
15. Selenium(ppm)	0.05	0.05	<0.0005	3/1/2006	no	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
16. Sulfate(ppb)	250	250	6.480	9/19/2000	no	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
17. Thallium(ppm)	0.002	0.002	<0.0005	3/1/2006	no	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
18. Nitrate (as Nitrogen)(ppm)	10.0	10.0	<0.08	1/5/2008	no	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
19. Nitrite (as Nitrogen)(ppm)	1.0	1.0	<0.02	1/5/2008	no	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
20. Lead(ppm)	0	AL=1.5	0.003	1/01/2005	no	Corrosion of household plumbing systems, erosion of natural deposits
21. Copper(ppm)	1.3	AL=1.3	0.1	1/01/2005	no	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
TTHM RAA(mg/l)	0.080	0.080	0.022	8/13/2007	no	By-product of drinking water chlorination
HAA5 RAA(MG/L)	0.060	0.060	0.006	8/13/2007	no	By-product of drinking water disinfection

TERMS AND DEFINITIONS

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ND: No Detect: No contaminant is detected. **RAA:** Running Annual Average Report for Trihalomethanes and Halo acetic Acids (TTHM/HAA)

MCL: maximum contaminant level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible

370005

CITY OF LUMBERTON
P. O. Box 211
Lumberton, MS 39455
OFFICE 601-796-8341
FAX 601-796-2323

Larry L. Strahan
Mayor

Aldermen:
Miriam Holder
E. Nell Busby
Stanley Rayborn
Quincy Rogers
Terry Cannaday

June 30, 2009

To Whom It May Concen:

Enclosed you will find the corrected CCR Report for the City of Lumberton. If you have any questions, please call me at 601-543-2679.

Sincerely,
Danny Davis
Public Works Director

RECEIVED-WATER SUPPLY
2009 JUL -7 PM 1:42

2009 JUL -7 PM 1:42

ANNUAL DRINKING WATER QUALITY REPORT**City of Lumberton****PWS ID: 370005****June 10, 2009**

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source consists of three wells. **Our wells draw from the Miocene Aquifer.**

A copy of this CCR Report will not be mailed to our customers.

Our source water assessment has been completed. Our wells were ranked **Moderate to High** in terms of susceptibility to contamination. For a copy of the report, please contact our office at 601-796-8341.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Lumberton is responsible for providing high quality drinking water, but cannot control the variety of materials and components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hot line or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage I Disinfection By-Products Rule. Our water system failed to complete these monitoring requirements in March of 2006. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

*******A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007- December 2007. your public water supply completed sampling by the schedule deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

I'm please to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact **Danny Davis, at 601-796-8341**. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the **first and third Tuesday of every month at 6:00 pm**. The meeting will be conducted at City Hall, 102 East Main Avenue.

The City of Lumberton routinely monitors for constituents in your drinking water according to Federal and State Laws. This table shows the results of our monitoring for the period of January 1st to December 31, 2007. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions at the bottom of the page.

TEST RESULTS for CITY of LUMBERTON PWS ID 37005

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards.

Contaminant	MCLG	MCL	YOUR WATER	SAMPLE DATE	VIOLATION	Likely Source of Contamination
Microbiological Contaminants						
1.Total Coliform Bacteria	0	<1	0 pos	2008	no	presence of Coliform bacteria in 5% of monthly samples Naturally present in the environment.
2. Fecal Coliform and Ecolab	0	5	0 pos	2008	no	A routine sample and repeat sample are total Coliform positive, and one is also fecal Coliform or E. coli positive Human and animal fecal waste
Radioactive Contaminant						
3. Gross Alpha(pCi/l)	0	15	ND	1/25/99	no	Decay of Natural and man-made deposits
4. Beta(pCi/l) calculated from Gross Alpha	0	50	ND	1/25/99	no	Erosion of natural ppm deposits
Inorganic Contaminants						
5. Antimony(ppm)	0.006	0.006	<0.0005	3/1/2006	no	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
6. Arsenic(ppm)	0.05	0.05	<0.0005	3/1/2006	no	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
7. Barium(ppm)	2.0	2.0	0.003038	3/1/2006	no	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
8. Beryllium(ppm)	0.004	0.004	<0.0001	3/1/2006	no	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
9. Cadmium(ppm)	0.005	0.005	<0.0001	3/1/2006	no	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
10. Chromium(ppm)	0.1	0.1	<0.0005	3/1/2006	no	Discharge from steel and pulp mills; erosion of natural deposits
11. cyanide (ppm)	0.2	0.2	<0.005	3/1/2006	no	Discharge from plastic and fertilizer factories; Discharge from steel and metal factories.
12. Fluoride(ppm)	4	4	0.160838	3/1/2006	no	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
13. Mercury ppm	0.002	0.002	<0.0002	3/1/2006	no	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
14. Nickel(ppm)	0.1	0.1	ND	09/19/2000	no	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
15. Selenium(ppm)	0.05	0.05	<0.0005	3/1/2006	no	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
16. Sulfate(ppb)	250	250	6.480	9/19/2000	no	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
17. Thallium(ppm)	0.002	0.002	<0.0005	3/1/2006	no	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
18. Nitrate (as Nitrogen)(ppm)	10.0	10.0	<0.08	1/5/2008	no	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
19. Nitrite (as Nitrogen)(ppm)	1.0	1.0	<0.02	1/5/2008	no	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
20. Lead(ppm)	0	Al=1.5	0.003	1/01/2005	no	Corrosion of household plumbing systems, erosion of natural deposits
21. Copper(ppm)	1.3	Al=1.3	0.1	1/01/2005	no	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservative
TTHM RAA(mg/l)	0.080	0.080	0.022	8/13/2007	no	By-product of drinking water chlorination
HAA5 RAA(MG/L)	0.060	0.060	0.006	8/13/2007	no	By-product of drinking water disinfection

TERMS AND DEFINITIONS

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety

Chlorine Residual RAA (mg/l)	.87		12/31/08	no
maximum cl2 Residual	1.20	mcl 4.0	12/31/08	
minimum cl2 Residual	.75		12/31/08	

2008 CCR Contact Information

Date: 6/29/09 Time: 1:20

PWSID: 370005

System Name: Lumberton

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) _____

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Mr. Davis will do corrected copy and notify
customers of available corrected report on the water
bill and send us a copy.

Spoke with Daniel Davis 601 543-2679
(Operator, Owner, Secretary)

RECEIVED - WATER SUPPLY

2009 AUG -5 AM 8:47

CITY OF LUMBERTON

P. O. Box 211

Lumberton, MS 39455

OFFICE 601-796-8341

FAX 601-796-2323

Miriam Holder
Mayor

Stephanie C. Mullings
City Clerk

370005


Aldermen:
Bobby Gibson
Kent Crider
Rebecca Hale
Quincy Rogers
Timothy Johnson

August 4, 2009

Dear Christi:

Attached hereto please find a copy of our most recent water bill issued to all our current customers.

Please note that we included the proper wording regarding the CCR report.

Sincerely,

DANNY DAVIS

ACCOUNT NO.	SERVICE FROM	SERVICE TO
60-01677	06/20	07/24
SERVICE ADDRESS		
13 INDUSTRIAL PARKWAY		
METER READINGS		
CURRENT	PREVIOUS	USED
75	90	2
CHARGE FOR SERVICES		

CITY OF LUMBERTON WATER DEPARTMENT P.O. BOX 211 • LUMBERTON, MS 39455			PRESORTED FIRST-CLASS MAIL U.S. POSTAGE PAID PERMIT NO. 19 LUMBERTON, MS
PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE	
	08/10/2003		
NET AMOUNT	SAVE THIS	GROSS AMOUNT	
37.45	10.70	48.15	

WTR	10.75
SDP	5.00
ETP	17.00
DP	1.15
TAX	.75
NET DUE	37.45
SAVE THIS	10.70
GROSS DUE	48.15

CORRECTED COB AVAILABLE BY
CALLING 601-796-8241.

RETURN SERVICE REQUESTED
PO Box
466
 01-016877
 CARRELL, RICK
 13 INDUSTRIAL PARKWAY
 LUMBERTON, MS 39455

LTP

