

APPROVED

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

P.A.C. UTILITY CO, INC.
Public Water Supply Name

0300160
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

X Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper
On water bills
X Other Letter mailed with water bill

Date customers were informed: 6/16/09

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper:

Date Published: / /

CCR was posted in public places. (Attach list of locations)

Date Posted: / /

CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Kelly Singleton
Name/Title (President, Mayor, Owner, etc.)

6-16-09
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

Annual Drinking Water Quality Report 2008

P.A.C. Utility Co., Inc. PWS 0300160

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is *the Graham Ferry Aquifer. Our source water assessment has not been completed at this time.* I'm pleased to report that our drinking water meets all federal and state requirements. This table shows the results of our monitoring for the period of 01/01/08-12/31/08.

If you have any questions concerning your water utility, please contact **Melvin McVey at 228-990-1277.** **Please feel free to attend our annual meeting July 18 at 8:00 AM at the Utility office.**

We routinely monitor for constituents in your drinking water according to Federal and State laws. The date of last testing is shown for those contaminants not requiring annual testing. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances.

Definitions used in this Table:

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Running Annual Average (RAA)- Average of multiple samples taken throughout the year.

Some people who drink water containing trihalomethanes in excess of the MCL over many years experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. PAC Utilities is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

A Message From MSDH Concerning Radiological Sampling

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December, 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Mellissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Contaminant	Violation Y/N	Date Collected	Level Detected	# Samples exceed MCL/ACL	Unit Measure	MCGL	MCL	Likely source
Haloacetic Acids (HAA5)	N	05/01/08 RAA	0.055	0	Mg/L	NA	.060	By-product of drinking water chlorination
Trihalomethanes (TTHM)	N	05/01/08 RAA	0.077	0	Mg/L	NA	0.080	By-product of drinking water chlorination
Disinfectant Byproduct	N	12/01/08 RAA	2.02	0	Mg/L	NA	4.0	Chlorine residual

Inorganic Contaminants

7. Antimony	N	2/13/06	0.05	0	Ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
8. Arsenic	N	2/13/06	0.05	0	Ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2/13/06	.004679	0	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
11. Beryllium	N	2/13/06	0.1	0	Ppb	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
12. Cadmium	N	2/13/06	0.1	0	Ppb	5	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
13. Chromium	N	2/13/06	0.5	0	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	10/14/08	0.2051	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N	2/13/06	0.5	0	Ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
16. Fluoride	N	2/13/06	.661592	0	Ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	10/14/08	0.0006	0	ppm	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
18. Mercury (inorganic)	N	2/13/06	0.2	0	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
19. Nitrate (as Nitrogen)	N	06/09/08	0.08	0	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
20. Nitrite (as Nitrogen)	N	06/09/08	0.02	0	ppm	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	2/13/06	0.5	0	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
22. Thallium	N	2/13/06	0.5	0	ppb	0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

Annual Drinking Water Quality Report 2008

P.A.C. Utility Co., Inc. PWS 0300160

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is *the Graham Ferry Aquifer. Our source water assessment has not been completed at this time.* I'm pleased to report that our drinking water meets all federal and state requirements. This table shows the results of our monitoring for the period of 01/01/08-12/31/08.

If you have any questions concerning your water utility, please contact Melvin McVey at 228-990-1277. Please feel free to attend our annual meeting July 18 at 8:00 AM at the Utility office.

We routinely monitor for constituents in your drinking water according to Federal and State laws. The date of last testing is shown for those contaminants not requiring annual testing. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances.

Definitions used in this Table:

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Running Annual Average (RAA)- Average of multiple samples taken throughout the year.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

*

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. PAC Utilities is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

A Message From MSDH Concerning Radiological Sampling

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December, 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Mellissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Contaminant	Violation Y/N	Date Collected	Level Detected Your water	Range of detects/or #samples exceeding MCL/ACL	Unit Measure	MCGL	MCL	Likely source
Haloacetic Acids (HAA5)	N	7/08 RAA	0.054	0	Mg/L	NA	.060	By-product of drinking water chlorination
Trihalomethanes *(TTHM)	N	7/08 RAA	0.081	1	Mg/L	NA	0.080	By-product of drinking water chlorination
Chlorine (as Cl2)(ppm)	N	2008 RAA	2.02	.8-2.5	Ppm	NA	4.0	Water additive used to control microbes

Inorganic Contaminants								
7. Antimony	N	2/13/06	0.05	0	Ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
8. Arsenic	N	2/13/06	0.05	0	Ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2/13/06	.004679	0	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
11. Beryllium	N	2/13/06	0.1	0	Ppb	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
12. Cadmium	N	2/13/06	0.1	0	Ppb	5	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
13. Chromium	N	2/13/06	0.5	0	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	10/14/08	0.2051	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N	2/13/06	0.5	0	Ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
16. Fluoride	N	2/13/06	.661592	0	Ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	10/14/08	0.0006	0	ppm	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
18. Mercury (inorganic)	N	2/13/06	0.2	0	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
19. Nitrate (as Nitrogen)	N	06/09/08	0.08	0	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
20. Nitrite (as Nitrogen)	N	06/09/08	0.02	0	ppm	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	2/13/06	0.5	0	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
22. Thallium	N	2/13/06	0.5	0	ppb	0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

2008 CCR Contact Information

Date: 6/18/09 Time: 11:17

PWSID: 300160

System Name: PAC

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) TTHM (MCL) vio 7/08 *Not listed is Data Table*

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Mr. McVey will have corrected copy done and
notify customers of available corrected report
by July 1, 2009.

Beverly Tainter With Workman Does his CCR.
228-255-0772

*Need Health Effects
Language under
Data Table*

Spoke with Melvin McVey
(Operator, Owner, Secretary)

228 990-1277
Fax # 228 875-4356

June 22, 2009

Bureau of Public Water Supply

P. O. Box 1700

Jackson, MS 39215

RE: Consumer Confidence Reports for 2008

Enclosed you will find corrected copies of twenty-one CCR showing the required terminology for disinfection by-products (chlorine residual) as well as any other discrepancies I have been notified of by your office. Corrected copies have been sent to all water systems, including documentation and instructions to notify their customers of the changes.

The Consumer Confidence Report Certification Forms were submitted to your office by the water systems along with the original reports. I have not included copies of these forms as I no longer have access to them.

Sincerely yours,

A handwritten signature in cursive script that reads "Beverly Painter".

Beverly Painter, Operator D03273

228.255.0772

APPROVED

Annual Drinking Water Quality Report 2008

P.A.C. Utility Co., Inc. PWS 0300160

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is *the Graham Ferry Aquifer. Our source water assessment has not been completed at this time.* I'm pleased to report that our drinking water meets all federal and state requirements. This table shows the results of our monitoring for the period of 01/01/08-12/31/08.

If you have any questions concerning your water utility, please contact Melvin McVey at 228-990-1277. Please feel free to attend our annual meeting July 18 at 8:00 AM at the Utility office.

We routinely monitor for constituents in your drinking water according to Federal and State laws. The date of last testing is shown for those contaminants not requiring annual testing. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances.

Definitions used in this Table:

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Running Annual Average (RAA)- Average of multiple samples taken throughout the year.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

*

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. PAC Utilities is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

A Message From MSDH Concerning Radiological Sampling

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December, 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Mellissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Contaminant	Violation = Y/N	Date Collected	Level Detected Your water	Range of detects/or #samples exceeding MCL/ACL	Unit Measure	MCGL	MCL	Likely source
Haloacetic Acids (HAA5)	N	7/08 RAA	0.054	0	Mg/L	NA	.060	By-product of drinking water chlorination
Trihalomethanes (THM)	N	7/08 RAA	0.081	1	Mg/L	NA	0.080	By-product of drinking water chlorination
Chlorine (as Cl ₂)(ppm)	N	2008 RAA	2.02	8-2.5	Ppm	NA	4.0	Water additive used to control microbes
Inorganic Contaminants								
7. Antimony	N	2/13/06	0.05	0	Ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
8. Arsenic	N	2/13/06	0.05	0	Ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2/13/06	.004679	0	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
11. Beryllium	N	2/13/06	0.1	0	Ppb	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
12. Cadmium	N	2/13/06	0.1	0	Ppb	5	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
13. Chromium	N	2/13/06	0.5	0	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	10/14/08	0.2051	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N	2/13/06	0.5	0	Ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
16. Fluoride	N	2/13/06	.661592	0	Ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	10/14/08	0.0006	0	ppm	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
18. Mercury (inorganic)	N	2/13/06	0.2	0	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
19. Nitrate (as Nitrogen)	N	06/09/08	0.08	0	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
20. Nitrite (as Nitrogen)	N	06/09/08	0.02	0	ppm	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	2/13/06	0.5	0	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
22. Thallium	N	2/13/06	0.5	0	ppb	0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

The Waterman
10624 Allen Dr.
Pass Christian, MS 39571
Phone & Fax: 228-255-0772
Cell: 228 860-5454

facsimile transmittal

*Revised
Version*

To: PAC Utilities Fax: 228-818-5308
From: L. Painter Date: 6-19
Re: CCR Pages: 4
CC:

- Urgent For Review Please Comment Please Reply Please Recycle

*Hopefully this is the final version of
the report. This copy is for your
records.*

2008 CCR Contact Information

Date: 6/18/09 Time: 11:17

PWSID: 300160

System Name: PAC

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) TTM (MCL) via 7/08

Not listed is
Data Table
Need Health Effects
Language under
Data Table

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Mr. Macey will have corrected copy done and
mail customers of available corrected report
by July 1, 2009.

Beverly Tainter With Wilbur Das his CCR
228-255-0772

Spoke with Melvin Macey 228 990-1277
(Operator, Owner, Secretary)
Fax # 228 875-4356

Spoke with Kelly Singleton 4:58 pm
6/25/09 will Fax over corrected copy
and notify customers of available corrected
Report. 228-219-5300

PAC Utility Co., Inc.
3000 Hamill Farm Road
Ocean Springs, Mississippi 39564-8739
228-818-5300 Fax: 818-5308

June 26, 2009

Mrs. Jessie Byrd
Bureau of Public Water Supply
P O Box 1700
Jackson, MS 39215

SENT VIA FAX

(6 pages)

RE: Revised Consumer Confidence Report
PAC Utility Co., Inc. ID 0300160


Dear Mrs. Byrd:

I have enclosed the revised Consumer Confidence Report.

I have also enclosed a copy of our invoice to customers with a note in bold at the bottom of the invoice to explain the correction to the data table that was included in the CCR that was included with the customers bills that were mailed on June 16, 2009. We will be including this note on the July invoices to customers. The original report did include the medical statement regarding TTHMs.

Please respond with an indication of whether you approve the revised report and our note to customers regarding the data table correction.

Sincerely,



Kelly W. Singleton,
President

P. A. C. Utility Co., Inc.
 3000 Hamill Farm Road
 Ocean Springs, MS 39564-8739

Invoice

DATE	INVOICE #
6/25/2009	15586
DUE DATE	
7/11/2009	

ACCOUNT NUMBER
7912 Sarah - ChapmanT06/23/09

Dean Chapman
 2062 Jordan Road
 Glennville, GA 30427

****CUT HERE-RETURN UPPER PART WITH CHECK****

ITEM	DESCRIPTION	QTY	AMOUNT
6 Water	Water usage for 06/16/09 - 06/23/09	2,780	13.90

Invoice Total \$13.90

\$3.00 Late Charge Added If Not Received By Due Date

NOTICE: SERVICES ARE SUBJECT TO BEING DISCONNECTED WITHOUT NOTICE IF PAYMENT IS NOT RECEIVED BY THE DUE DATE.

For SERVICE PROBLEMS CALL Melvin McVey at (228) 990-1277 or (228) 875-4356. For information about your account call (228) 818-5300. P.A.C. Utility Co., Inc.

IF YOU RECEIVED A STATEMENT WITH THIS INVOICE, THEN THIS INVOICE TOTAL SHOULD BE INCLUDED IN THE TOTAL DUE AMOUNT ON THE STATEMENT.

NOTICE TO CUSTOMERS:

The second line of the Data Table included in the Annual Drinking Water Quality Report - 2008 which was included in your June bill is corrected to read as follows:

Contaminant	Violation Y/N	Date Collected	Level Detected in Your Water	Number of samples exceeding MCL/ACL	Unit of Measure	MCGL	MCL	Likely Source
Trihalomethanes (TTHM)	Y	07/08 RAA	0.081	1	Mg/L	NA	0.080	By-product of drinking water chlorination