

APPROVED

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Burleson Mobile Home Park

Public Water Supply Name

410038

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper
On water bills
Other Hand Delivered to tenants

Date customers were informed: 7/20/09

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper:

Date Published: / /

CCR was posted in public places. (Attach list of locations)

Date Posted: / /

CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Signature of official

Name/Title (President, Mayor, Owner, etc.)

Signature and Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215 Phone: 601-576-7518

17077

Rec'd
7/13/09

Burleson Mobile Home Park
Annual Drinking Water Quality Report
PWS ID# 0410038
 July 13, 2009

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is one well. Our well draws from the Eutaw Formation.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Baldwyn and Ingram water systems have received a **moderate susceptibility** ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Mitch Burleson at 662-610-9130. We want our valued customers to be informed about their water utility.

Burleson Mobile Home Park routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level – AL: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique - TT: A required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level – MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal – MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level – MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

| Burleson MHP PWS ID # 0410038 TEST RESULTS | | | | | | | | |
|--|------------------|-------------------|-------------------|--|---------------------|------|-----|--------------------------------|
| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination |

| Inorganic Contaminants | | | | | | | | |
|--|---|------|------|-----------|-----|-----|--------|--|
| Copper | N | 2008 | .006 | .055-0.06 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| Disinfectants & Disinfection By-Products (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.) | | | | | | | | |
| Chlorine (as Cl ₂) (ppm) | N | 2008 | .55 | .50-.60 | ppm | 4 | 4 | Water additive used to control microbes |

We are required to monitor your drinking water for specific constituents on a monthly basis. Beginning January 1, 2004, the Ms. Dept. of Health required public water systems that use chlorine as a primary disinfectant to monitor for chlorine residuals as required by the Stage 1 Disinfection By Products Rule. Our system failed to monitor and record on our bacteriological sample cards the residual in the months of Jan.-04 thru, June-04, Sept.04 thru April05, June-05 thru Sept.-06, and in 1-08. We did not complete the monitoring requirements for bacteriological sampling that showed no coliform present.

Total Coliform monitoring violations

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In January 2008, the Mississippi State Department of Health (MSDH) required public water systems to monitor/test for bacteriological samples as required by the Total Coliform Rule. Our water system failed to complete these monitoring requirements: therefore, we cannot be sure of your water quality during this particular time.

Nitrate monitoring violations

We are required to monitor your drinking water for specific constituents. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January – December 2008, the Mississippi State Department of Health (MSDH) required public water systems to monitor/test for Nitrate/Nitrite samples as required by the Phase II Chemical Rule. Our water system failed to complete these monitoring requirements: therefore, we cannot be sure of your water quality during this particular time.

*** A message from MSDH concerning radiological sampling ***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007- December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Ms. State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact **Melissa Parker**, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Burleson Mobile Home Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including

bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Your CCR will not be mailed to you however; you may obtain a copy by calling (662) 610-9130 if you have questions.

TRANSMISSION VERIFICATION REPORT

TIME : 08/25/2009 20:31
NAME :
FAX :
TEL :
SER. # : 000H7J524733

| | |
|--------------|----------------------|
| DATE, TIME | 08/25 20:28 |
| FAX NO./NAME | 90166284109646870149 |
| DURATION | 00:02:49 |
| PAGE(S) | 05 |
| RESULT | OK |
| MODE | STANDARD ECM |

Fax Cover Sheet

Mississippi State Department of Health
 Bureau of Public Water Supply
 570 East Woodrow Wilson, P. O. Box 1700
 Jackson, Mississippi 39215-1700
 Voice: 601-576-7518
 Fax: 601-576-7822

| | |
|---------------|----------------|
| Company Name: | Burleson MHP |
| Contact Name: | Mitch Burleson |
| Fax Number: | 662-841-0964 |

| | |
|--------------|--------------|
| Sender: | |
| Description: | |
| | ATTN: |
| | Jean Coakley |
| | |
| | |
| | |
| | |
| | |
| | |

Number of pages (including cover): 5

Date Sent: 8/26/09

If there are any problems with this transmission, please call: Jean Coakley
 at 601-576-7518 immediately.

Cockrell, Joan

From: Parker, Melissa
Sent: Friday, July 31, 2009 2:31 PM
To: 'Tom Abernathy'
Cc: Cockrell, Joan
Subject: FW: Burleson MHP

It looks fine to me. Joan, take a look and make sure all is included that you need and shoot him an email.

Thanks,
Melissa

-----Original Message-----

From: Tom Abernathy [mailto:tomabernathy92@yahoo.com]
Sent: Friday, July 31, 2009 11:46 AM
To: Parker, Melissa
Subject: Burleson MHP

See what you think, Thanks, Tom