

BUREAU OF PUBLIC WATER SUPPLY

RECEIVED-WATER SUPPLY

2009 JUN 29 AM 10:19

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION REPORT

CITY OF SCHLATER
PWS ID # 0420005

APPROVED

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: (*Attach copy of publication, water bill, or other*)

- Advertisement in local paper
- On water bills
- Other

Date customers were informed: 6/29/09

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date mailed/distributed:

CCR was published in local newspaper. (*Attach copy of published CCR and proof of publication*)

Name of Newspaper:
Date Published:

CCR was posted in public places. (*Attach list of locations*) POST OFFICE/CITY HALL

Date posted: 6/29/09

CCR was posted on a publicly accessible internet site at the address: www:

CERTIFICATION:

I hereby certify that a Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Jason Colquhoun
Name/Title (President, Mayor, Owner, etc.)

Date 6-29-09

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Signature

Date

**Mail completed form to: Bureau of Public Water Supply ~ P O Box 1700 ~ Jackson, MS 39215
Phone: 601-576-7518**

RECEIVED - WATER SUPPLY
Annual Drinking Water Quality Report
City of Schlater 2009 JUN 29 AM 10:19
PWS ID # 0420005
June, 2009

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well that draws from the Meridian-Upper Wilcox Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. A report containing detailed information has been received by our office and will be made available for review upon request. The water supply for the City of Schlater received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Bobby Brown at 662-721-7534. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at Town Hall at 7:30 pm.

The City of Schlater routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

*******A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Schlater is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

Monitoring and reporting of compliance data violations:

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system failed to complete these monitoring requirements in December, 2008. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period..

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2006*	0.01	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2006*	1	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N		0.5	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2006*	0.9	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N		2	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Volatile Organic Contaminants								
73. TTHM [Total tri-halomethanes]	N	2007*	33	None	ppb	0	80	By-product of drinking water chlorination
HAA5	N	2007*	11	None	ppb	0	60	By-product of drinking water chlorination
Disinfectants & Disinfection By-Products								
Chlorine (as Cl2)	N	Jan-Dec 2008	1.01 to 1.12	None	ppm	4	4	Water additive used to control microbes

* Most recent sample results available

We constantly monitor for various constituents in the water supply to meet all regulatory requirements. This past year we failed to collect a sample during one sampling period.. This does not pose a threat to the quality of our water supply.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

042005
0420022

Town of Schlater
P.O. BOX 203
Schlater, MS 38952

FIRST-CLASS MAIL
U.S. POSTAGE
PAID

PERMIT NO.

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
sample				

CUSTOMER		PAY GROSS AMOUNT AFTER THIS DATE
ROUTE	ACCOUNT	
###	####	Due Date Here
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID
123.45		125.45

RECEIVED-WATER SUPPLY
2009 JUL -2 AM 8:23

MAIL THIS STUB WITH YOUR PAYMENT

F9 Sample

Sample

RVS SOFTWARE TO REORDER CALL 1-866-787-2455

METER READ			TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
MONTH	DAY	CLASS			
##	##	1	123.45	2.00	125.45

CCR AVAILABLE CALL 721-7534

Town of Schlater
P.O. BOX 203
Schlater, MS 38952

FIRST-CLASS MAIL
U.S. POSTAGE
PAID

PERMIT NO.

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
sample				

CUSTOMER		PAY GROSS AMOUNT AFTER THIS DATE
ROUTE	ACCOUNT	
###	####	Due Date Here
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID
123.45		125.45

MAIL THIS STUB WITH YOUR PAYMENT

F9 Sample

Sample

RVS SOFTWARE TO REORDER CALL 1-866-787-2455

METER READ			TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
MONTH	DAY	CLASS			
##	##	1	123.45	2.00	125.45

CCR AVAILABLE CALL 721-7534

Town of Schlater
 P.O. BOX 203
 Schlater, MS 38952

FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID

PERMIT NO.

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
sample				

CUSTOMER ROUTE ###	CUSTOMER ACCOUNT ####	Due Date Here
NET AMOUNT TO BE PAID 123.45		

MAIL THIS STUB WITH YOUR PAYMENT

F9 Sample

Sample

RVS SOFTWARE TO REORDER CALL 1-866-767-2455

METER READ			CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
MONTH	DAY					
##	##			123.45	2.00	125.45

CCR AVAILABLE CALL 721-7534