

APPROVED

BUREAU OF PUBLIC WATER SUPPLY
CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

City of Ridgeland
Public Water Supply Name

450013
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
Advertisement in local paper
On water bills
Other

Date customers were informed: / /

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 6 / 22 / 09

- CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper:

Date Published: / /

- CCR was posted in public places. (Attach list of locations) Library & apartment complexes

Date Posted: 6 23 / 09

- CCR was posted on a publicly accessible internet site at the address: www.ridgelandms.org

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

[Signature]
Name/Title (President, Mayor, Owner, etc.)

6/23/09
Date

United States Postal Service Postage Statement — Standard Mail

Comments: USPS: Note Mail Arrival Date & Time (Do not Round-Stamp)

Permit Holder's Name and Address and Email Address, if Any; Telephone (601)-853-6133 Extension; Name and Address of Mailing Agent; Telephone (601)-853-6133 Extension; Name and Address of Individual or Organization for Which Mailing is Prepared; Dealing Addressing & Mailing Service; CAPS Cust Ref No.; Customer Number

Post Office of Mailing Jackson, MS 39201; Processing Category; Mailing Date 6/22/2009; Fed. Agency Cost Code; Statement Seq. No. CITY O; Type of Postage; Weight of a Single Piece 0.0250 pounds; Total Pieces 6,685; No. of Containers; Permit # 80; For Mail Enclosed Within Another Class; If Sacked, Based on; Total Weight 167.1250; For Automation Price Pieces, Enter Date of Address Matching and Coding; For ECR Price Pieces, Enter Date of Address Matching and Coding; For ECR Price Pieces, Enter Date of Carrier Route Sequencing; Move Update method

Parts Completed (Select all that apply) [X]A []B []C [X]D []E []F []G []H []I []J []K []L []S

Total Postage (Add Parts Totals) 1,295.33; Price at Which Postage Affixed (Check one) Complete if the mailing includes pieces bearing metered or precanceled stamps; Net Postage Due (Subtract postage affixed from total postage); Additional Postage Payment (State reason); Total Adjusted Postage Affixed; Total Adjusted Postage Permit Imprint

The mailer's signature certifies acceptance of liability for and agreement to pay any revenue deficiencies assessed on this mailing, subject to appeal. If an agent signs this form, the agent certifies that he or she is authorized to sign on behalf of the mailer, and that the mailer is bound by the certification and agrees to pay any deficiencies. In addition, agents may be liable for any deficiencies resulting from matters within their responsibility, knowledge, or control. The mailer hereby certifies that all information furnished on this form is accurate, truthful, and complete, that the mail and the supporting documentation comply with all postal standards and that the mailing qualifies for the prices and fees claimed; and that the mailing does not contain any matter prohibited by law or postal regulation. I understand that anyone who furnishes false or misleading information on this form or who omits information requested on this form may be subject to criminal and/or civil penalties, including fines and imprisonment. Privacy Notice: For information regarding our Privacy Policy visit www.usps.com.

Signature of Mailer or Agent: Valerie Hutas; Printed Name of Mailer or Agent Signing Form: Dealing Addressing; Telephone: 601-853-6133 Extension

Weight of a Single Piece; Total Pieces; Total Weight; Total Postage; Are postage figures at left adjusted from mailer's entries? [] Yes [] No; Round Stamp (Required) Date Mail Released; Presort Verification Performed? (Check One) [] Yes [] No; Date Mailed Notified; Contact; By (Initials); I CERTIFY that this mailing has been inspected concerning: (1) eligibility for postage rates claimed; (2) proper preparation (and presort where required); (3) proper completion of postage statement; (4) payment of annual fee (if required); and (5) sufficient funds on deposit (if required); USPS Employee's Signature; Print USPS Employee's Name; Time AM PM

2008 CCR Contact Information

Date: _____ Time: _____

PWSID: 450013

System Name: Ridgeland

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) _____

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Mark McManus
601 856-4646
601 756-3000

Spoke with _____
(Operator, Owner, Secretary)

Revised Annual Drinking Water Quality Report 2008

City of Ridgeland and Livingston Road Water Association PWS IDs MS0450013 and MS0450009

The following information was inadvertently excluded from the 2008 Consumer Confidence Report for the City of Ridgeland and Livingston Road Water Association. The water quality results table should have included information regarding the amount of chlorine measured as a chlorine residual in your drinking water. Additionally, the report should have included general information regarding lead exposure and testing of your drinking water for lead.

This table may include terms and abbreviations you might not be familiar with. To help better understand these terms we've provided the following definitions:

ppm – parts per million or milligrams per liter (mg/l)

MRDL – Maximum Residual Disinfectant Level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is **necessary** for control of microbial contaminants.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MRDL	Likely Source of Contamination
Disinfection By-Products								
Chlorine as CL₂								
City of Ridgeland	N	2008	1.31	1.31-1.44	ppm	4	4	Water additive used to Control microbes
Livingston Road Water	N	2008	1.39	1.39-1.51				

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The **City of Ridgeland and Livingston Road Water Association** are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

Revised Annual Drinking Water Quality Report 2008

City of Ridgeland and Livingston Road Water Association PWS IDs MS0450013 and MS0450009

The following information was inadvertently excluded from the 2008 Consumer Confidence Report for the City of Ridgeland and Livingston Road Water Association. The water quality results table should have included information regarding the amount of chlorine measured as a chlorine residual in your drinking water. Additionally, the report should have included general information regarding lead exposure and testing of your drinking water for lead.

This table may include terms and abbreviations you might not be familiar with. To help better understand these terms we've provided the following definitions:

ppm – parts per million or milligrams per liter (mg/l)

MRDL – Maximum Residual Disinfectant Level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant **is necessary** for control of microbial contaminants.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MRDL	Likely Source of Contamination
Disinfection By-Products								
Chlorine as Cl₂								
City of Ridgeland	N	2008	1.31	1.31-1.44	ppm	4	4	Water additive used to Control microbes
Livingston Road Water	N	2008	1.39	1.39-1.51				

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The **City of Ridgeland and Livingston Road Water Association** are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

PO BOX 217
RIDGELAND, MS 39158

Account Statement

ACCOUNT: 05-3005-00
SERVICE ADDRESS: 2077 LAKESHORE DR
LAST PAYMENT: 06/08/2009 -59.64
SERVICE PERIOD: 05/18/2009 TO: 06/17/2009
BILLING DATE: 07/01/2009

AUTOSCH 5-DIGIT 39157 & AUTOMATION 5-DIGIT
1336 L AV B-395 54523AA2--1

DAVID E. LOPEZ
2077 LAKESHORE DR
RIDGELAND MS 39157-1025

FOR INQUIRIES CALL
Billing - (601) 856-3938
Public Works - (601) 853-2027

PAYMENT OPTIONS
Automatic Monthly Bank Draft
Online at www.ridgelandms.org
Mail
In Person

ACCOUNT HISTORY

Your Water Use this Period: 8,000 Gallons
Water Usage Same Period Last Year: 14,000 Gallons
Average Water Usage: 9,077 Gallons

If you would like to receive city and community news via e-mail, sign up online at http://www.ridgelandms.org/online_services/enewsletter.html.

Celebrate America Balloon Glow is scheduled for 6 p.m., Friday, July 3 at Northpark Mall. Award-winning recording artist, Diamond Rio, will perform. This is a free community event.

Ridgeland earned the Scenic Communities of Mississippi award 2009 for excelling in management of natural resources.


Please contact the Public Works Department at 601-853-2027 for an updated consumer confidence report.

Meter	Previous	Current	Usage	Amount
H34437808	185	193	8,000	16.52

Description	Amount
SWR-RIDGE	11.88
SWR-JACKS	13.28
GARBAGE	10.41
RECYCLING	2.84

TOTAL CURRENT CHARGES 54.93

TOTAL DUE IF PAID AFTER 07/15/2009 60.42



Payment Coupon

ACCOUNT: 05-3005-00
SERVICE ADDRESS: 2077 LAKESHORE DR
SERVICE PERIOD: 05/18/2009 TO: 06/17/2009
BILLING DATE: 07/01/2009

TOTAL DUE IF PAID AFTER 07/15/2009 60.42

DAVID E. LOPEZ
2077 LAKESHORE DR
RIDGELAND MS. 39157-1025

CITY OF RIDGELAND
PO BOX 217
RIDGELAND MS 39158-0217



05300500000054930000060423

TRAC702750055 - DataFusion, Inc. - www.datafusion.com - 543234432-A-11136-1-1

City of Ridgeland

Post Office Box 217
39158
304 Highway 51
Ridgeland, Mississippi 39157
601.856.7113
www.ridgeland.ms.gov

City of Ridgeland
Public Works Department

304 Highway 51, 39157, Post Office Box 217, 39158
Ridgeland, MS
Ph. (601) 853-2027, Fax No. (601) 853-2019
Email: publicworks@ridgeland.ms.gov

Fax Cover Sheet

Date: 7/1/09
Attention: Joan
Company: MSDH
Fax Number Dialed: 601-576-7800
From: Renee Buckner
Total Pages: 3
(including cover sheet)

Gene F. McGee
Mayor

David W. Overby, CPA
Director of Finance &
Administration
City Clerk

Board of Aldermen

Ken Heard, Ward 1

Chuck Gautier, Ward 2

Kevin Holder, Ward 3

Larry Roberts, Ward 4

Scott Jones, Ward 5

Linda S. Davis, Ward 6

Gerald Steen, At-Large
Mayor Pro Tempore




MESSAGE:

PLEASE NOTIFY US IF THE MESSAGE IS INCOMPLETE
OR UNCLEAR.

THANK YOU.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. Remember that the presence of contaminants in small amounts does not necessarily indicate a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.



Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate ways to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

The City of Ridgeland asks all our customers to help us protect our water sources, which are the heart of our community, our way of life and our children's future. Citizens can report water leaks and contamination of the system by contacting the Public Works Department at 601-853-2027.

The City of Ridgeland is expanding its system to include a new tank and well west of U.S. Interstate 55, new distribution lines and improvements to existing facilities. These improvements will provide a reliable source of water for years to come.

If you would like additional information about your drinking water, you may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address:

<http://www.msdh.state.us/watersupply/index.htm>.

Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water," and "Flooding and Safe Drinking Water" may be obtained.

If you have any questions about this report or concerning your water supply utility, please contact Mark McManus - Water/Sewer System Superintendent at 601-853-2027. We want our customers to be informed about their water supply utility.


Presorted
Standard
U.S. Postage
PAID
Jackson, MS
Permit No. 80



CITY OF RIDGELAND
PUBLIC WORKS DEPARTMENT
P.O. BOX 217
RIDGELAND, MS 39158

PY5ID450013
DATE 2008

CITY OF RIDGELAND WATER QUALITY REPORT



CITY OF RIDGELAND

PWSID 450013 - Date 2008

Ridgeland's Public Works Department is pleased to present to you the 2008 Annual Water Quality Report to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide a safe and dependable supply of drinking water, and we work consistently to improve the water treatment process and protect our water resources. Ridgeland's water source is two deep-water supply wells in the Cockfield Aquifer and four deep-water supply wells in the Sparta Aquifer.

Last year, we conducted tests for over 80 contaminants. We found only one at a level higher than the EPA allows. We are committed to providing you with information because informed customers are our best allies. (For more information see the section labeled Violations at the end of the report.)

The City of Ridgeland routinely tests for contaminants in your drinking water, according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1 to December 31, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It is important to recognize that the presence of these elements does not necessarily pose a health risk.

A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline, however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

DEFINITIONS:

Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi State Department of Health requires the City to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, may be more than one year old. In the following table you will find several terms and abbreviations with which you may not be familiar. To help you better understand these terms, we've provided the following definitions:

NON-DETECTS (ND) - laboratory analysis indicates that the constituent is not present.

PARTS PER MILLION (ppm) OR MILLIGRAMS PER LITER (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

PARTS PER BILLION (ppb) OR MICROGRAMS PER LITER - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

ACTION LEVEL - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

TREATMENT TECHNIQUE (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

MAXIMUM CONTAMINANT LEVEL - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MAXIMUM CONTAMINANT LEVEL GOAL - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Defects or No. of Samples Exceeding MCL/AL	Unit Measurement	MCLG	MCL	Likely source of contamination:
MICROBIAL CONTAMINANTS:								
Total Coliform	N	2008	0.0	No Range	#	0	>1	Naturally present in the environment
HALOACETIC ACIDS:								
(HAA5)	Y	2008	.052	No Range	ppb	NA	60	By-product of drinking water disinfection
INORGANIC CONTAMINANTS:								
Nitrate	N	2008	0.08	0.08	ppm	10	10	Runoff from fertilizer;
Nitrite	N	2008	0.02	0.02	ppm	1	1	leaching from septic tanks, sewage; erosion
Nitrate Nitrite	N	2008	0.1	0.1	ppm	10	10	of natural deposits
VOLATILE ORGANIC CONTAMINANTS:								
THM (total trihalomethanes)	Y	2008	83	No Range	ppb	0	80	Chlorine By-Product
RADIOLOGICAL CONTAMINANTS:								
Radium 228	N	2008	1.15	.087-1.15	pCi/L	1.15	80	Naturally present in the environment

VIOLATIONS AND EXCEDANCES

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. The THM violation occurred during the 2008 testing cycle as required by the Mississippi State Department of Health. The City of Ridgeland is working with the Mississippi State Department of Health to reduce the amount of THM in its drinking water supply. We anticipate a minor adjustment in the amount of Chlorine injected into the water system for the purpose of bacterial disinfection as a short term solution.