

2009 JUN 22 AM 9:59

**Annual Drinking Water Quality Report**  
**Wake Forest Water Association**  
**PWS ID 530025**  
**June 30, 2009**

APPROVED

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater, and our two wells draw from the Gordo Formation.

If you have any questions about this report or concerning your water utility, please contact John Shaw at (662) 465-8788. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on .Board meetings are held on the first Monday of each month at 6:00 P.M. at the water Association office on Sturgis Reform Rd.

Wake Forest Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Our source water assessment has been completed. Our wells were ranked **Moderate to Low** in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662.465-6494.

To help you better understand these terms we've provided the following definitions. In this table you will find many terms and abbreviations you might not be familiar with.

Parts per million (ppm) or Milligrams per liter (mg/l) -one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

## Volatile Organic Contaminants

HAA5 Total	N	2007*	1.0	No Range	ppb	0	40	By- product of drinking water chlorination
---------------	---	-------	-----	----------	-----	---	----	---

\* Most recent sample None required in 2008

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

### **\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclids beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Please call our office if you have questions. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCL G	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	-------	-----	--------------------------------

**Inorganic Contaminants**

Cadmium	N	2008	.0001	0	ppm	5	5	Corrosion of galvanized pipe ; refineries; from waste batteries & paint
Arsenic	N	*2006	.003148	No Range	Ppb	n/a	50	Erosion of natural deposits ; Runoff from orchards , glass and electronics production wastes
Selenium	N	*2006	.0011544	0	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Barium	N	*2006	.0.055691	No Range	Ppm	2	2	Discharge of drilling wastes; refineries; erosion of natural deposits
Nitrate (as Nitrogen)	N	2008	0.02	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion from natural deposits
Antimony	N	*2006	.0005	No Range	ppb	6	4	Discharge from petroleum ; fire retardants; ceramics; solder test addition
Chromium	N	*2006	.000903	No Range	Ppb	100	100	Discharge from steel and pulp of natural deposits
Copper	N	2008	0.0	0	ppm	1.3	AL= 1.3	Corrosion of household plumbing erosion of natural deposits; leaching from wood preservatives
Cyanide	N	2006*	.005	0	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride	N	*2006	.997755	0.670-1.080	ppm	4	4	Erosion of natural deposits; additive which water promotes strong teeth; discharge from fertilizer and aluminum factories
Lead	N	2008	0.005	No Range	ppb	0	AL= 15	Corrosion of household plumbing erosion of natural deposits;
Mercury (inorganic)	N	*2006	.0002	No Range	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland

**Inorganic Contaminants**

Antimony	N	*2006	.0005	No Range	Ppb	6	6	Discharge from petroleum refineries ceramics; electronics ;
----------	---	-------	-------	----------	-----	---	---	---

**BUREAU OF PUBLIC WATER SUPPLY**

**CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM**

WPAKO Forest W.A.  
Public Water Supply Name

570025  
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

***Please Answer the Following Questions Regarding the Consumer Confidence Report***

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper  
 On water bills  
 Other \_\_\_\_\_

Date customers were informed: \_\_\_ / \_\_\_ / \_\_\_

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: \_\_\_ / \_\_\_ / \_\_\_

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Starkville Daily News

Date Published: \_\_\_ / \_\_\_ / \_\_\_

CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_ / \_\_\_ / \_\_\_

CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Sandra Seabright, Clerk  
Name/Title (President, Mayor, Owner, etc.)

\_\_\_\_\_  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

## Annual Drinking Water Quality Report

Wake Forest Water Association

PWS ID 530025

June 30, 2009

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater, and our two wells draw from the Gordo Formation.

If you have any questions about this report or concerning your water utility, please contact John Shaw at (662) 465-8788. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on Board meetings are held on the first Monday of each month at 6:00 P.M. at the water Association office on Sturgis Reform Rd.

Wake Forest Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Our source water assessment has been completed. Our wells were ranked Moderate to Low in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662.465-6494.

To help you better understand these terms we've provided the following definitions. In this table you will find many terms and abbreviations you might not be familiar with.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

### TEST RESULTS

Contaminant	Violated Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure ment	MCL G	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
Cadmium	N	2008	.0001	0	ppm	5	5	Corrosion of galvanized pipe ; refineries; from waste batteries & paint
Arsenic	N	*2006	.00314 8	No Range	Ppb	n/a	50	Erosion of natural deposits ; Runoff from orchards , glass and electronics production wastes
Selenium	N	*2006	.00115 44	0	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Barium	N	*2006	.0.0556 91	No Range	Ppm	2	.2	Discharge of drilling wastes; refineries; erosion of natural deposits
Nitrate (as Nitro gen)	N	2008	0.02	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion from natural deposits
Antimony	N	*2006	.0005	No Range	ppb	6	4	Discharge from petroleum ; fire retardants; ceramics; solder test addition
Chromium	N	*2006	.00090 3	No Range	Ppb	100	100	Discharge from steel and pulp of natural deposits
Copper	N	2008	0.0	0	ppm	1.3	AL= 1.3	Corrosion of household plumbing erosion of natural deposits; leaching from wood preservatives
Cyanide	N	2006*	.005	0	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride	N	*2006	.99775 5	0.670-1.080	ppm	4	4	Erosion of natural deposits; additive which water promotes strong teeth; discharge from fertilizer and aluminum factories
Lead	N	2008	0.005	No Range	ppb	0	AL= 15	Corrosion of household plumbing erosion of natural deposits;
Mercury (inorganic)	N	*2006	.0002	No Range	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfill; runoff from cropland

**Inorganic Contaminants**

Antimony	N	*2006	.0005	No Range	Ppb	6	6	Discharge from petroleum refineries, ceramics, electronics ;
----------	---	-------	-------	----------	-----	---	---	--

**Volatile Organic Contaminants**

HAA5 Total	N	2007*	1.0	No Range	ppb	0	40	By-product of drinking water chlorination
------------	---	-------	-----	----------	-----	---	----	---

\* Most recent sample None required in 2008

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

**Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

**\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Please call our office if you have questions. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

# The State of Mississippi

OKTIBBEHA COUNTY

## AFFIDAVIT OF PUBLICATION

Before me, in and for said county, this day personally came the undersigned representative of the Starkville Daily News, a newspaper published in the City of Starkville, of said county and state, who being duly sworn deposeth and says that the publication of a certain notice, a true copy of which, is hereto affixed has been made for 1 weeks consecutively, to wit:

Dated 6-12, 2009  
Dated \_\_\_\_\_, 20\_\_\_\_  
Dated \_\_\_\_\_, 20\_\_\_\_  
Dated \_\_\_\_\_, 20\_\_\_\_  
Dated \_\_\_\_\_, 20\_\_\_\_

Said representative further certifies that the several numbers of the newspaper containing the above mentioned notice have been produced and compared with the copy affixed; and that the publication thereof has been correctly made.

WITNESS MY HAND AND SEAL OF OFFICE, this the

17 day of June, A.D., 2009

By:

[Signature]  
Notary Public  
Commission Expires: October 19, 2010  
Equal Holder: Brooks & Gardner, Inc.

STARKVILLE DAILY NEWS

By:

[Signature]  
( ) Publisher  Clerk

SEAL:

Publication Fee \$ \_\_\_\_\_  
Proof(s) Of Publication \$ \_\_\_\_\_  
Total Charges \$ 450.00

AFFIDAVIT# 33370

**Annual Drinking Water Quality Report**  
**Wake Forest Water Association**  
**PWS ID 530025**  
**June 30, 2009**

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater, and our two wells draw from the Gordo Formation.

If you have any questions about this report or concerning your water utility, please contact John Shaw at (662) 465-8788. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on .Board meetings are held on the first Monday of each month at 6:00 P.M. at the water Association office on Sturgis Reform Rd.

Wake Forest Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Our source water assessment has been completed. Our wells were ranked **Moderate to Low** in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662.465-6494.

To help you better understand these terms we've provided the following definitions. In this table you will find many terms and abbreviations you might not be familiar with.

Parts per million (ppm) or Milligrams per liter (mg/l) -one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.



**Disinfectants & Disinfection By Products**

Chlorine [asC12]	N	2008	0.40	0.30-0.40	ppm	4	4	water additive used to control microbes
---------------------	---	------	------	-----------	-----	---	---	---

**Volatile Organic Contaminants**

HAA5 Total	N	2007*	1.0	No Range	ppb	0	40	By- product of drinking water chlorination
---------------	---	-------	-----	----------	-----	---	----	--

\* Most recent sample None required in 2008

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

**Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

**\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclids beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Please call our office if you have questions. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCL G	MCL	Likely Source of Contamination
-------------	------------------	----------------	----------------	--	------------------	-------	-----	--------------------------------

**Inorganic Contaminants**

Cadmium	N	2008	.0001	0	ppm	5	5	Corrosion of galvanized pipe ; refineries; from waste batteries & paint
Arsenic	N	*2006	.003148	No Range	Ppb	n/a	50	Erosion of natural deposits ; Runoff from orchards , glass and electronics production wastes
Selenium	N	*2006	.0011544	0	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Barium	N	*2006	.0.055691	No Range	Ppm	2	2	Discharge of drilling wastes; refineries; erosion of natural deposits
Nitrate (as Nitrogen)	N	2008	0.02	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion from natural deposits
Antimony	N	*2006	.0005	No Range	ppb	6	4	Discharge from petroleum ; fire retardants; ceramics; solder test addition
Chromium	N	*2006	.000903	No Range	Ppb	100	100	Discharge from steel and pulp of natural deposits
Copper	N	2008	0.0	0	ppm	1.3	AL= 1.3	Corrosion of household plumbing erosion of natural deposits; leaching from wood preservatives
Cyanide	N	2006*	.005	0	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride	N	*2006	.997755	0.670-1.080	ppm	4	4	Erosion of natural deposits; additive which water promotes strong teeth; discharge from fertilizer and aluminum factories
Lead	N	2008	0.005	No Range	ppb	0	AL= 15	Corrosion of household plumbing erosion of natural deposits;
Mercury (inorganic)	N	*2006	.0002	No Range	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland

**Inorganic Contaminants**

Antimony	N	*2006	.0005	No Range	Ppb	6	6	Discharge from petroleum refineries ceramics; electronics ;
----------	---	-------	-------	----------	-----	---	---	---

**Annual Drinking Water Quality Report**  
**Wake Forest Water Association**  
**PWS ID 530025**  
**June 30, 2009**

TO: OUR WATER CUSTOMERS

Our CCR Report for the year 2008 has been corrected. The chlorine residual was inadvertently left off of the report. For a copy of the corrected CCR report, contact your water system or 662-285-7243.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCL G	MCL	Likely Source of Contamination
-------------	------------------	----------------	----------------	--	------------------	-------	-----	--------------------------------

**Disinfectants & Disinfection By Products**

Chlorine [asCl <sub>2</sub> ]	N	2008	0.40	0.30-0.40	ppm	4	4	water additive used to control microbes
-------------------------------	---	------	------	-----------	-----	---	---	---

*Mailed  
6-27-09  
[Signature]*

# 2008 CCR Contact Information

Date: 6/22/09 Time: 12:27

PWSID: 530025

System Name: Wabe Forest

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) \_\_\_\_\_

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Mr. Vowell is very Frustrated about adding any  
thing to the CCR his Complaint is its non profitable  
and time Consuming, with a add Cost. He  
Stated he might do a corrected copy, Or be  
out of Compliance to get a hearing.  
I Faxed Mr. Vowell the Drinking Water Quality  
Report he will look at it, he has several System  
to do Corrected Copies on.

Spoke with Richard Vowell  
(Operator, Owner, Secretary)

662 547-6889  
662 285-7243  
662 547-9787 fax#

0100016  
0100006  
0100009

These are the Only ones he could think of at the time.