

2009 JUN 12 11:10:22

APPROVED

**BUREAU OF PUBLIC WATER SUPPLY**

**CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM**

City of Poplarville  
Public Water Supply Name

0550006 0550061  
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

**Please Answer the Following Questions Regarding the Consumer Confidence Report**

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper
  - On water bills
  - Other \_\_\_\_\_

Date customers were informed: 5/28/09 on water bill

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 1/1

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: THE POPLARVILLE DEMOCRAT

Date Published: 6/4/09

- CCR was posted in public places. *(Attach list of locations)*

Date Posted: 5/19/09 @ The City of Poplarville - City Hall

- CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Bill Jones - Mayor  
Name/Title (President, Mayor, Owner, etc.)

6-10-09  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

2008 Annual Drinking Water Quality Report  
 City of Poplarville  
 PWS#: 0550006  
 May 2009

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from two wells drawing from the Miocene Series Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Poplarville have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Samuel E. Hale at 601-795-8161. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first & third Tuesdays of each month at 5:00 P.M. at the City Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2008. In cases where monitoring wasn't required in 2008, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that rap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Treatment Technique (TT)* - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--------------------------	------------------	------	-----	--------------------------------

				Samples Exceeding MCL/ACL				
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2006*	.583	No Range	ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2006*	.019	.006 - .019	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
16. Fluoride**	N	2006*	.651	.224 - .651	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
66. Ethylbenzene	N	2008	1.14	No Range	ppb	700	700	Discharge from petroleum refineries
76. Xylenes	N	2008	.0005	No Range	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
<b>Disinfection By-Products</b>								
81. HAA5	N	2007*	.2	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2008	.63	.50 - .63	ppm	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2008.

\*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l.

As you can see by the table, our system had no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about

contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

**\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The City of Poplarville works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**CITY OF POPLARVILLE**  
**WATER & SEWER**  
 200 HWY. 26 EAST  
 POPLARVILLE, MS 39470

(601) 795-8161

PRESORTED  
 FIRST CLASS MAIL  
 U.S. POSTAGE PAID  
 POPLARVILLE, MS  
 PERMIT NO. 2

SERVICE FROM 04-20-09 TO 05-21-09 31 days

ACCT. 12023500: 519 MARTIN LUTHER KI

CURRENT	PREVIOUS	CONSUMPTION	AMOUNT
10399	10320	79	NORM READ

PAYMENTS 72.27CR  
 WATER 30.89  
 SEWER 24.64  
 GARBAGE 12.10  
 PRCUA SURCHARGE 1.50  
 LATE FEE 10.00

RETURN THIS STUB WITH YOUR REMITTANCE TO:  
**CITY OF POPLARVILLE**  
**WATER & SEWER**  
 200 HWY. 26 EAST  
 POPLARVILLE, MS 39470

ACCT. NO.	TOTAL DUE
12023500	162.12
BILLING DATE	DATE DUE
05-28-09	06-15-09

WE ARE AN EQUAL OPPORTUNITY SERVICE PROVIDER

MAE AARON  
 519 MARTIN LUTHER KING D  
 POPLARVILLE MS 39470

BILLING DATE	PREVIOUS BALANCE
05-28-09	155.26
DUE DATE	TOTAL DUE
06-15-09	162.12

The 2008 Drinking Water Quality Report(CCR) will be published in the June 4 Poplarville Democrat.

**STATE OF MISSISSIPPI,  
COUNTY OF PEARL RIVER**

PERSONALLY CAME before me, the undersigned, a notary public in and for PEARL RIVER County, Mississippi, Tom Andrews Publisher of THE POPLARVILLE DEMOCRAT, a newspaper published in the town of Poplarville, Pearl River County, In said state, who being dully sworn, deposes and says that The Poplarville Democrat is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858, of the Mississippi Code of 1942, and that the publication of a notice, of which the annexed is a copy, In the matter of

2008 ANNUAL WATER REPORT



has been made in said paper 1 consecutively,  
to wit:

On the 4TH day of JUNE 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_ 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_ 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_ 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_ 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_ 2009

  
\_\_\_\_\_  
The Poplarville Democrat

SWORN TO and subscribed before me, this 8TH  
day of JUNE 2009

My Commission Expires  
May 15, 2010

  
  
\_\_\_\_\_  
Notary Public

\_\_\_\_\_  
Poplarville, Mississippi 2009

TO THE POPLARVILLE DEMOCRAT

TO PUBLISHING CITY OF POPLARVILLE

case of 2008 ANNUAL WATER REPORT

\_\_\_\_\_ words space 3 X 21.25  
1 times and making proof \$434.59



## Inorganic Contaminants

8. Arsenic	N	2006*	.583	No Range	ppb	n/a	50	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
10. Barium	N	2006*	.019	.006-.019	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
16. Fluoride**	N	2006*	.651	.224-.651	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
17. Lead	N	2008	2	0	ppb	0	AL = 15	Corrosion of household plumbing systems; erosion of natural deposits.
66. Ethylbenzene	N	2008	1.14	No Range	ppb	700	700	Discharge from petroleum refineries.
76. Xylenes	N	2008	.0005	No Range	ppm	10	1	Discharge from petroleum factories; discharge from chemical factories.



## Disinfection By-Products

81. HAA5	N	2007*	.2	No Range	ppb	0	60	By-Product of drinking water disinfection
Chlorine	N	2008	.63	.50-.63	ppm	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2008.

\*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7-1.3 mg/l.

As you can see by the table, our system had no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by Stage 1 Disinfection By-Products Rule. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least a small amount of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk for infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-428-4791.

### \*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The City of Poplarville works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Publish: June 4, 2009