

Revised CCR 2008
 The 2008 report was revised on June 17, 2009.
 Updated copies are available in our office effective June 19, 2009.
 Updated ~~version~~ *version* was placed on our website (www.hawlms.com) on June 19.
 Our customers will be notified of this on our June 25, 2009 billing statement. A copy of the bill will be mailed to you after it is generated.

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Our customers will also be notified of this per notice posted on page 10 in our monthly newsletter (see attached).

Hide-A-Way Water System
 Public Water Supply Name

550013
 List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: / /

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 5/20/09

- CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: _____

Date Published: / /

- CCR was posted in public places. (*Attach list of locations*)

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www.hawlms.com
 (*on 6/22/2009*)

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Bruce J. Miller
 Name/Title (President, Mayor, Owner, etc.)

6-1-09
 Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
 Phone: 601-576-7518

Certification of Revised CCR 2008
Bruce J. Miller
 Name

6-22-09
 Date

RECEIVED-WATER SUPPLY
 2009 JUL -2 PM 1:53

2008 Drinking Water Quality Report

Revised June 17, 2009

HIDE-A-WAY WATER SYSTEM

Zoe Bretzius-Bowers, Certified Water Operator
PWS ID #550013 Pearl River County
510 E. LAKESHORE DR.
CARRIERE, MS 39426
601-798-1484

RECEIVED-WATER SUPPLY

2009 JUL -2 PM 1:54

Is my water safe?

Last year, as in years past, your tap water met all U. S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Where does my water come from?

Our water comes from two (2) wells that draw ground water from the **Miocene Series Aquifer**.

Source water assessment and its availability:

Our source water assessment has been completed by the Mississippi State Department of Health. Copies will be made available upon request.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

How can I get involved?

Our board meets on the **2nd WEDNESDAY evening of every month. Meetings start at 6:30 pm at the Hide-A-Way Lake Club House.** We encourage all customers who have any concerns or questions to meet with us. Our association conducts its annual membership meeting on the third Saturday in July at 10:00 a.m. at the Hide-A-Way Lake Club House. This is a very important meeting in which all customers are encouraged to attend.

Other information:

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address: <http://www.healthymys.com>. Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and Safe Drinking Water" may be obtained.

Water Quality Data Table

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi State Department of Health requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data though representative of the water quality may be more than one year old.

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hide-A-Way Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

Terms and Abbreviations used in the Table

MCLG: *Maximum Contaminant Level Goal* - is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.


MCL: *Maximum Contaminant Level* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: *Action Level* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

TEST RESULTS

Contaminant	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination
Inorganic Contaminants						
7. Antimony (ppm) Well #2 Well #3	6 6	.0006 .0006	.0005 .0005	03/22/06 03/22/06	NO NO	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
8. Arsenic (ppm) Well #2 Well #3	N/A	.05 .05	.0005 .0005	03/22/06 03/22/06	NO NO	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
10. Barium (ppm) Well #2 Well #3	2 2	2 2	.005 .007	03/22/06 03/22/06	NO NO	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits.
11. Beryllium (ppm) Well #2 Well #3	4 4	.004 .004	.0001 .0001	03/22/06 03/22/06	NO NO	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.
12. Cadmium (ppm) Well #2 Well #3	5 5	.005 .005	.0001 .0001	03/22/06 03/22/06	NO NO	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints.
13. Chromium (ppm) Well #2 Well #3	100 100	0.1 0.1	.0006 .001	03/22/06 03/22/06	NO NO	Discharge from steel and pulp mills; erosion of natural deposits.
14. Copper (ppm)	1.3	AL= 1.3	0.1	01/01/06– 12/31/08 (Triennial)	NO	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
15. Cyanide (ppm) Well #2 Well #3	200 200	.2 .2	.005 .005	03/22/06 03/22/06	NO NO	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
17. Lead (ppb)	0	AL = 15	0.001	01/01/06– 12/31/08 (Triennial)	NO	Corrosion of household plumbing systems, erosion of natural deposits.
18. Mercury (inorganic) (ppm) Well #2 Well #3	2 2	.002 .002	.0002 .0002	03/22/06 03/22/06	NO NO	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.
19. Nitrate (as Nitrogen) (ppm) Well #2 Well #3	10 10	10 10	0.08 0.08	07/07/08 07/07/08	NO NO	Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits.
20. Nitrite (as Nitrogen) (ppm) Well #2 Well #3	1 1	1 1	0.02 0.02	07/07/08 07/07/08	NO NO	Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits.
21. Selenium (ppm) Well #2 Well #3	50 50	.05 .05	0.0005 0.0005	03/22/06 03/22/06	NO NO	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.

22. Iodine (ppm)						
Well #2	0.5	.002	0.0005	03/22/06	NO	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories.
Well #3	0.5	.002	0.0005	03/22/06	NO	
73. TTHM (Total trihalomethanes) (mq/l)						
Well #2 and Well #3 combined average	0	0.080	0.017	09/06/07	NO	By-product of drinking water chlorination.
Disinfection By-Products						
Chlorine	4.0	4.0	1.19 running average	01/01/04–12/31/08	NO	Water additive used to control microbes.
Microbiological Contaminants	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination
# Total Coliform	0	>1	ND	Monthly	NO	Naturally present in the environment
<i>Units Description:</i> ppm: parts per million, or milligrams per liter (mg/l), ppb: parts per billion, or micrograms per liter (µg/l), pCi/l: picocuries per liter (a measure of radioactivity), % of monthly positive samples: Percent of samples taken monthly that were positive						



HIDE-A-WAY LAKE CLUB, INC.

P.O. Box 1011

PICAYUNE, MISSISSIPPI 39466

Phone: 601-798-1484

Fax: 601-798-0604

June 30, 2009

CERTIFIED MAIL

Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Re: Hide-A-Way Water System (PWS ID#550013) Revised CCR 2008

Dear Sir or Madame:

Per the revised 2008 Consumer Confidence Report Certification Form that we had mailed to your department on June 22, 2009, our customers were notified of the revised CCR 2008 via the monthly billing statement generated for June 25, 2009. The message, "CCR 2008 has been revised. See website or contact office for corrected copy." was placed on all of the billing statements. Attached is a copy of one of the billing statements. In addition to the message on the billing statement, a notice was placed on page 10 of our monthly newsletter (*Echoes* July edition) of the revised report.

Please call me at 601-798-1484 if you have any questions.

Sincerely,

Bruce Devillier
General Manager

Enclosure

RECEIVED - WATER SUPPLY
2009 JUL -2 PM 1:54

RECEIVED - WATER SUPPLY
2009 JUL -2 PM 1:54

HIDE-A-WAY LAKE CLUB, INC.
P.O. BOX 1011
PICAYUNE MS 39466
(601) 798-1484 Ext. 0000

RECEIVED-WATER SUPPLY
STATEMENT
2009 JUL -2 PM 1:53

Date:	6/25/2009
Account:	0001

Amount Due: \$99.35

Due Date: 07/25/2009

Amount Paid: _____

Check Number: _____

Phone #: (404) 371-1970

STUART HOLCOMBE - EXECUTOR
516 CLAIREMONT AVE.
DECATUR GA 30030

^Please return this portion with your payment^

Document No.	Date	Code	Description	Amount	Balance
	5/25/2009	BBF		\$104.35	\$104.35
PYMNT89038	6/18/2009	PMT		(\$104.35)	\$0.00
00016/25/2009	6/25/2009	SLS	179340-178390=950 GAL USED	\$15.35	\$15.35
0001CAP-RSV000000079	6/25/2009	SLS	CAPITAL RESERVE	\$15.00	\$30.35
0001GAR-FEE000000081	6/25/2009	SLS	GARBAGE FEE	\$13.00	\$43.35
0001OP-FEE0000000081	6/25/2009	SLS	OPERATIONAL FEE	\$51.00	\$94.35
0001SEC-FEE0000000081	6/25/2009	SLS	SECURITY FEE	\$5.00	\$99.35

Amount Due: \$99.35

CCR 2008 has been revised. See website or contact office for corrected copy.

HIDE-A-WAY LAKE CLUB, INC.

Lot #: 0001

Date: 6/25/2009

Current	1 - 30 Days	31 - 60 Days	61 and Over			
\$99.35	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00

Codes: SLS = Sales / Invoices
SCP = Scheduled Payments
DR = Debit Memos

FIN = Finance Charges
SVC = Service / Repairs
WRN = Warranties

CR = Credit Memos
RTN = Returns
PMT = Cash Receipts



July 2009

HAWL Board Meetings



A Board Meeting was held on June 10, 2009. See page 4 for Board Motions and Actions. The next Board Meeting is July 8, 2009 at 6:30 pm.



Stay Connected with Up-to-Date Information

In an effort to better communicate with our homeowners, we now offer an email newsletter. Get instant notification when important bulletins are available (boil water notices/lifts, burn bans/lifts, etc.). You will also receive a weekly Waters Edge Restaurant Specials and Events Mailing. Sign up online at www.hawlms.com and register for FREE! Once at the website, simply click on the 'Newsletters' button, located at the left side of the screen, and then follow the directions.



Every Vote Counts



Do your duty and cast your vote for the 2009 annual Board of Directors election. In addition to the annual election ballot, there will be a special second ballot to change the process of future elections. See page 5 for more information.



Pool Information

- The Pool's Hours of Operation are Tuesday-Sunday 11:00 am-8:00 pm.
- However, on July 4th the hours are 11:00 am-9:00 pm.
- Also, our Deck Dining Delivery Menu is featured on page 12.



Fourth of July Activities

- 11:00 am-9:00 pm: Pool Open
- 11:00 am-2:30 pm: BBQ Lunch at Waters Edge Restaurant
- 6:00 pm: Boat Parade Begins
- 9:00 pm: Fireworks Show
 - See page 6 for more July 4th information.
 - Please note, the rain date for the Fireworks Show is scheduled for July 5, 2009.



Up-Coming Events.

The Lunch Specials* for July are:

- Wed. Pulled Pork Sandwich w/ Chips or Fries \$7.95
- Thurs. Buy One get One 1/2 price Hamburger 1st @ \$7.95/2nd @ \$3.98
- Fri. Small Catfish Platter \$6.95

*July Lunch Specials include FREE beverage.
*Full menu will also be available.

- July 3rd Tilapia or Rib-Eye Steak Dinner*
- July 4th 4th of July BBQ Buffet 11:00 am-2:30 pm
Boat Parade begins at 6:00 pm
Fireworks Show begins at 9:00 pm
- July 5th Sunday Lunch Buffet
- July 8th Board Meeting
- July 10th Tilapia or Rib-Eye Steak Dinner*
- July 11th Italian Pasta Buffet
- July 12th Sunday Lunch Buffet
- July 18th Soft Shell Crab or Pork Medallion Dinner*
- July 19th Sunday Lunch Buffet
- July 24th Tilapia or Rib-Eye Steak Dinner*
- July 25th Soft Shell Crab or Pork Medallion Dinner*
- July 26th Sunday Lunch Buffet
- July 31st Tilapia or Rib-Eye Steak Dinner*
- Aug. 1st Recycling Drive
- Aug. 7th P.O.S. Dinner Theater
- Aug. 8th P.O.S. Dinner Theater

*Full menu will also be available.



See page 12 for more Waters Edge Restaurant events and information.

Local House Cleaning

Hide-A-Way Lake Resident

Yami Lumpkin

(601) 798-0872

(601) 590-4772

SUNCOAST PATIOS & SCREEN

Experienced

Patio Covers
Carport Covers
Screen Rooms
& Rescreens

Dependable

Phillip Dunn
601-590-1142

Free
Estimates

Carpet, Ceramic Tile, Vinyl & Wood Flooring

RON'S 7 KETTLE FLOORING

6431 Hwy. 11 North
Carriere, MS 39426

601-799-2943

601-799-1723 128 Third Street, Picayune MS

**A-1
AUTOMOTIVE REPAIR
AND SERVICE**

SUPPORT YOUR LOCAL LAKER!

GARY STOCKSTILL

Mon-Fri: 7:30-5:30

Page Bookkeeping and Tax Service

615 West Canal Street
Picayune, MS 39466
601/798-3116
FAX 601/798-5650

Bertha L. Page, Enrolled Agent

Please make sure to abide by all HAWL boating rules, which can be found online at www.hawlms.com or a copy can be picked up in the office. Listed below are a few examples of signs you will see posted on the Lake:

- Speed Limit- 40 mph on open lake during daylight hours and "No Wake" speed at night, when the flashing light is on at the lodge, or during periods of limited visibility.
- All watercraft shall operate at idle speed in marked "No Wake" areas including marinas, bays, coves, and within 100 feet adjacent to the shoreline in the open lake.



The 2008 Drinking Water Quality Report (CCR 2008) has been revised. Please see our website (www.hawlms.com) or contact the office for a corrected copy.



FIND YOUR ACCOUNT NUMBER!

Each month three (3) account numbers will be hidden in the Echoes. Look closely, as the account number may be in numerical or word format. However, the account number will not appear in any phone numbers, addresses, dollar amounts, time, or property owner advertisements. If you find your account number, call the Office (601-798-1484) to claim your prize!



2009 JUL -3 AM 9:09

APPROVED

BUREAU OF PUBLIC WATER SUPPLY
CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

Hide-A-Way Water System
Public Water Supply Name

550013
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: ___ / ___ / ___

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 5/29/09

- CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: _____

Date Published: ___ / ___ / ___

- CCR was posted in public places. (*Attach list of locations*)

Date Posted: ___ / ___ / ___

- CCR was posted on a publicly accessible internet site at the address: www. hawlms.com
on 07/22, 2009

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Benny D. Walker
Name/Title (President, Mayor, Owner, etc.)

6-1-09
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2008 Drinking Water Quality Report

HIDE-A-WAY WATER SYSTEM

Zoe Bretzious-Bowers, Certified Water Operator
PWS ID #550013 Pearl River County
510 E. LAKESHORE DR.
CARRIERE, MS 39426
601-798-1484

Is my water safe?

Last year, as in years past, your tap water met all U. S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Where does my water come from?

Our water comes from two (2) wells that draw ground water from the **Miocene Series Aquifer**.

Source water assessment and its availability:

Our source water assessment has been completed by the Mississippi State Department of Health. Copies will be made available upon request.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

How can I get involved?

Our board meets on the **2nd WEDNESDAY evening of every month. Meetings start at 6:30 pm at the Hide-A-Way Lake Club House.** We encourage all customers who have any concerns or questions to meet with us. Our association conducts its annual membership meeting on the third Saturday in July at 10:00 a.m. at the Hide-A-Way Lake Club House. This is a very important meeting in which all customers are encouraged to attend.

Other information:

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address: <http://www.msdh.state.us/watersupply/index.htm>. Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and Safe Drinking Water" may be obtained.

Water Quality Data Table

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi State Department of Health requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data though representative of the water quality may be more than one year old.

A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

✓ If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hide-A-Way Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

Terms and Abbreviations used in the Table

MCLG: *Maximum Contaminant Level Goal* - is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: *Maximum Contaminant Level* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: *Action Level* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

TEST RESULTS

Contaminant	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination
Inorganic Contaminants						
7. Antimony (ppm) Well #2 Well #3	6 6	.0006 .0006	.0005 .0005	03/22/06 03/22/06	NO NO	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
8. Arsenic (ppm) Well #2 Well #3	N/A	.05 .05	.0005 .0005	03/22/06 03/22/06	NO NO	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
10. Barium (ppm) Well #2 Well #3	2 2	2 2	.005 .007	03/22/06 03/22/06	NO NO	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits.
11. Beryllium (ppm) Well #2 Well #3	4 4	.004 .004	.0001 .0001	03/22/06 03/22/06	NO NO	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.
12. Cadmium (ppm) Well #2 Well #3	5 5	.005 .005	.0001 .0001	03/22/06 03/22/06	NO NO	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints.
13. Chromium (ppm) Well #2 Well #3	100 100	0.1 0.1	.0006 .001	03/22/06 03/22/06	NO NO	Discharge from steel and pulp mills; erosion of natural deposits.
14. Copper	1.3	AL= 1.3	0.1	01/01/06–12/31/08 (Triennial)	NO	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
15. Cyanide (ppm) Well #2 Well #3	200 200	.2 .2	.005 .005	03/22/06 03/22/06	NO NO	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
17. Lead	0	AL = 15	0.001	01/01/06–12/31/08 (Triennial)	NO	Corrosion of household plumbing systems, erosion of natural deposits.
18. Mercury (inorganic) (ppm) Well #2 Well #3	2 2	.002 .002	.0002 .0002	03/22/06 03/22/06	NO NO	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.
19. Nitrate (as Nitrogen) (ppm) Well #2 Well #3	10 10	10 10	0.08 0.08	07/07/08 07/07/08	NO NO	Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits.
20. Nitrite (as Nitrogen) (ppm) Well #2 Well #3	1 1	1 1	0.02 0.02	07/07/08 07/07/08	NO NO	Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits.
21. Selenium (ppm) Well #2 Well #3	50 50	.05 .05	0.0005 0.0005	03/22/06 03/22/06	NO NO	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.

22. Thallium (ppm)							
Well #2	0.5	.002	0.0005	03/22/06	NO	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories.	
Well #3	0.5	.002	0.0005	03/22/06	NO		
73. TTHM (Total trihalomethanes) (mg/l)							
Well #2 and Well #3 (combined average)	0	0.080	0.017	09/06/07	NO	By-product of drinking water chlorination.	
Microbiological Contaminants	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination	
# Total Coliform	0	>1	ND	Monthly	NO	Naturally present in the environment	
<i>Units Description:</i> ppm: parts per million, or milligrams per liter (mg/l); ppb: parts per billion, or micrograms per liter (µg/l); pCi/l: picocuries per liter (a measure of radioactivity); % of monthly positive samples: Percent of samples taken monthly that were positive.							

"Revised CCR 2008"

- Our CCR 2008 report was revised on June 17, 2009.
- Updated copies are available in our office effective June 19, 2009.
- Updated ~~copy~~ version was placed on our website (www.hawlms.com) on 6-19-09
- Our customers will be notified of this on our June 25, 2009 billing statement. A copy of the bill will be mailed to you after it is generated.

our customers will also be notified of this per notice placed on page 10 in our monthly newsletter (see attached).

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Hide-A-Way Water System
Public Water Supply Name

550013

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: ___ / ___ / ___

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 5/29/09

- CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: _____

Date Published: ___ / ___ / ___

- CCR was posted in public places. (*Attach list of locations*)

Date Posted: ___ / ___ / ___

- CCR was posted on a publicly accessible internet site at the address: www. hawlms.com
on 6/22/2009

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Bruce J. Miller
Name/Title (President, Mayor, Owner, etc.)

6-1-09
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

Certification of Revised CCR 2008

Bruce J. Miller
Name

6-22-09
Date

2009 JUN 24 AM 9:23

2008 Drinking Water Quality Report

Revised June 17, 2009

HIDE-A-WAY WATER SYSTEM

Zoe Bretzius-Bowers, Certified Water Operator

PWS ID #550013 Pearl River County

510 E. LAKESHORE DR.

CARRIERE, MS 39426

601-798-1484

Is my water safe?

Last year, as in years past, your tap water met all U. S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Where does my water come from?

Our water comes from two (2) wells that draw ground water from the **Miocene Series Aquifer**.

Source water assessment and its availability:

Our source water assessment has been completed by the Mississippi State Department of Health. Copies will be made available upon request.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

How can I get involved?

Our board meets on the **2nd WEDNESDAY evening of every month. Meetings start at 6:30 pm at the Hide-A-Way Lake Club House.** We encourage all customers who have any concerns or questions to meet with us. Our association conducts its annual membership meeting on the third Saturday in July at 10:00 a.m. at the Hide-A-Way Lake Club House. This is a very important meeting in which all customers are encouraged to attend.

Other information:

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address: <http://www.healthymms.com>. Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and Safe Drinking Water" may be obtained.

Water Quality Data Table

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi State Department of Health requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data though representative of the water quality may be more than one year old.

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of a...
Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hide-A-Way Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

2008 Drinking Water Quality Report

Revised June 17, 2009

HIDE-A-WAY WATER SYSTEM

Zoe Bretzius-Bowers, Certified Water Operator

PWS ID #550013 Pearl River County

510 E. LAKESHORE DR.

CARRIERE, MS 39426

601-798-1484

Is my water safe?

Last year, as in years past, your tap water met all U. S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Where does my water come from?

Our water comes from two (2) wells that draw ground water from the **Miocene Series Aquifer**.

Source water assessment and its availability:

Our source water assessment has been completed by the Mississippi State Department of Health. Copies will be made available upon request.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

How can I get involved?

Our board meets on the **2nd WEDNESDAY evening of every month. Meetings start at 6:30 pm at the Hide-A-Way Lake Club House.** We encourage all customers who have any concerns or questions to meet with us. Our association conducts its annual membership meeting on the third Saturday in July at 10:00 a.m. at the Hide-A-Way Lake Club House. This is a very important meeting in which all customers are encouraged to attend.

Other information:

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address: <http://www.healthymms.com>. Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and Safe Drinking Water" may be obtained.

Water Quality Data Table

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi State Department of Health requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data though representative of the water quality may be more than one year old.

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

73. TTHM (Total trihalomethanes) (mq/l) Well #2 and Well #3 combined average	0	0.080	0.017	09/06/07	NO	By-product of drinking water chlorination.
Disinfection By-Products						
Chlorine	4.0	4.0	1.19 running average	01/01/04- 12/31/08	NO	Water additive used to control microbes.
Microbiological Contaminants	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination
# Total Coliform	0	>1	ND	Monthly	NO	Naturally present in the environment
<i>Units Description:</i> ppm: parts per million, or milligrams per liter (mg/l), ppb: parts per billion, or micrograms per liter (µg/l), pCi/l: picocuries per liter (a measure of radioactivity), % of monthly positive samples: Percent of samples taken monthly that were positive						

2008 CCR Contact Information

Date: 6/5/09

Time: 10:08

PWSID: 550013

System Name: Hide-A-Way Water

Lead/Copper Language

MSDH Message re: Radiological Lab

MRDL Violation

Chlorine Residual (MRDL) RAA

Other Violation(s) _____

Will correct report & mail copy marked "**corrected copy**" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Amy Will Talk with Operator

Spoke with _____
(Operator, Owner, Secretary)