

2009 JUL -4 AM 9:10

# 2008 Annual Drinking Water Quality Report

City of luka  
PWS ID #0710006

APPROVED

## Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards set for quality and safety. Local Water vigilantly safeguards its water supplies and once again we are very proud that our system has not violated a maximum contaminant level or any other water quality standard. This report shows the results for our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2008. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

## Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

## Where does my water come from?

Our water source consists of four (4) wells; three that draws from the Paleozoic Aquifer and one drawing from the Fort Payne Chert Aquifer.

## Source water assessment and its availability:

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing at our office upon request. Listed below are the ratings for the wells of the City of luka.

- Well # 710006-01 – moderate rating on source water assessment
- Well # 710006-02 – higher rating on source water assessment
- Well # 710006-04 – moderate rating on source water assessment
- Well # 710006-05 – lower rating on source water assessment

## Why are there contaminants in my drinking water?

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### How can I get involved?

Please join us for our monthly meetings. Our board meets monthly on the first Tuesday night of each month at 7:00 PM at City Hall at 118 S Pearl Street. We encourage all customers with concerns or questions to meet with us.

## FOR MORE INFORMATION CONTACT:

<i>City of Iuka Water Department</i>
<i>ATTN: Josh Clingan</i>
<i>118 S Pearl Street</i>
<i>Iuka MS 38852</i>
<i>Phone: 662-423-9879</i>

### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Iuka is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

### Monitoring and reporting of compliance data violations

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system failed to complete these monitoring requirements in August of 2004, September of 2004, December of 2004, and April of 2007. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

### \*\*\*\*\* A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The tables below list all the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

# City of Iuka

## PWS ID # 0710006

### 2008 WATER QUALITY DATA TABLE

Contaminants (units)	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b>								
Chlorine (ppm)	4	4	0.97	0.87	0.97	2008	No	Water additive used to control microbes
HAA5 (Haloacetic Acids) (ppb)	0	60	6.0	N/A	N/A	2008	No	By Product of drinking water chlorination
<b>Inorganic Contaminants</b>								
Barium (ppm)	2	2	0.009	N/A	N/A	2006	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Cadmium (ppm)	0.005	0.005	0.0003	N/A	N/A	2005	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries runoff from waste batteries and paints
Chromium (ppm)	0.1	0.1	0.001	N/A	N/A	2005	No	Discharge from steel and pulp mills; Erosion of natural deposits.
Nickel (mg/l)	MNR	MNR	0.002	N/A	N/A	2004	No	
Nitrate {measured as Nitrogen} (ppm)	10	10	0.20	N/A	N/A	2008	No	Runoff from fertilizer user; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite {measured as Nitrogen} (ppm)	1	1	0.05	N/A	N/A	2008	No	Runoff from fertilizer user; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	50	50	0.05	N/A	N/A	2005	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines

Contaminants (units)	MCLG	AL	Your Water	# Samples Exceeding AL	Exceeds AL	Sample Date	Typical Source
<b>Inorganic Contaminants (Lead and Copper)</b>							
Copper (ppm)	1.3	1.3	0.5	0	No	2008	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	0	15	7	0	No	2008	Corrosion of household plumbing systems; Erosion of natural deposits

<b>Important Drinking Water Definitions</b>	
MCLG - Maximum Contaminant Level Goal	The level of a contaminant in drinking water below which there is no know or expected risk to health. MCLGs allow for a margin of safety.
MCL - Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
AL - Action Level	The concentration of a contaminant which, if exceeded, triggers a treatment or other requirements which a water system must follow.
TT-Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
MRDLG - Maximum Residual Disinfection Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL - Maximum Residual Disinfection Level	The highest level of a disinfectant allowed in drinking water. Ther is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR - Monitored Not Regulated	
MPL - State Assigned Maximum Permissible Level	

<b>Unit Descriptions</b>	
ppb - Parts per billion, or micrograms per liter (ug/l)	ppm - Parts per million, or milligrams per liter (mg/l)
pCi/L - Picocuries per liter (a measure of radioactivity)	NA - not applicable
ND - Not detected	NR - Moitoring not required, but recommended

## 2008 Annual Drinking Water Quality Report City of Iuka PWS ID #0710006

### Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards set for quality and safety. Local Water vigilantly safeguards its water supplies and once again we are very proud that our system has not violated a maximum contaminant level or any other water quality standard. This report shows the results for our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2008. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

### Where does my water come from?

Our water source consists of four (4) wells: three that draw from the Paleozoic Aquifer and one drawing from the Fort Payne Chert Aquifer.

### Source water assessment and its availability:

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing at our office upon request. Listed below are the ratings for the wells of the City of Iuka.

- Well # 710006-01 – moderate rating on source water assessment
- Well # 710006-02 – higher rating on source water assessment
- Well # 710006-04 – moderate rating on source water assessment
- Well # 710006-05 – lower rating on source water assessment

### Why are there contaminants in my drinking water?

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline 1-800-426-4791. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### How can I get involved?

Please join us for our monthly meetings. Our board meets monthly on the first Tuesday night of each month at 7:00 PM at City Hall at 118 S Pearl Street. We encourage all customers with concerns or questions to meet with us.

### FOR MORE INFORMATION CONTACT:

<i>City of Iuka Water Department</i>
ATTN: Josh Clingan
118 S Pearl Street
Iuka MS 38852
Phone: 662-423-9879

### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Iuka is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

**Monitoring and reporting of compliance data violations**

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system failed to complete these monitoring requirements in August of 2004, September of 2004, December of 2004, and April of 2007. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

**\*\*\*\*\* A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The tables below list all the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

**City of Iuka  
PWS ID # 0710006  
2008 WATER QUALITY DATA TABLE**

Contaminants (Units)	MCLG	MCL	Your Water	Range		Sample Date	Violation	Typical Source
	MRDLG	MRDL		Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b>								
Chlorine (ppm)	4	4	0.97	0.87	0.97	2008	No	Water additive used to control microbes
HAA5 (Haloacetic Acids) (ppb)	0	60	6.0	N/A	N/A	2008	No	By Product of drinking water chlorination
<b>Inorganic Contaminants</b>								
Barium (ppm)	2	2	0.009	N/A	N/A	2006	No	Discharge of drilling wastes, Discharge from metal refineries, Erosion of natural deposits
Cadmium (ppm)	0.005	0.005	0.0003	N/A	N/A	2005	No	Corrosion of galvanized pipes, Erosion of natural deposits, Discharge from metal refineries runoff from waste batteries and paints
Chromium (ppm)	0.1	0.1	0.001	N/A	N/A	2005	No	Discharge from steel and pulp mills, Erosion of natural deposits
Nickel (mg/l)	MNR	MNR	0.002	N/A	N/A	2004	No	
Nitrate (measured as Nitrogen) (ppm)	10	10	0.20	N/A	N/A	2008	No	Runoff from fertilizer user, Leaching from septic tanks, sewage, Erosion of natural deposits
Nitrite (measured as Nitrogen) (ppm)	1	1	0.05	N/A	N/A	2008	No	Runoff from fertilizer user, Leaching from septic tanks, sewage, Erosion of natural deposits
Selenium (ppb)	50	50	0.05	N/A	N/A	2005	No	Discharge from petroleum and metal refineries, Erosion of natural deposits, Discharge from mines

Contaminants (Units)	MCLG	AL	Your Water	# Samples Exceeding AL	Exceeds AL	Sample Date	Typical Source
<b>Inorganic Contaminants (Lead and Copper)</b>							
Copper (ppm)	1.3	1.3	0.5	0	No	2008	Corrosion of household plumbing systems, Erosion of natural deposits
Lead (ppb)	0	15	7	0	No	2008	Corrosion of household plumbing systems, Erosion of natural deposits

<b>Important Drinking Water Definitions</b>	
MCLG - Maximum Contaminant Level Goal	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL - Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
AL - Action Level	The concentration of a contaminant which, if exceeded, triggers a treatment or other requirements which a water system must follow.
TT - Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
MRDLG - Maximum Residual Disinfection Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL - Maximum Residual Disinfection Level	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR - Monitored Not Regulated	
MPL - State Assigned Maximum Permissible Level	

<b>Unit Descriptions</b>	
ppb - Parts per billion, or micrograms per liter (ug/l)	ppm - Parts per million, or milligrams per liter (mg/l)
pCi/L - Picocuries per liter (a measure of radioactivity)	NA - not applicable
ND - Not detected	NR - Monitoring not required, but recommended

City of luka

**PROOF OF PUBLICATION**

STATE OF MISSISSIPPI,  
TISHOMINGO COUNTY.

Personally appeared before me, the undersigned, Notary Public court, in and for said county, John H. Biggs, of the Tishomingo County News, a newspaper published in the Town of luka, in said county, who being duly sworn, deposes and says that the "notice," a copy of which is hereto attached, was published in said newspaper for One consecutive weeks, to wit:

In Vol. .... <u>125</u> .....	No. .... <u>41</u> .....	Dated .... <u>May 21,</u> .....	20 .....	<u>09</u>
In Vol. .... .....	No. .... .....	Dated .... .....	20 .....	
In Vol. .... .....	No. .... .....	Dated .... .....	20 .....	
In Vol. .... .....	No. .... .....	Dated .... .....	20 .....	
In Vol. .... .....	No. .... .....	Dated .... .....	20 .....	
In Vol. .... .....	No. .... .....	Dated .... .....	20 .....	
In Vol. .... .....	No. .... .....	Dated .... .....	20 .....	
In Vol. .... .....	No. .... .....	Dated .... .....	20 .....	
In Vol. .... .....	No. .... .....	Dated .... .....	20 .....	
In Vol. .... .....	No. .... .....	Dated .... .....	20 .....	

John H. Biggs, Publisher

Sworn to and subscribed before me this 22nd day of May, A.D., 2009

Fees \_\_\_\_\_  
Charlette B. McWay  
Notary Public

Annual Water Quality Report

STATEMENT

My Commission Expires 150.00  
**March 4, 2013**

Publishing _____ words, 12 cents first insertion .....	\$ _____
Publishing _____ words, 10 cents for each subsequent insertion .....	\$ _____
.....	\$ _____
Making proof of publication .....	\$ <u>3.00</u>
.....	\$ _____
Total .....	\$ <u>153.00</u>

**MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM**

**CITY OF IUKA**  
Public Water Supply Name

**0710006**

PWS ID#(s) (List ID #s for all Water Systems Covered by This CCR)

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

**Please Answer the Following Questions Regarding the Consumer Confidence Report**

Customers were informed of availability of CCR by:

Advertisement in local paper

On water bills

Other

Date customers were informed: 6/1/09

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: \_\_\_/\_\_\_/\_\_\_

CCR was published in local newspaper. (Attach copy of published CCR & proof of publication)

Name of Newspaper: Tishomingo County Vidette

Date Published: 5/21/09

CCR was posted in public places. (Attach list of locations)

Date Posted: \_\_\_/\_\_\_/\_\_\_

CCR was posted on a publicly accessible internet site at the address:


www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system official by the Mississippi State Department of Health, Bureau of Water Supply.

**Jackie Bryant, Mayor**

Name/Title (President, Mayor, Owner, etc.) Please type/print

  
Signature

6/1/09  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

030172001 04/23 05/23  
 SERVICE ADDRESS  
 801 INDIAN CREEK RD

CITY OF IUKA UTILITIES  
 118 S. PEARL STREET  
 IUKA, MS 38852

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PERMIT NO. 11  
 IUKA, MS

CURRENT	METER READINGS		USED
	PREVIOUS		
2717	2698		19 W
2660	2645		15 G

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/16/2009	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
36.63	3.66	40.29

CHARGE FOR SERVICES  
 GAS 14.38  
 WTR 7.50  
 SEW 7.50  
 GRB 7.25  
 NET DUE >>> 36.63  
 SAVE THIS >> 3.66  
 GROSS DUE >> 40.29

2008 CCR IS AVAILABLE AT CITY HALL.

RETURN SERVICE REQUESTED

030172001  
 MARY MAXWELL  
 801 INDIAN CREEK RD  
 IUKA MS 38852-2607



ACCOUNT NO. SERVICE FROM SERVICE TO  
 030182202 04/23 05/23  
 SERVICE ADDRESS  
 613 PIKE ST E

RETURN THIS STUB WITH PAYMENT TO:  
 CITY OF IUKA UTILITIES  
 118 S. PEARL STREET  
 IUKA, MS 38852

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PERMIT NO. 11  
 IUKA, MS

CURRENT	METER READINGS		USED
	PREVIOUS		
10684	10669		15 W
16383	16364		19 G

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/16/2009	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
39.38	3.94	43.32

CHARGE FOR SERVICES  
 GAS 17.13  
 WTR 7.50  
 SEW 7.50  
 GRB 7.25  
 NET DUE >>> 39.38  
 SAVE THIS >> 3.94  
 GROSS DUE >> 43.32

2008 CCR IS AVAILABLE AT CITY HALL.

RETURN SERVICE REQUESTED

030182202  
 BRYANT OR JAMIE GARGUS  
 613 PIKE ST  
 IUKA MS 38852-2613



ACCOUNT NO. SERVICE FROM SERVICE TO  
 030147800 04/23 05/23  
 SERVICE ADDRESS  
 502 ABERDEEN ST S

RETURN THIS STUB WITH PAYMENT TO:  
 CITY OF IUKA UTILITIES  
 118 S. PEARL STREET  
 IUKA, MS 38852

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PERMIT NO. 11  
 IUKA, MS

CURRENT	METER READINGS		USED
	PREVIOUS		
15759	15722		37 W
758	757		1 G

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/16/2009	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
29.75	2.98	32.73

CHARGE FOR SERVICES  
 GAS 7.50  
 WTR 7.50  
 SEW 7.50  
 GRB 7.25  
 NET DUE >>> 29.75  
 SAVE THIS >> 2.98  
 GROSS DUE >> 32.73

2008 CCR IS AVAILABLE AT CITY HALL.

RETURN SERVICE REQUESTED

030147800  
 YVONNE M RUSSELL  
 502 S ABERDEEN ST  
 IUKA MS 38852-2614

