

APPROVED

2009 JUN 19 AM 8:57

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2008 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

McHenry Utility Association, Inc. Public Water Supply Name

0660002 List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
- Advertisement in local paper
- On water bills
- Other

Date customers were informed: / /

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: Stone County Enterprise

Date Published: 6/10/09

- CCR was posted in public places. (Attach list of locations)

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Monica Parker / manager Name/Title (President, Mayor, Owner, etc.)

6/17/09 Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215 Phone: 601-576-7518

**2008 ANNUAL DRINKING WATER QUALITY REPORT**  
**MCHENRY UTILITY ASSOCIATION, INC.**  
**PWS ID: 0660002**

The purpose of this report is to keep the users of water provided by this non-profit utility association informed concerning the water and services delivered over the past year. It will not be mailed to each customer. The association's goal is and always has been, to provide a safe and dependable supply of drinking water. The association's source of water is a four and a six inch well, both of which draw groundwater from the Miocene aquifer.

The drinking water provided by this utility association meets federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mark Blackwell at 601-762-5132. The mailing address is Mc Henry Utility Association, Inc., Post Office Box 23, McHenry, Mississippi 39561. It is important to this association that customers are fully informed about their water utility. Customers are welcome to attend regular association meetings, which are held on the first Tuesday of even numbered months at 6:30 p.m. at the Neighborhood Watch Building, McHenry, MS. The February meeting additionally serves as the annual meeting.

McHenry Utility Association, Inc. routinely monitors for constituents in the drinking water as required by Federal and Mississippi laws. The table included with this report shows the results of monitoring for the period of January 1, 2008 to December 31, 2008. As water travels over land and underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It is important to remember that the presence of these constituents does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. McHenry Utility Association, Inc. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

**Definitions**

**Maximum Contaminant Level-** The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCGLs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal-** The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Non-detects (ND)-** Laboratory analysis indicates the constituent is not present.

**Parts Per Million- ppm**

**Milligrams Per Liter-mg/L**

**Parts Per Billion- ppb**

**Picocuries Per Liter- Picocuries per liter (pCi/l)** is a measure of the radioactivity in water.

**Action Level- AL**

WATER QUALITY TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>								
1. Total Coliform Bacteria	NO		0			0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
<b>Radioactive Contaminants</b>								
2. Beta/Photon emitters	NO	October 13, 1999	ND	0	PCi/l	0	50	Decay of natural and man-made deposits
3. Alpha emitters	NO	October 13, 1999	ND	0	PCi/l	0	15	Erosion of natural deposits

### Inorganic Contaminants

4. Copper	NO	2008	0.0	0	mg/L	0	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
5. Lead	NO	2008	0.002	0	mg/L	0	0.015	Corrosion of household plumbing systems, erosion of natural deposits.
6. Fluoride	NO	April 10, 2006	0.68876 6 ppm	0	ppm	4 ppm		Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
7. Sulfate	NO	March 29, 2004	7.510 mg/l	0	mg/l	250.0 mg/l		
8. Barium	NO	April 10, 2006	0.01110 8 ppm	0	ppm	2 ppm		Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
9. Chromium	NO	April 10, 2006	0.00212 7 ppm	0	ppm	0.1 ppm		Discharge from steel and pulp mills; Erosion of natural deposits
10. Antimony	NO	April 10, 2006	Less than 0.0005 ppm	0	ppm	0.006 ppm		
11. Arsenic	NO	April 10, 2006	Less than 0.0005 ppm	0	ppm	0.05 ppm		
12. Beryllium	NO	April 10, 2006	Less than 0.0001 ppm	0	ppm	0.004 ppm		
13. Cadmium	NO	April 10, 2006	Less than 0.0001 ppm	0	ppm	0.005 ppm		
14. Mercury	NO	April 10, 2006	Less than 0.0002 ppm	0	ppm	0.002 ppm		
15. Selenium	NO	April 10, 2006	Less than 0.0005 ppm	0	ppm	0.05 ppm		

### Microbiological Contaminants:

Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

#### Comment:

Infrequently, water pressure is lost because of a hurricane, electrical power loss or a broken line, which requires repair. The line or lines, when restored to the proper pressure, are then extensively flushed with chlorine treated water to remove and/or kill any contaminants. Should a user note such pressure loss, any water used for drinking should be boiled. Additionally, should a user effect repairs or modifications to lines on the user side of the meter, extensive flushing with the utility association's chlorinated water should take place before drinking water from these user lines.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call if you have questions or desire a copy of this report. The McHenry Utility Association, Inc. requests that all customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Publish: 6/10/09

# Stone County Enterprise

PO Box 157, Wiggins, MS 39577 • 601-928-4802 (phone) • 601-928-2191 (fax)

## Proof of Publication

STATE OF MISSISSIPPI  
COUNTY OF STONE  
CITY OF WIGGINS

Personally appeared before me the undersigned authority in and for City, County and State aforesaid, **Heather Freret** who being by me first duly sworn, states on oath, that she is Publisher of the **Stone County Enterprise**, a newspaper published in the City, County, and State aforesaid, and the publication of the notice, a copy of which is hereto attached, has been made in said newspaper \_\_\_\_\_ times as follows:

On the 10<sup>th</sup> day of June 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_ 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_ 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_ 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_ 2009  
On the \_\_\_\_\_ day of \_\_\_\_\_ 2009



Heather Freret

Sworn to and subscribed before me this 10<sup>th</sup> day of June 2009.

Charlotte Wippler  
Notary Public

My commission expires



**2008 ANNUAL DRINKING WATER QUALITY REPORT  
MCHENRY UTILITY ASSOCIATION, INC.  
PWS ID: 0660002**

Chlorine  
Residual  
Missing

The purpose of this report is to keep the users of water provided by this non-profit utility association informed concerning the water and services delivered over the past year. It will not be mailed to each customer. The association's goal is and always has been, to provide a safe and dependable supply of drinking water. The association's source of water is a four and a six inch well, both of which draw groundwater from the Miocene aquifer. Our source water assessment has been completed. Our wells were ranked **moderate** in terms of susceptibility to contamination. For a copy of the report, please contact our office at 601-762-5132.

The drinking water provided by this utility association meets federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mark Blackwell at 601-762-5132. The mailing address is Mc Henry Utility Association, Inc., Post Office Box 23, McHenry, Mississippi 39561. It is important to this association that customers are fully informed about their water utility. Customers are welcome to attend regular association meetings, which are held on the first Tuesday of even numbered months at 6:30 p.m. at the Neighborhood Watch Building, McHenry, MS. The February meeting additionally serves as the annual meeting.

McHenry Utility Association, Inc. routinely monitors for constituents in the drinking water as required by Federal and Mississippi laws. The table included with this report shows the results of monitoring for the period of January 1, 2008 to December 31, 2008. As water travels over land and underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It is important to remember that the presence of these constituents does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

#### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. McHenry Utility Association, Inc. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public

Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

### Definitions

**Maximum Contaminant Level-** The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCGLs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal-** The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Non-detects (ND)-** Laboratory analysis indicates the constituent is not present.

**Parts Per Million- ppm**

**Milligrams Per Liter-mg/L**

**Parts Per Billion- ppb**

**Picocuries Per Liter-** Picocuries per liter (pCi/l) is a measure of the radioactivity in water.

**Action Level- AL**

<b>WATER QUALITY TEST RESULTS</b>								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>								
1. Total Coliform Bacteria	NO			0		0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
<b>Radioactive Contaminants</b>								
2. Beta/photon emitters	NO	October 13, 1999	ND	0	PCi/l	0	50	Decay of natural and man-made deposits
3. Alpha emitters	NO	October 13, 1999	ND	0	PCi/l	0	15	Erosion of natural deposits
<b>Inorganic Contaminants</b>								
4. Copper	NO	2008	0.0	0	mg/L	0	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
5. Lead	NO	2008	0.002	0	mg/L	0	0.015	Corrosion of household plumbing systems, erosion of natural deposits.
6. Fluoride	NO	April 10, 2006	0.68876 6 ppm	0	ppm		4 ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from

**Microbiological Contaminants:**

Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

**Comment:**

Infrequently, water pressure is lost because of a hurricane, electrical power loss or a broken line, which requires repair. The line or lines, when restored to the proper pressure, are then extensively flushed with chlorine treated water to remove and/or kill any contaminates. Should a user note such pressure loss, any water used for drinking should be boiled. Additionally, should a user effect repairs or modifications to lines on the user side of the meter, extensive flushing with the utility association's chlorinated water should take place before drinking water from these user lines.

**\*\*\*\*\*MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply at 601.576.7518.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call if you have questions or desire a copy of this report. The McHenry Utility Association, Inc. requests that all customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**2008 ANNUAL DRINKING WATER QUALITY REPORT**  
**McHENRY UTILITY ASSOCIATION, INC.**  
**PWS ID: 0660002**

The purpose of this report is to keep the users of water provided by this non-profit utility association informed concerning the water and services delivered over the past year. It will not be mailed to each customer. The association's goal is and always has been, to provide a safe and dependable supply of drinking water. The association's source of water is a four and a six inch well, both of which draw groundwater from the Miocene aquifer. Our source water assessment has been completed. Our wells were ranked **moderate** in terms of susceptibility to contamination. For a copy of the report, please contact our office at 601-762-5132.

The drinking water provided by this utility association meets federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mark Blackwell at 601-762-5132. The mailing address is Mc Henry Utility Association, Inc., Post Office Box 23, McHenry, Mississippi 39561. It is important to this association that customers are fully informed about their water utility. Customers are welcome to attend regular association meetings, which are held on the first Tuesday of even numbered months at 6:30 p.m. at the Neighborhood Watch Building, McHenry, MS. The February meeting additionally serves as the annual meeting.

McHenry Utility Association, Inc. routinely monitors for constituents in the drinking water as required by Federal and Mississippi laws. The table included with this report shows the results of monitoring for the period of January 1, 2008 to December 31, 2008. As water travels over land and underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It is important to remember that the presence of these constituents does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

#### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. McHenry Utility Association, Inc. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public



Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

### Definitions

**Maximum Contaminant Level-** The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal-** The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Non-detects (ND)-** Laboratory analysis indicates the constituent is not present.

**Parts Per Million- ppm**

**Milligrams Per Liter-mg/L**

**Parts Per Billion- ppb**

**Picocuries Per Liter-** Picocuries per liter (pCi/l) is a measure of the radioactivity in water.

**Action Level- AL**

## WATER QUALITY TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>								
1. Total Coliform Bacteria	NO			0		0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
<b>Inorganic Contaminants</b>								
4. Copper	NO	2008	0.0	0	mg/L	0	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
5. Lead	NO	2008	0.002	0	mg/L	0	0.015	Corrosion of household plumbing systems, erosion of natural deposits.
6. Fluoride	NO	April 10, 2006	0.688766 ppm	0	ppm		4 ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
7. Sulfate	NO	March 29, 2004	7,510 mg/l	0	mg/l		250.0 mg/l	
8. Barium	NO	April 10,	0.011108	0	ppm		2 ppm	Discharge of drilling

		2006	ppm					wastes; Discharge from metal refineries; Erosion of natural deposits
9. Chromium	NO	April 10, 2006	0.002127 ppm	0	ppm		0.1 ppm	Discharge from steel and pulp mills; Erosion of natural deposits
10. Antimony	NO	April 10, 2006	Less than 0.0005 ppm	0	ppm		0.006 ppm	
11. Arsenic	NO	April 10, 2006	Less than 0.0005 ppm	0	ppm		0.05 ppm	
12. Beryllium	NO	April 10, 2006	Less than 0.0001 ppm	0	ppm		0.004 ppm	
13. Cadmium	NO	April 10, 2006	Less than 0.0001 ppm	0	ppm		0.005 ppm	
14. Mercury	NO	April 10, 2006	Less than 0.0002 ppm	0	ppm		0.002 ppm	
15. Selenium	NO	April 10, 2006	Less than 0.0005 ppm	0	ppm		0.05 ppm	
16. Thallium	NO	April 10, 2006	Less than 0.0005 ppm	0	ppm		0.002 ppm	
17. Cyanide	NO	April 10, 2006	Less than 0.005 ppm	0	ppm		0.2 ppm	
18. Nitrate (as N) TF101,TF102	NO	July 21, 2008	Less than 0.08 ppm	0	ppm		10 ppm	
19. Nitrite (as N) TF101,TF102	NO	July 21, 2008	Less than 0.02 ppm	0	ppm		1 ppm	
20. Nitrate+Nitrite (as N) TF101,TF102	NO	July 21, 2008	Less than 0.1 ppm	0	ppm		10 ppm	
Running Annual Average for Trihalomethanes	NO	October 3, 2006	4.0 ppb	0	ppb		80.0 ppb	
Running Annual Average for Haloacetic Acids	NO	October 3, 2006	0.4 ppb	0	ppb		60.0 ppb	
<b>Disinfection Byproducts</b>								
Chlorine(as Cl2)	N	2008	Average 0.53 Highest 0.53 Lowest 0.52	0	ppm	4.0	4.0	Water additive used to control microbes

**Microbiological Contaminants:**

Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

**Comment:**

Infrequently, water pressure is lost because of a hurricane, electrical power loss or a broken line, which requires repair. The line or lines, when restored to the proper pressure, are then extensively flushed with chlorine treated water to remove and/or kill any contaminates. Should a user note such pressure loss, any water used for drinking should be boiled. Additionally, should a user effect repairs or modifications to lines on the user side of the meter, extensive flushing with the utility association's chlorinated water should take place before drinking water from these user lines.

\*\*\*\*\*MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\*

✓ In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

✓ Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply at 601.576.7518.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call if you have questions or desire a copy of this report. The McHenry Utility Association, Inc. requests that all customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

# 2008 CCR Contact Information

Date: 6/19/09 Time: 4:27

PWSID: 660002

System Name: McDenny

Lead/Copper Language MSDH Message re: Radiological Lab

MRDL Violation Chlorine Residual (MRDL) RAA

Other Violation(s) \_\_\_\_\_

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Mr. Willis will contact the person who prepared the CCR and get them to do a corrected copy and mail to us by July 1, 2009 and Notify Customers of available report by July 1, 2009.

Spoke with Billy Willis 601 528-1493  
(Operator, Owner, Secretary)

9/10/09 11:36

Billy Willis will call me back after he speak with the person who prepared CCR.

9/10/09  
SECOND ATTEMPT

9/10/09 11:48  
John Price Accountant 601-928-3681  
will do corrected copy and Fax to us.