

RECEIVED - WATER SUPPLY
2010 JUN 23 PM 1:43



MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2009 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

Combined Utilities Inc.

Public Water Supply Name

0200001

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: 6/17/2010

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:
Date Mailed/Distributed: / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*
Name of Newspaper: George County Times
Date Published: 6/17/2010

- CCR was posted in public places. *(Attach list of locations)*
Date Posted: 6/17/2010 George County Public Library

- CCR was posted on a publicly accessible internet site at www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Lenny Howell

Name/Title (President, Mayor, Owner, etc.)

6-22-2010

Date

Use Completed Form for Bureau of Public Water Supply/E.O. Form 1700/Jackson, MS 39215

Phone: 601-576-7318

570 East Woodrow Wilson · Post Office Box 1700 · Jackson, MS 39215-1700
601-576-8090 · 1-866-HLTHY4U · www.HealthyMS.com

Equal Opportunity in Employment/Services

RECEIVED - WATER SUPPLY
 2010 JUN -8 PM 12:47

2009 Annual Drinking Water Quality Report
 Combined Utilities
 PWS ID#: 0200001
 June 2010

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Tipper Catahoula Formation and the Miocene Series Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Combined Utilities have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Stacey Dungan at 601.508.3866. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 6:00 PM at 9147 Old HWY 63 South.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2009. In cases where monitoring wasn't required in 2009, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								

8. Arsenic	N	2008*	.21	.12 - .21	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2008*	.010	.008- .01	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2008*	2	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2005/07*	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2008*	.946	.208 - .946	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2008*	1.2	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection By-Products								
81. HAA5	N	2008*	17	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2008*	45.32	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2009	.83	.55 – 1.48	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2009.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Combined Utilities works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

NOTIFICATION OF NOTICE

**STATE OF MISSISSIPPI
COUNTY OF GEORGE**

Before me, the undersigned authority in and for the County and State aforesaid, this day personally appeared O.G. SELLERS

_____, who being dually sworn, states on oath that he is the EDITOR of the George County Times, a newspaper published in the City (or Town) of Lucedale, State and County aforesaid, and with a general circulation in said county, and that the publication of the notice, a copy of which is hereby attached, has been made in said paper One times, at weekly intervals, and in the regular entire issue of said newspaper for the numbers and dates hereinafter named for One consecutive weeks, immediately proceeding the date of sale named in said notice, to-wit:

- Vol. 106 No. 24 on the 17th day of June 2010
- Vol. _____ No. _____ on the _____ day of _____ 2010
- Vol. _____ No. _____ on the _____ day of _____ 2010
- Vol. _____ No. _____ on the _____ day of _____ 2010

[Signature]

Sworn to and subscribed before me, this the 17th day of June, 2010

[Signature]



Drinking Water Quality Report
Combined Utilities
WS ID#: 0200001
June 2010

Water Report. This report is designed to inform you about the quality water is to provide you with a safe and dependable supply of drinking water. We improve the water treatment process and protect our water resources. We water source is from wells drawing from the Tipper Catahoula Formation and

our public water system to determine the overall susceptibility of its drinking water. The general susceptibility rankings assigned to each well of this system are information on how the susceptibility determinations were made has been viewing upon request. The wells for the Combined Utilities have received

your water utility, please contact Stacey Dungan at 601.508.3866. We want utility. If you want to learn more, please attend any of our regularly scheduled month at 6:00 PM at 9147 Old HWY 63 South.

water according to Federal and State laws. This table below lists all of the the period of January 1st to December 31st, 2009. In cases where monitoring t results. As water travels over the surface of land or underground, it dissolves tive materials and can pick up substances or contaminants from the presence s, such as viruses and bacteria, that may come from sewage treatment plants, diffe; inorganic contaminants, such as salts and metals, which can be naturally trial, or domestic wastewater discharges, oil and gas production, mining, or om a variety of sources such as agriculture, urban storm-water runoff, and ng synthetic and volatile organic chemicals, which are by-products of industrial he from gas stations and septic systems; radioactive contaminants, which can duction and mining activities. In order to ensure that tap water is safe to drink, ain contaminants in water provided by public water systems. All drinking water, ected to contain at least small amounts of some constituents. It's important to not necessarily indicate that the water poses a health risk.

you might not be familiar with. To help you better understand these terms we've

sh, if exceeded, triggers treatment or other requirements which a water system

a required process intended to reduce the level of a contaminant in drinking

Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking e using the best available treatment technology.

(MCLG) is the level of a contaminant in drinking water below which there is no margin of safety.

highest level of a disinfectant allowed in drinking water. There is convincing control microbial contaminants.

- The level of a drinking water disinfectant below which there is no known or nefits of the use of disinfectants to control microbial contaminants.

TEST RESULTS

Number of Detects of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
21	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes