



RECEIVED - WATER SUPPLY
2010 JUN 22 PM 1:41

MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2009 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

John C. Stennis Space Center
Public Water Supply Name

#0230015

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other e-mail to Environmental Working Group, Orbiter

Date customers were informed: 06 / 18 / 2010

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: / /

- CCR was posted in public places. *(Attach list of locations)* See attachment II

Date Posted: / /

- CCR was posted on a publicly accessible intranet and Center wide electronic global notice.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Ronald H. Magee
Name/Title (President, Mayor, Owner, etc.)

6/18/2010
Date

**Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518**

570 East Woodrow Wilson Post Office Box 1700 Jackson, MS 39215-1700
601-576-8090 1-866-HLTHY4U www.HealthyMS.com

Consumer Confidence Report

Is my water safe?

The John C. Stennis Space Center (SSC) continues to report as in years past, that the tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The routine monitoring is done onsite by the NASA Environmental Laboratory each month throughout the Center but the Mississippi Department of Health obtains split random samples throughout the year. SSC vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. Only those contaminants that were detected are reflected in this report.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

There are several aquifers that can be traced through Hancock County where SSC is located. The area is underlain by freshwater bearing, southward-tipping sands of Miocene and Pliocene ages. The sequence of alternating and discontinuous clay layers, creating the confining nature of the deeper aquifers, is part of the Coastal Lowlands Aquifer System or the Southeastern Coastal Plain System. SSC's drinking water well depths range from 1,434 to 1,530 feet with a natural flow of 1,100 to 2,500 gallons per minute.

Source water assessment and its availability

A Vulnerability Assessment for the SSC Drinking Water System was completed and forwarded to the U. S. Environmental Protection Agency along with the Certification Statement in 2004. The Certification Statement was also sent to the Mississippi State Department of Health (MSDH). The Environmental portion of the Assessment was updated and released in 2009. Our wells were ranked lower in terms of susceptibility to contamination. MSDH conducts an annual compliant site review and we continue to maintain an excellent rating.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can

be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

How can I get involved?

See the Conservation Tips for how you can get involved at work as well as at home.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.

- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. John C. Stennis Space Center is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants	MCLG	MCL, TT, or	Your Water	Range		Sample Date	Violation	Typical Source
	MRDLG	MRDL		Low	High			
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	1.22	0.72	1.22	2009	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	20	NA		2009	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	58	NA		2009	No	By-product of drinking water disinfection
Inorganic Contaminants								
Barium (ppm)	2	2	0.015	0.014	0.015	2008	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

Copper - source water (ppm)		MPL	0.39(MPL)	0.02	0.39	2009	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - source water (ppm)		MPL	0.086(MPL)	0	0.086	2009	No	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride (ppm)	4	4	0.24	0.2	0.24	2008	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Microbiological Contaminants

Total Coliform (positive samples/month)	0	1	0	NA		2009	No	Naturally present in the environment
---	---	---	---	----	--	------	----	--------------------------------------

<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your Water</u>	<u>Sample Date</u>	<u># Samples Exceeding AL</u>	<u>Exceeds AL</u>	<u>Typical Source</u>
---------------------	-------------	-----------	-------------------	--------------------	-------------------------------	-------------------	-----------------------

Inorganic Contaminants

Copper - action level at consumer taps (ppm)	1.3	1.3	0.2	2009	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	0.004	2009	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions

Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
positive samples/month	positive samples/month: Number of samples taken monthly that were found to be positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Jenette B. Gordon
Address:
B1100 Room 3021G
SSC, MS 39529
Phone: 228-688-1416
Fax: 228-688-6699
E-Mail: Jenette.B.Gordon@nasa.gov

2009 CCR Contact Information

Date: 7/15/10 Time: 3:36pm

PWSID: 230015

System Name: John C Stennis Space Center

Lead/Copper Language

Chlorine Residual (MRDL) RAA

Other Violation(S) _____

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Connecting today will email corrected copy.

Spoke with Opardle Gordon 228-688-1416
(Operator, Owner, Secretary)

Cockrell, Joan

From: Gordon, Jenette B. (SSC-RA02) [jenette.b.gordon@nasa.gov]
Sent: Thursday, July 15, 2010 4:11 PM
To: Cockrell, Joan
Subject: SSC Revised 2009 CCR

Joan,

Per our conversation on today, 07/15th I have included the required language for 'Additional Information for Lead'. It was in the original package but during the reformatting with the table we inadvertently left off that particular section. I will send the entire document out to the customers again electronically on tomorrow.

Thanks again for your support and assistance. If you require additionally assistance, please call me.

Sincerely,

Jenette

Jenette B. Gordon
Environmental Management Staff
B1100 Room 3017F
SSC, MS 39529-6000
Phone: (228) 688-1416
FAX: (228) 688-6699

"We do not inherit the earth from our ancestors, we borrow it from our children."
~~ Native American Proverb

7/15/2010

Consumer Confidence Report

Is my water safe?

The John C. Stennis Space Center (SSC) continues to report as in years past, that the tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The routine monitoring is done onsite by the NASA Environmental Laboratory each month throughout the Center but the Mississippi Department of Health obtains split random samples throughout the year. SSC vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. Only those contaminants that were detected are reflected in this report.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

There are several aquifers that can be traced through Hancock County where SSC is located. The area is underlain by freshwater bearing, southward-tipping sands of Miocene and Pliocene ages. The sequence of alternating and discontinuous clay layers, creating the confining nature of the deeper aquifers, is part of the Coastal Lowlands Aquifer System or the Southeastern Coastal Plain System. SSC's drinking water well depths range from 1,434 to 1,530 feet with a natural flow of 1,100 to 2,500 gallons per minute.

Source water assessment and its availability:

A Vulnerability Assessment for the SSC Drinking Water System was completed and forwarded to the U. S. Environmental Protection Agency along with the Certification Statement in 2004. The Certification Statement was also sent to the Mississippi State Department of Health (MSDH). The Environmental portion of the Assessment was updated and released in 2009. Our wells were ranked lower in terms of susceptibility to contamination. MSDH conducts an annual compliant site review and we continue to maintain an excellent rating.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

How can I get involved?

See the Conservation Tips for how you can get involved at work as well as at home.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL,</u> <u>TT, or</u> <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Range</u> <u>Low</u> <u>High</u>		<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	1.22	0.72	1.22	2009	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	20	NA		2009	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	58	NA		2009	No	By-product of drinking water disinfection
Inorganic Contaminants								
Barium (ppm)	2	2	0.015	0.014	0.015	2008	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Copper - source water (ppm)		MPL	0.39(MPL)	0.02	0.39	2009	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - source water (ppm)		MPL	0.086(MPL)	0	0.086	2009	No	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride (ppm)	4	4	0.24	0.2	0.24	2008	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Microbiological Contaminants								
Total Coliform (positive samples/month)	0	1	0	NA		2009	No	Naturally present in the environment
Contaminants Exceeding Action Level								
<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your</u> <u>Water</u>	<u>Sample</u> <u>Date</u>	<u># Samples</u> <u>Exceeding AL</u>	<u>Exceeds</u> <u>AL</u>	<u>Typical Source</u>	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	0.2	2009	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	0.004	2009	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
positive samples/month	positive samples/month: Number of samples taken monthly that were found to be positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Jenette B. Gordon
Address:
B1100 Room 3021G
SSC, MS 39529
Phone: 228-688-1416
Fax: 228-688-6699
E-Mail: Jenette.B.Gordon@nasa.gov

National Aeronautics and
Space Administration

2010 JUN 22 PM 1:40

John C. Stennis Space Center
Stennis Space Center, MS 39529-6000



June 21, 2010

Reply to the Attn: **RA02**

Ms. Melissa Parker
Mississippi Department of
Health
Post Office Box 1700
Jackson, MS 39215-1700

Dear Ms. Parker:

The John C. Stennis Space Center (SSC) is submitting the 2009 calendar year Consumer Confidence Report (CCR) for public water system # 0230015. The population for this reporting period was 5,044. This report does not include data for the Mississippi Army Ammunition Plant.

This letter includes a listing of the Environmental Working Group members, which consist of NASA contractors, resident government agencies, resident academia and other specific contact persons who disseminate or post the CCR in their respective areas.

The attachments for this submission are:

Attachment I - A copy of the CY 2009 CCR.

Attachment II- Copy of the e-mail that was forwarded to the listing noted. Information was placed on the SSC Community website that is available to all resident agencies at <http://ssccommunity.ssc.nasa.gov/library.asp>

Attachment III- Certification Form


The CCR Certification shall be forwarded to you under separate cover letter.

The potential areas where the report could be posted are as follows and the asterisk (*) indicates those areas that have accessibility to the SSC internal website:

If you desire to know more about SSC's Water System compliance history, please contact the Mississippi Department of Health representative, Ms. Christi Brantley at (601) 576-7518.

If you have additional questions, please contact Ms. Jenette B. Gordon at (228) 688-1416.

Sincerely,

A handwritten signature in cursive script, appearing to read "Michael J. Blotzer".

for Michael J. Blotzer
Environmental Officer

Enclosure

Working Group Members & Other Contacts	Agency	Building Location
Tripp Boone	U. S. EPA	1105
Carolyn Scott/ Terry Shelby	Naval Oceanographic Office	1000, 1002, 1100, 1005, 1032, 1011, 2406
Lisa Garcia Evan Tillman	United States Geological Survey/HIF	2101
Dennis Mahar	National Data Buoy Center	3202, 3203, 3206
Lou Calehuff	Naval Research Lab	1005, 1007, 1009
Merritt Tuel	University Southern Mississippi	1020
Nelson May Walt Gandy	National Marine Fisheries Service	1103
*Cindy Canady	NASA	1100, 3225, 3226
*Marianne Smith	Pratt-Whitney Rocketdyne	4120, 4220, 4995, 4122, 4301,
*Peter Sciarabba Darryl Miller	Jacobs/FOSC	2109, 8100
*Marcia Stewart	Jacobs/FOSC	2104, 2105, 2119, 2204, 2201, 2205,
*Michael Slade Keith Fulton Bernie Parker	Jacobs/TOC	8201, 8301, 4010, 3305, 3407, 4400
*Lasonya Pulliam Jim Sever Stacy Brunson	Computer Science	1100 (1 st & 2 nd floor), 1105, 1110, 1210, 1201T
*Al Watkins/ Tabatha Butler	AGT	8100, 8110, 9801
*Dr. Lucius Andrews Sue L. Smith	Jacobs/Clinic	8000
*Gary Taylor Alyce Moran	Concessionaires	2124, 2411, 3219, T272
David Everett Johnny Finch	SBT-22	2601, 2602, 2603, 2604, 2605,
Jim Barnett	NSSC	1111
Matthew Martini	NAVSCIATTS	2606
Dona Stewart	Navy/Child Care	2120
Jim Hesse	LMSO/Rolls Royce	5001, 5003, 5005, 5008
Glen Harriel	Lockheed Martin	5100

Gordon, Jenette B. (SSC-RA02)

To: boone.tripp@epa.gov; Lisa A Garcia; Merritt Tuel; Dennis Mahar; 'Calehuff, Lou'; Shelby, Terry D CIV N62306; Smith, Marianne (SSC-PWR)[PRATT WHITNEY ROCKETDYNE]; Stewart, Marcia L. (SSC-JACOBS)[JACOBS TECHNOLOGY INC (SSC FOSC)]; Sciarabba, Peter J. (SSC-JACOBS)[Jacobs]; Smith, Sue L. (SSC-JACOBS)[COMPREHENSIVE OCCUPATIONAL RESOURCES]; Andrews, Lucius C. (SSC-JACOBS)[COMPREHENSIVE OCCUPATIONAL RESOURCES]; Everett David L CIV USSOCOM NSWSBT22; Pulliam, Lasonya D. (SSC-ARTS)[ASRC Research & Technology Solutions LLC (SSC)]; Taylor, Gary O. (SSC-PA50); dona.scdc@yahoo.com; Slade, Michael E. (SSC-JACOBS)[ERC/JT]; Watkins, Al E. (SSC-A2R)[A2Research (SSC)]; Hesse, James A; Barnett, James C. (NSSC-XB000); Finch Johnny S Mr CIV USSOCOM NSWSBT22; Martini Matthew D CPO USSOCOM NAVSCIATTS; Glen.A.Harriel@lmco.com; Canady, Cynthia P. (SSC-PA20); Hey, Brian M. (SSC-AA00); Nelson.May@noaa.gov

Cc: Miller, Daryl W. (SSC-JACOBS)[Jacobs Technology]; Moran, Alyce L. (SSC-NASA)[Exchange Store]; Fulton, Keith B. (SSC-JACOBS)[ENGINEER RESOURCES COMPANY]; Parker, Bernie D. (SSC-JACOBS)[Jacobs Technology]; Sever, James (SSC-ARTS)[ASRC Research & Technology Solutions LLC (SSC)]; Brunson, Stacy E. (SSC-ARTS)[ASRC Research & Technology Solutions LLC (SSC)]; Butler, Tabatha (SSC-A2R)[A2Research (SSC)]; carolyn.j.scott@navy.mil; Les Gray; Fendley, Susan E. (SSC-JACOBS)[ENGINEER RESOURCES COMPANY]; Majors, Sharlene R. (SSC-A2R)[A2Research (SSC)]; Walt.Gandy@noaa.gov

Subject: 2009 Consumer Confidence Report

Attachments: 1Consumer Confidence Report 0610.doc

The attached Consumer Confidence Report (CCR) for the SSC drinking water is being sent to each of you to post in your respective areas in accordance with Subpart O of 40 CFR 141.155/National Primary Drinking Water regulations. This report does not include the Mississippi Army Ammunition Plant. Again, the SSC water system has not violated any water quality standards, which means we continue to provide good quality water to the SSC personnel. This information shall be placed on the SSC Intranet Portal.

A hard copy of this report is being sent to the Mississippi Department of Health.

If you have any questions, please give me a call.

Sincerely,

Jenette

Jenette B. Gordon
Environmental Management Staff
B1100 Room 3017F
SSC, MS 39529-6000
Phone: (228) 688-1416
FAX: (228) 688-6699

'We do not inherit the earth from our ancestors, we borrow it from our children.'
-- Native American Proverb

Gordon, Jenette B. (SSC-RA02)

From: SSC-Public Affairs Office
Sent: Friday, June 18, 2010 11:53 AM
Subject: 2009 Consumer Confidence Report
Attachments: 1Consumer Confidence Report 0610.doc

Attached is the Consumer Confidence Report (CCR) for the drinking water at Stennis Space Center. This report does not include the Mississippi Army Ammunition Plant. The SSC water system has not violated any water quality standards, which means good quality water continues to be provided to SSC personnel.

Gordon, Jenette B. (SSC-RA02)

From: Foerman, Paul (SSC-IA10)
Sent: Friday, June 18, 2010 11:48 AM
To: Gordon, Jenette B. (SSC-RA02)
Subject: RE: 2009 Consumer Confidence Report

Thanks. The email will be sent out soon.

Paul Foerman
NASA Public Affairs
Stennis Space Center, MS
Phone: 228-688-1880

Learn more about NASA at: <http://www.nasa.gov>

From: Gordon, Jenette B. (SSC-RA02)
Sent: Friday, June 18, 2010 11:47 AM
To: Foerman, Paul (SSC-IA10)
Subject: RE: 2009 Consumer Confidence Report

Paul,

Yes, that is fine.

Thanks,

Jenette

From: Foerman, Paul (SSC-IA10)
Sent: Friday, June 18, 2010 11:27 AM
To: Gordon, Jenette B. (SSC-RA02)
Subject: RE: 2009 Consumer Confidence Report

Jenette,

For the site-wide distribution, is the following acceptable to go along with the attachment?

Attached is the Consumer Confidence Report (CCR) for the SSC drinking water. This report does not include the Mississippi Army Ammunition Plant. The SSC water system has not violated any water quality standards, which means we continue to provide good quality water to the SSC personnel.

Paul Foerman
NASA Public Affairs
Stennis Space Center, MS
Phone: 228-688-1880

Learn more about NASA at: <http://www.nasa.gov>

From: Gordon, Jenette B. (SSC-RA02)
Sent: Friday, June 18, 2010 11:11 AM
To: Femal, Mark E. (SSC-RA40); Foerman, Paul (SSC-IA10)
Subject: FW: 2009 Consumer Confidence Report

Mark and Paul,

I need your assistance in placing the attached document on the internet and intranet Community Bulletin Boards. If you have any questions please let me know. Paul, can you send this out in an electronic global broadcast to all of the SSC personnel (inclusive of tenants and or concessionaires). Call me @ 81416 if you have questions.

Thanks,

Jenette

From: Gordon, Jenette B. (SSC-RA02)
Sent: Friday, June 18, 2010 11:00 AM
To: boone.tripp@epa.gov; Lisa A Garcia; Merritt Tuel; Dennis Mahar; 'Calehuff, Lou'; Shelby, Terry D CIV N62306; marianne.smith@pwr.utc.com; Stewart, Marcia L. (SSC-JACOBS)[JACOBS TECHNOLOGY INC (SSC FOSC)]; Sciarabba, Peter J. (SSC-JACOBS)[Jacobs]; Smith, Sue L. (SSC-JACOBS)[COMPREHENSIVE OCCUPATIONAL RESOURCES]; Andrews, Lucius C. (SSC-JACOBS)[COMPREHENSIVE OCCUPATIONAL RESOURCES]; 'Everett David L CIV USSOCOM NSWSBT22'; Pulliam, Lasonya D. (SSC-ARTS)[ASRC Research & Technology Solutions LLC (SSC)]; Taylor, Gary O. (SSC-PA50); 'dona.scdc@yahoo.com'; Slade, Michael E. (SSC-JACOBS)[ERC/JT]; Watkins, Al E. (SSC-A2R)[A2Research (SSC)]; Hesse, James A; Barnett, James C. (NSSC-XB000); Finch Johnny S Mr CIV USSOCOM NSWSBT22; Martini Matthew D CPO USSOCOM NAVSCIATTS; 'Glen.A.Harriel@lmco.com'; Canady, Cynthia P. (SSC-PA20); Hey, Brian M. (SSC-AA00); 'Nelson.May@noaa.gov'
Cc: Miller, Daryl W. (SSC-JACOBS)[Jacobs Technology]; Moran, Alyce L. (SSC-NASA)[Exchange Store]; Fulton, Keith B. (SSC-JACOBS)[ENGINEER RESOURCES COMPANY]; Parker, Bernie D. (SSC-JACOBS)[Jacobs Technology]; Sever, James (SSC-ARTS)[ASRC Research & Technology Solutions LLC (SSC)]; Brunson, Stacy E. (SSC-ARTS)[ASRC Research & Technology Solutions LLC (SSC)]; Butler, Tabatha (SSC-A2R)[A2Research (SSC)]; carolyn.j.scott@navy.mil; Les Gray; Fendley, Susan E. (SSC-JACOBS)[ENGINEER RESOURCES COMPANY]; Majors, Sharlene R. (SSC-A2R)[A2Research (SSC)]; 'Walt.Gandy@noaa.gov'
Subject: 2009 Consumer Confidence Report

The attached Consumer Confidence Report (CCR) for the SSC drinking water is being sent to each of you to post in your respective areas in accordance with Subpart O of 40 CFR 141.155/National Primary Drinking Water regulations. This report does not include the Mississippi Army Ammunition Plant. Again, the SSC water system has not violated any water quality standards, which means we continue to provide good quality water to the SSC personnel. This information shall be placed on the SSC Intranet Portal.

A hard copy of this report is being sent to the Mississippi Department of Health.

If you have any questions, please give me a call.

Sincerely,

Jenette

Jenette B. Gordon
Environmental Management Staff
B1100 Room 3017F
SSC, MS 39529-6000
Phone: (228) 688-1416
FAX: (228) 688-6699