

2010 JUN 29 AM 8:56

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2009 CONSUMER CONFIDENCE REPORT
CERTIFICATION REPORT

SOUTH TERRY WATER ASSOCIATION
PWS ID # ('s):0250023

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill, or other)*

- Advertisement in local paper *5/27/10*
- On water bills *6/24/10*
- Other _____

Date customers were informed: _____

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date mailed/distributed: _____

CCR was published in local newspaper. *(Attach copy of published CCR and proof of publication)*

Name of Newspaper: *Hinds Co. Gazette*
Date Published: *5/27/10*

CCR was posted in public places. *(Attach list of locations)*

Date posted: _____

CCR was posted on a publicly accessible internet site at the address: www: _____

CERTIFICATION:

I hereby certify that a Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Sylvia McDawid

Name/Title *(President, Mayor, Owner, etc.)*
Office manager

6/28/10

Date

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Wesley Boyett

Signature

5/18/10

Date

Annual Drinking Water Quality Report
 South Terry Water Association
 PWS ID # 0250023
 May, 2010

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells that draw from the Forest Hill and Sparta Sand Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. A report containing detailed information has been received by our office and will be made available for review upon request. The water supply for South Terry Water Association received a low susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Sylvia McDavid at 601-878-5308. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday every 3 (three) months at 2428 Old Hwy 51 in Terry, MS at 7:00 pm.

South Terry Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2009. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2008*	0.009	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2008*	1	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2008*	0.3	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2008*	0.5	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	2	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Volatile Organic Contaminants								
56. Carbon tetrachloride	N		0.5	None	ppb	0	5	Discharge from chemical plants and other industrial activities
76. Xylenes	N		0.6	None	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
Disinfectants & Disinfection By-Products								
Chlorine (as Cl ₂)	N		0.84 to 0.95	None	ppm	4	4	Water additive used to control microbes
73. TTHM [Total trihalomethanes]	N		0.062 to 0.071	None	ppb	0	80	By-product of drinking water chlorination
HAA5	N		0.058 to 0.082	None	ppb	0	60	By-product of drinking water chlorination

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. South Terry Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

STATE OF MISSISSIPPI)
)
COUNTY OF HINDS)

PERSONALLY CAME before me, a notary public in and for the State of Mississippi at Large, the CLERK of the *HINDS COUNTY GAZETTE*, a newspaper published in the City of Raymond, Second Judicial District of Hinds County, in said state, who being duly sworn, deposes and says that the *HINDS COUNTY GAZETTE* is a newspaper as defined and prescribed in the Mississippi Code of 1972, and the publication of a notice of which the annexed is a copy, in the matter of:

Annual Drinking Water Quality Report
South Jersey Water Association
PWS ID# 0250023

Has been made in said paper 1 times consecutively, to-wit:

On the 27 day of May, 2010
On the _____ day of _____, 2010
On the _____ day of _____, 2010
On the _____ day of _____, 2010

SWORN TO and SUBSCRIBED before me, this

27 day of May, 2010

Mary Ann Keith
Notary Public

Heather Rupton
Clerk



TO PUBLISH _____
_____ HINDS COUNTY GAZETTE Dr.

Case of _____

Word space _____ Weeks _____ Proof Charge \$3.00 - Total \$ _____

RECEIVED OF _____

Check No. _____ Date _____

Annual Drinking Water Quality Report
South Terry Water Association
 PWS ID # 0250023
 May, 2010

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells that draw from the Forest Hill and Sparta Sand Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. A report containing detailed information has been received by our office and will be made available for review upon request. The water supply for South Terry Water Association received a low susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Sylvia McDavid at 601-878-5308. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday every 3 (three) months at 2428 Old Hwy 51 in Terry, MS at 7:00 pm.

South Terry Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2009. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2008*	0.009	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2008*	1	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14.
16.
17.1
Vo
56. (tetra
76.)
Dis
Chlo
73. 1 triha
HAA

* Mos
Addi
 If pre
 Lead
 South
 mater
 poten
 you a
 testin
 http://
 testin.
 All sc
 made.
 includ
 of cor
 poten!
 1-800

Some comp
 transp
 from i
 guidel
 are av.
 Please

Copper	N	2008*	0.3	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride	N	2008*	0.5	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead	N	2008*	2	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Latile Organic Contaminants								
Carbon chloride	N		0.5	None	ppb	0	5	Discharge from chemical plants and other industrial activities
Cylenes	N		0.6	None	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
infectants & Disinfection By-Products								
rine (as Cl2)	N		0.84 to 0.95	None	ppm	4	4	Water additive used to control microbes
THM [Total omethanes]	N		0.062 to 0.071	None	ppb	0	80	By-product of drinking water chlorination
5	N		0.058 to 0.082	None	ppb	0	60	By-product of drinking water chlorination

† recent sample results available

Additional Information for Lead

sent, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. in drinking water is primarily from materials and components associated with service lines and home plumbing. Terry Water Association is responsible for providing high quality drinking water, but cannot control the variety of ials used in plumbing components. When your water has been sitting for several hours, you can minimize the tial for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If re concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, g methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at /www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead g for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

ources of drinking water are subject to potential contamination by substances that are naturally occurring or man. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, ling bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence taminants does not necessarily indicate that the water poses a health risk. More information about contaminants and ial health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at -426-4791.

people may be more vulnerable to contaminants in drinking water than the general population. Immuno- omised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ lants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk nfections. These people should seek advice about drinking water from their health care providers. EPA/CDC ines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants ailable from the Safe Drinking Water Hotline (800-426-4791).

call our office if you have questions.

ARE
phone
-6461

56

59"

South Terry Water Assoc.
 POBox 298, Terry MS 39170
 Bills & Accounts 878-5308,

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	313000	310000	3,000	21.75

2428 OLD HWY 51
 IF PASTDUE 60 DAYS DUE FOR CUTOFF

ACCOUNT 107 6/23/10

METER READ		CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
MONTH	DAY				
6	20	1	21.75	2.18	23.93

STWA's ANNUAL MEMBERSHIP MEETING WILL BE HELD
 SEPT 9, 2010 AT 7:00 pm AT THE COMMUNITY CENTER IN TERRY,
 COPIES OF THE 2010 CCR REPORT AND THE 2011 BUDGET
 ARE AVAILABLE ON REQUEST AT 2428 OLD HWY 51 TERRY, MS.