



RECEIVED-WATER SUPPLY
2010 JUL -1 AM 10:34

MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2009 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

North Hinds Water Assn.
Public Water Supply Name

0250029
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: ___/___/___

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 6/30/10

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: ___/___/___

- CCR was posted in public places. *(Attach list of locations)*

Date Posted: ___/___/___

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Doug Barker
Doug Barker / Manager
Name/Title (President, Mayor, Owner, etc.)

6/30/10
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2009 Chapel Hill CCR; 05/18/2010: 0250029

Is my water safe?

In 2009, as in years past, North Hinds Water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Well #1 Draws from the Cockfield Aquifer.

Well #2 Draws from the Sparta Aquifer.

Source water assessment is available on the MSDEQ web site.

Well #1 (Moderate)

Well #2 (Lower)

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Please contact our office with any comments or questions you may have.

Maximum Residual Disinfectant Level Report.

During the monitoring period the MCL was not exceeded.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. North Hinds Water Assn is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants	MCLG	MCL,	Your	Range		Sample	Violation	Typical Source
	or	TT, or		Low	High			
	MRDLG	MRDL	Water			Date		
Disinfectants & Disinfectant By-Products								
There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	0.95	NA		2009	No	Water additive used to control microbes
THMs [Total Trihalomethanes] (ppb)	NA	80	50	NA		2008	No	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	NA	60	25	NA		2008	No	By-product of drinking water chlorination
Inorganic Contaminants								

Notice

Water Fluoridation

In June 2010, North Hinds Water Assn., Inc., began adding fluoride to its treated water supply. This is being done based on recommendations from the Mississippi State Department of Health, the U.S. Centers of Disease Control and Prevention, and the American Dental Association. North Hinds Water now joins more than 64 communities across the State of Mississippi that have fluoridated water supplies.

You will not notice a change in the taste, smell or appearance of your water. Water fluoridation is not a new concept. Cities across the nation have been adding fluoride to their water supplies for decades. In addition, many cities in Mississippi have recently joined the long list of communities benefiting from water fluoridation.

Fluoride FAQ

Your water supply & fluoride

Water delivered by North Hinds Water to our customers will remain below the regulated dosage of 1.3 parts per million (ppm) with an optimal level of 0.7 ppm. This follows the recommendations of the Mississippi State Department of Health, the U.S. Centers of Disease Control and Prevention, and the American Dental Association. Fluoride levels in drinking water are limited under Mississippi state regulations at a maximum dosage of 1.3 parts per million (ppm).

Benefits of fluoridated water

According to extensive research conducted over the past 50 years, water fluoridation is safe and healthy. Water fluoridation is the single, most cost-effective public health measure to prevent tooth decay and improve oral health.

Drinking fluoridated water, as part of your diet, will provide about 60 percent of the protection necessary to fight against cavities. Fluoride works to strengthen tooth enamel so teeth become more resistant to decay, and it reverses newly formed cavities. This is a particular advantage for children. Fluoride also prevents cavities in the root surfaces of teeth for older adults when their gums start to recede.

Fluoridated water and fluoride supplements

Drinking fluoridated water on a regular basis makes the use of fluoride tablets or drops unnecessary. However, the continued use of fluoride treatments by professional dental caregivers is recommended. Drinking fluoridated water should be part of a total treatment plan for healthy gums and teeth, combined with brushing and flossing your teeth regularly and using less sugar in your diet. Customers who do not wish to drink fluoridated water should know that most bottled waters contain levels of fluoride below the optimum range.

If you have any questions or concerns, please call North Hinds Water Assn., Inc. at 601-981-1657 between the hours of 8:00-12:00 and 1:00-5:00 Monday through Friday.

Nitrate [measured as Nitrogen] (ppm)	10	10	0.2	NA		2009	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.05	NA		2009	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	10	NA		2008	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Antimony (ppb)	6	6	0.5	NA		2008	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; pest addition.
Arsenic (ppb)	10	10	0.5	NA		2008	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.004046	NA		2008	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	4	4	0.1	NA		2008	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	0.1	NA		2008	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	0.5	NA		2008	No	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	4	4	0.2185	NA		2008	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury [Inorganic] (ppb)	2	2	0.2	NA		2008	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Selenium (ppb)	50	50	0.5	NA		2008	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	NA		2008	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
Volatile Organic Contaminants								
1,2,4-Trichlorobenzene (ppb)	70	70	0.5	NA		2008	No	Discharge from textile-finishing factories
cis-1,2-Dichloroethylene (ppb)	70	70	0.5	NA		2008	No	Discharge from industrial chemical factories
Xylenes (ppm)	10	10	0.0005	NA		2008	No	Discharge from petroleum factories; Discharge from chemical factories
Dichloromethane (ppb)	0	5	0.5	NA		2008	No	Discharge from pharmaceutical and chemical factories
o-Dichlorobenzene (ppb)	600	600	0.5	NA		2008	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	NA		2008	No	Discharge from industrial chemical factories
Vinyl Chloride (ppb)	0	2	0.5	NA		2008	No	Leaching from PVC piping; Discharge from plastics factories
1,1-Dichloroethylene (ppb)	7	7	0.5	NA		2008	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	NA		2008	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	0	5	0.5	NA		2008	No	Discharge from industrial chemical factories
1,1,1-Trichloroethane (ppb)	200	200	0.5	NA		2008	No	Discharge from metal degreasing sites and other factories
Carbon Tetrachloride (ppb)	0	5	0.5	NA		2008	No	Discharge from chemical plants and other industrial activities
1,2-Dichloropropane (ppb)	0	5	0.5	NA		2008	No	Discharge from industrial chemical factories

Trichloroethylene (ppb)	0	5	0.5	NA	2008	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	0.5	NA	2008	No	Discharge from industrial chemical factories
Tetrachloroethylene (ppb)	0	5	0.5	NA	2008	No	Discharge from factories and dry cleaners
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	NA	2008	No	Discharge from chemical and agricultural chemical factories
Benzene (ppb)	0	5	0.5	NA	2008	No	Discharge from factories; Leaching from gas storage tanks and landfills
Toluene (ppm)	1	1	0.5	NA	2008	No	Discharge from petroleum factories
Ethylbenzene (ppb)	700	700	0.5	NA	2008	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	0.5	NA	2008	No	Discharge from rubber and plastic factories; Leaching from landfills

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
--------------	------	----	------------	-------------	------------------------	------------	----------------

Inorganic Contaminants							
Lead - action level at consumer taps (ppb)	0	15	2	2008	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Copper - action level at consumer taps (ppm)	1.3	1.3	0.7	2008	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Jeff Jones
Address:
P.O. Drawer 300
Flora, MS 39071
Phone: 601-981-1657
Fax: 601-982-2871

Flora
Flora, Mississippi
390719998
2737860071 -0098
06/30/2010 (601)879-3101 11:17:50 AM

Product Description	Sales Receipt		Final Price
	Sale Qty	Unit Price	

Permit Type: Permit Imprint
Permit Number: 6
Customer Name: NORTH HINDS WATER
ASSN.

Amount of Deposit: \$632.86
New Balance: \$632.86
Confirmation #: 201018111162159D

Permit Type: Permit Imprint
Permit Number: 6
Customer Name: NORTH HINDS WATER
ASSN.

Amount of Deposit: \$1,204.19
New Balance: \$1,837.05
Confirmation #: 201018111165468D

Total: \$1,837.05

Paid by:
Personal Check \$632.86
Personal Check \$1,204.19

Order stamps at USPS.com/shop or call
1-800-Stamp24. Go to USPS.com/clicknship
to print shipping labels with postage.
For other information call 1-800-ASK-USPS.