

2010 MAY 21 AM 8:41



MISSISSIPPI STATE DEPARTMENT OF HEALTH

**BUREAU OF PUBLIC WATER SUPPLY**

**CALENDAR YEAR 2009 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM**

City of Nettleton  
Public Water Supply Name

0410008  
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

**Please Answer the Following Questions Regarding the Consumer Confidence Report**

Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)

- Advertisement in local paper  
 On water bills  
 Other \_\_\_\_\_

Date customers were informed: 5/19/10

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed:  / /

CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: Lee County Courier

Date Published: 5/21/10

CCR was posted in public places. (*Attach list of locations*)

Date Posted: 5/19/10 city hall

CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

[Signature]  
Name/Title (President, Mayor, Owner, etc.)

5-19-10  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

5/21/10

**Annual Drinking Water Quality Report**  
**City of Nettleton**  
**PWS ID: 0410008**  
**May 19, 2010**

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is groundwater and our well's draw from the McShand Formation.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are moderate susceptibility to contamination and is available for viewing upon request.

I'm pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Randy Parchman at (662)-963-2605. We want our valued customers to be informed about their water utility. If you want to learn more, please attend one of our regular meetings held at 6:30 P.M on the first Monday of each month at the City Hall.

The City of Nettleton routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2009. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MRDL**: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

## TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl <sub>2</sub> ) (ppm)	N	2009	.49	.47-.49	Ppm	4	4	Water additive used to control microbes
<b>Inorganic Contaminants</b>								
Barium	N	2009	.181	.169-.181	Ppm	2	2	Discharge of drilling wastes discharge from metal refineries erosion of natural deposits
Chromium	N	2009	.61	.53-.61	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper	N	*2007	.354	.027 - .354	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead	N	*2007	1.0	0 – 1.0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

\*Most recent sample. No sample was required in 2009

### \*\*\*Additional Information for Lead\*\*\*

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Nettleton is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

We ask that all our customers help us protect our water sources, which are the heart of our community.


**KIRK LINDSEY**  
*Alderman at Large*

**CHARLES MORRIS**  
*Alderman Ward 1*

**DOUG BROWN**  
*Alderman Ward 2*

**WILLIE BRANDON, JR.**  
*Alderman Ward 3*

**LARRY GUESS**  
*Alderman Ward 4*



**RICKY PAYNE**  
*Chief of Police*

**BILL TAPSCOTT**  
*City Clerk*

**DANA GRUBBS**  
*Court Clerk*

**MICHAEL MALSKI**  
*City Judge*

**GARY CARNATHAN**  
*City Attorney*

## **CITY OF NETTLETON**

**R. V. ADAMS**  
*Mayor*

May 19, 2010

Mississippi State Department of Health  
Division of Water Supply  
Post Office Box 1700  
Jackson, MS 39215

RE: 2009 Consumer Confidence Report for the City of Nettleton PWS - 41-008

To Whom It May Concern:

Please find the enclosed 2009 Consumer Confidence Report for the City of Nettleton. This report was published in the Lee County Courier having general circulation in the City of Nettleton and posted on the bulletin board in the Nettleton City Hall.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in cursive script, appearing to read 'R.V. Adams'.

R.V. Adams, Mayor  
City of Nettleton