

RECEIVED-WATER SUPT.
2010 JUN 28 AM 10:12



MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2009 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

City of Madison
Public Water Supply Name

450010
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper
- On water bills
- Other by mail

Date customers were informed: 6/26/10

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 6/25/10

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: / /

CCR was posted in public places. *(Attach list of locations)* Madison Public Service Complex

Date Posted: 6/25/10 Madison City Hall

CCR was posted on a publicly accessible internet site at the address: www.madisonthecity.com/publicworks/index.html

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Mary Hawkins Butler
Name/Title (President, Mayor, Owner, etc.)

6-25-10
Date

**Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518**

0450010

City of Madison Water Quality Report 2009

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

We have four deep ground water wells. Two are in the Cockfield Aquifer and two are in the Sparta Aquifer.

Source water assessment and its availability

The Mississippi Source Water Assessment Program is a result of the Federal Safe Drinking Water Act 1996 which mandated all states to identify public water systems that may be susceptible to contamination and adopt appropriate management measures that will enhance their protection. More information is available at www.deq.state.ms.us

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure

that tap water is safe to drink; EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Attend any regularly scheduled meeting of the Mayor and Board of Alderman held at the Madison Justice Complex on Crawford Street at 6 p.m. on the first and third Tuesday of each month.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.

- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people “Dump No Waste - Drains to River” or “Protect Your Water.” Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Madison the City is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
THMs [Total Trihalomethanes] (ppb)	NA	80	11	NA		2009	No	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	NA	60	5	NA		2009	No	By-product of drinking water chlorination
Chlorine (as Cl ₂) (ppm)	4	4	0.49	0.24	2.09	2009	No	Water additive used to control microbes
Inorganic Contaminants								
Nitrite [measured as Nitrogen] (ppm)	1	1	≤ 0.2	≤ 0.2	0.2	2009	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrate [measured as Nitrogen] (ppm)	10	10	≤ .05	≤ .05	0.05	2009	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Volatile Organic Contaminants								
1,2,4-Trichlorobenzene (ppb)	70	70	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from textile-finishing factories

cis-1,2-Dichloroethylene (ppb)	70	70	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from industrial chemical factories
Xylenes (ppb)	10	10	≤ 0.5	≤ 0.5	2.24	2009	No	Discharge from petroleum factories; Discharge from chemical factories
Dichloromethane (ppb)	0	5	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from pharmaceutical and chemical factories
o-Dichlorobenzene (ppb)	600	600	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from industrial chemical factories
Vinyl Chloride (ppb)	0	2	≤ 0.5	≤ 0.5	0.5	2009	No	Leaching from PVC piping; Discharge from plastics factories
1,1-Dichloroethylene (ppb)	7	7	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	0	5	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from industrial chemical factories
1,1,1-Trichloroethane (ppb)	200	200	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from metal degreasing sites and other factories
Carbon Tetrachloride (ppb)	0	5	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from chemical plants and other industrial activities
1,2-Dichloropropane (ppb)	0	5	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from industrial chemical factories
Tetrachloroethylene (ppb)	0	5	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from factories and dry cleaners
Benzene (ppb)	0	5	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from factories; Leaching from gas storage tanks and landfills
Toluene (ppb)	1	1	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from petroleum factories
Ethylbenzene (ppb)	700	700	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	≤ 0.5	≤ 0.5	0.5	2009	No	Discharge from rubber and plastic factories; Leaching from landfills
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	0.4	2007	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	1	2007	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Additional Contaminants

In an effort to insure the safest water possible the State has required us to monitor some contaminants not required by Federal regulations. Of those contaminants only the ones listed below were found in your water

<u>Contaminants</u>	<u>State MCL</u>	<u>Your Water</u>	<u>Violation</u>	<u>Explanation and Comment</u>
monochlorobezene	100 ppb	0.5 ppb	No	

Additional Monitoring

As part of an on-going evaluation program the EPA has required us to monitor some additional contaminants/chemicals. Information collected through the monitoring of these contaminants/chemicals will help to ensure that future decisions on drinking water standards are based on sound science.

<u>Name</u>	<u>Reported Level</u>	<u>Range</u>	
		<u>Low</u>	<u>High</u>
1,3-dinitrobenzene (ppb)	≤ 0.8	≤ 0.8	0.8
Hexahydro-1,3,5-trinitro-1,3,5-triazine (RDX) (ppb)	≤ 1	≤ 1	1
2,4,6-trinitrotoluene (TNT) (ppb)	≤ 0.8	≤ 0.8	0.8
2,2',4,4',5,5'-hexabromobiphenyl (HBB) (ppb)	≤ 0.7	≤ 0.7	0.7
2,2',4,4',6-pentabromodiphenyl ether (BDE-100) (ppb)	≤ 0.5	≤ 0.5	0.5
2,2',4,4',5,5'-hexabromodiphenyl ether (BDE-153) (ppb)	≤ 0.8	≤ 0.8	0.8
2,2',4,4'-tetrabromodiphenyl ether (BDE-47) (ppb)	≤ 0.3	≤ 0.3	0.3
2,2',4,4',5-pentabromodiphenyl ether (BDE-99) (ppb)	≤ 0.9	≤ 0.9	0.9
Dimethoate (ppb)	≤ 0.7	≤ 0.7	0.7
Terbufos sulfone (ppb)	≤ 0.4	≤ 0.4	0.4

<u>Unit Descriptions</u>	
<u>Term</u>	<u>Definition</u>
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

<u>Important Drinking Water Definitions</u>	
<u>Term</u>	<u>Definition</u>
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Madison Public Works Department
1239 Highway 51
Madison, MS 39110-9092
Phone: 601-856-8958
Fax: 601-856-8996
E-Mail: publicworks@madisonthecity.com
Website: www.madisonthecity.com

City of Madison Water Quality Report 2009

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The City of Madison vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

We have four deep ground water wells. Two are in the Cockfield Aquifer and two are in the Sparta Aquifer.

Source water assessment and its availability

The Mississippi Source Water Assessment Program is a result of the Federal Safe Drinking Water Act 1996 which mandated all states to identify public water systems that may be susceptible to contamination and adopt appropriate management measures that will enhance their protection. More information is available at www.deq.state.ms.us

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink; EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Attend any regularly scheduled meeting of the Mayor and Board of Alderman held at the Madison Justice Complex on Crawford Street at 6 p.m. on the first and third Tuesday of each month.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants	MCLG	MCL,	Your	Range		Sample	Violation	Typical Source
	or	TT, or		Water	Low			
	MRDLG	MRDL						
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
TTHMs [Total Trihalomethanes] (ppb)	NA	80	11	NA		2009	No	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	NA	60	5	NA		2009	No	By-product of drinking water chlorination
Chlorine (as Cl ₂) (ppm)	4	4	0.49	0.24	2.09	2009	No	Water additive used to control microbes
Contaminants	MCLG	AL	Your	Sample	# Samples	Exceeds	Typical Source	
			Water	Date	Exceeding AL	AL		
Inorganic Compounds								
Copper - action level at consumer taps (ppb)	1.3	1.3	0.3555	2007	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	.0014	2007	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Volatile Contaminants								
Xylenes (ppb)	10	10	2.24	2009	0	No	Discharge from petroleum factories; Discharge from chemical factories	

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: Not Applicable
ND	ND: Not Detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public sewer system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Madison the City is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum Residual Disinfection Level Goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum Residual Disinfectant Level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Madison Public Works Department
1239 Highway 51
Madison, MS 39110-9092
Phone: 601-856-8958
Fax: 601-856-8996
E-Mail: publicworks@madisonthecity.com
Website: www.madisonthecity.com

City of Madison Water Quality Report 2009

Madison Public Works Department
1239 Highway 51
Madison, MS 39110-9092

PRSR STD U.S. POSTAGE PAID MADISON, MS PERMIT NO. 23
--

RECEIVED - WATER SUPPLY
2010 JUN 28 AM 10:12

Post Office: Note Mail Arrival
 Date & Time (Do not Round Stamp)

2:50 PM 6/25/10

Mailer:

Entry Point: (1) Jackson PO, Jackson, MS 39201-9997
 Presort: ALL

88372 : STD REG Auto LETTERS (PERMIT)
 City of Madison
 Water Quality report

2009 Water Quality Report

Permit Holder's Name and Address and Email Address, If Any City of Madison City of Madison P.O. BOX 40 Madison, MS 39130 CAPS Cust. Ref. No. Customer No.	Telephone 601-898-8700	Name and Address of Mailing Agent (If other than permit holder) SOURCELINK MADISON LLC 5 OLYMPIC WAY MADISON MS 39110	Telephone 601-898-8700	Name and Address of Individual or Organization for Which Mailing is Prepared (if other than permit holder)
		Customer No. 362061269		Customer No.

Mailing

Post Office of Mailing Jackson MS 39205	Mailing Date 6-22-10	Fed Agency Cost Code	Statement Sequence No. 0001 to 0002	No. and Type of Containers
Type of Postage [X] Permit Imprint [] Precanceled Stamps [] Metered	Processing Category [X] Letters [] CMM [] Flats [] NFM [] Parcels-Machinable [] Parcels-Irregular [] Letters-Paid as Nonauto Flats [] CR Letters-Paid as CR Flats	If Sacked, Based on [] 125 pcs [] 15 lbs. [] both	Total Pieces 4806 Total Weight 134.5680	0 -Sacks 0 -1' Ltr Trays 8 -2' Ltr Trays 0 -EMM Ltr Trays 8 -TTL Ltr Trays 0 -Flat Trays 0 -Pallets 0 -Other
Permit No. 23		Weight of a Single Piece	0.0280 pounds	

For Mail Enclosed within Another Class [] Periodicals [] Bound Printed Matter [] Library Mail [] Media Mail [] Parcel Post

For Automation Pieces, Enter Date of Address Matching and Coding: 6/22/10
 For Carrier Route Pieces, Enter Date of Address Matching and Coding: 6/22/10
 For Carrier Route Pieces, Enter Date of Carrier Route Sequencing: 6/22/10

For pieces bearing a simplified address enter date of delivery statistics file or alternative method / /

Move Update method: [] Ancillary Service Endorsement [] FASTforward [X] NCOA Link [] ACS [] Alternative method [] Multiple [] n/a Alternative Address Format [] OneCode ACS

Postage

Parts Completed (Select all that apply) [X] A [] B [] C [X] D [] E [] F [] G [] H [] I [] J [] K [] L [] S	Total Postage (Add parts totals)	\$ 921.72
Price at Which Postage Affixed (Check one) [] Correct [] Lowest [] Neither Complete if the mailing includes pieces bearing metered or precanceled stamps.	pcs. x \$ = Postage Affixed	\$
Net Postage Due (Subtract postage affixed from total postage)	\$	921.7190

USPS Use Only

Additional Postage Payment (State reason)	\$
For postage affixed add additional payment to net postage due; for permit imprint add additional payment to total postage.	Total Adjusted Postage Affixed \$
Postmaster: Report Total Postage in AIC 130 (Permit Imprint only)	Total Adjusted Postage Permit Imprint \$

Certification


The mailer's signature certifies acceptance of liability for and agreement to pay any revenue deficiencies assessed on this mailing, subject to appeal. If an agent signs this form, the agent certifies that he or she is authorized to sign on behalf of the mailer and that the mailer is bound by the certification and agrees to pay any deficiencies. In addition, agents may be liable for any deficiencies resulting from matters within their responsibility, knowledge, or control. The mailer hereby certifies that all information furnished on this form is accurate, truthful, and complete; that the mail and the supporting documentation comply with all postal standards and that the mailing qualifies for the prices and fees claimed; and that the mailing does not contain any matter prohibited by law or postal regulation. I understand that anyone who furnishes false or misleading information on this form or who omits information requested on this form may be subject to criminal and/or civil penalties, including fines and imprisonment. Privacy Notice: For information regarding our Privacy Policy visit www.usps.com

Signature of Mailer or Agent: *W. Holliday* Printed Name of Mailer or Agent Signing Form: *W. Holliday* Telephone: *701-898-8800*

USPS Use Only - To be completed in non-PostalOne! sites

Weight of a Single Piece 0.0275 pound	Are postage figures at left adjusted from mailer's entries? If yes, reason:	[] Yes [] No
Total Pieces 4810	Total Weight 132.425	
Total Postage 921.72		

Round Stamp (Required)
Date Mail Released



Presort Verification Performed? (check one) [] Yes [] No Date Mailer Notified Contact By (Initials)

I CERTIFY that this mailing has been inspected concerning: (1) eligibility for postage prices claimed; (2) proper preparation; (and presort where required); (3) proper completion of postage statement; (4) payment of annual fee; and (5) sufficient funds on deposit (if required).

USPS Employee's Signature: *Marshall Littleton* Print USPS Employee's Name: *Marshall Littleton* Time: *3:00* AM/PM: *PM*

Part A - Automation Letters Check box at left if prices are populated in this section.

Letters 3.3 oz. (0.2063 lbs.) or Less						
Entry	Price Category	Price		No. of Pieces	=	Total Postage
A1	None 5-Digit	0.233	x		=	\$
A2	None 3-Digit	0.251	x		=	\$
A3	None AADC	0.253	x		=	\$
A4	None Mixed AADC	0.270	x		=	\$
A5	DNDC 5-Digit	0.199	x		=	\$
A6	DNDC 3-Digit	0.217	x		=	\$
A7	DNDC AADC	0.219	x		=	\$
A8	DNDC Mixed AADC	0.236	x		=	\$
A9	DSCF 5-Digit	0.190	x	4433	=	\$ 842.2700
A10	DSCF 3-Digit	0.208	x		=	\$
A11	DSCF AADC	0.210	x		=	\$

Letters Over 3.3 oz. up to 3.5 oz.										
Entry	Price Category	Price	Piece Or Amount Affixed	No. of Pieces	Pieces Subtotal	Pound Price	Pounds	Pounds Subtotal	Total Postage	
A12	None 5-Digit	0.083	x		= \$	0.725 x		= \$	= \$	
A13	None 3-Digit	0.101	x		= \$	0.725 x		= \$	= \$	
A14	None AADC	0.103	x		= \$	0.725 x		= \$	= \$	
A15	None Mixed AADC	0.120	x		= \$	0.725 x		= \$	= \$	
A16	DNDC 5-Digit	0.083	x		= \$	0.562 x		= \$	= \$	
A17	DNDC 3-Digit	0.101	x		= \$	0.562 x		= \$	= \$	
A18	DNDC AADC	0.103	x		= \$	0.562 x		= \$	= \$	
A19	DNDC Mixed AADC	0.120	x		= \$	0.562 x		= \$	= \$	
A20	DSCF 5-Digit	0.083	x		= \$	0.517 x		= \$	= \$	
A21	DSCF 3-Digit	0.101	x		= \$	0.517 x		= \$	= \$	
A22	DSCF AADC	0.103	x		= \$	0.517 x		= \$	= \$	

For affixed postage mailings as described in DMM 243, compute and enter the price for each piece in the Amount Affixed column, multiply by No. of Pieces and total in the Total column.

A23 Standard Mail Automation Letters Subtotal (Lines A1-A22) \$ 842.2700

Full Service Intelligent Mail Option
 A24 Number of Pieces that Comply X \$0.001 = \$

Part A Total (Lines A23 minus A24) | \$ 842.2700 |

Part B - Automation Flats Check box at left if prices are populated in this section.

Flats 3.3 oz. (0.2063 lbs.) or Less						
Entry	Price Category	Price		No. of Pieces	=	Total Postage
B1	None 5-Digit	0.346	x		=	\$
B2	None 3-Digit	0.418	x		=	\$
B3	None ADC	0.486	x		=	\$
B4	None Mixed ADC	0.496	x		=	\$
B5	DNDC 5-Digit	0.312	x		=	\$
B6	DNDC 3-Digit	0.384	x		=	\$
B7	DNDC ADC	0.452	x		=	\$
B8	DNDC Mixed ADC	0.462	x		=	\$
B9	DSCF 5-Digit	0.303	x		=	\$
B10	DSCF 3-Digit	0.375	x		=	\$
B11	DSCF ADC	0.443	x		=	\$

Flats Over 3.3 oz. but less than 16 oz.										
Entry	Price Category	Price	Piece Or Amount Affixed	No. of Pieces	Pieces Subtotal	Pound Price	Pounds	Pounds Subtotal	Total Postage	
B12	None 5-Digit	0.196	x		= \$	0.725 x		= \$	= \$	
B13	None 3-Digit	0.268	x		= \$	0.725 x		= \$	= \$	
B14	None ADC	0.336	x		= \$	0.725 x		= \$	= \$	
B15	None Mixed ADC	0.346	x		= \$	0.725 x		= \$	= \$	
B16	DNDC 5-Digit	0.196	x		= \$	0.562 x		= \$	= \$	
B17	DNDC 3-Digit	0.268	x		= \$	0.562 x		= \$	= \$	
B18	DNDC ADC	0.336	x		= \$	0.562 x		= \$	= \$	
B19	DNDC Mixed ADC	0.346	x		= \$	0.562 x		= \$	= \$	
B20	DSCF 5-Digit	0.196	x		= \$	0.517 x		= \$	= \$	
B21	DSCF 3-Digit	0.268	x		= \$	0.517 x		= \$	= \$	
B22	DSCF ADC	0.336	x		= \$	0.517 x		= \$	= \$	

For affixed postage mailings as described in DMM 343, compute and enter the price for each piece in the Amount Affixed column, multiply by No. of Pieces and total in the Total column.

B23 Standard Mail Automation Flats Subtotal (Lines B1-B22) \$

Full Service Intelligent Mail Option
 B24 Number of Pieces that Comply X \$0.001 = \$

Part B Total (Lines B23 minus B24) | \$ |

Part C - Parcels' Check box at left if prices are populated in this section.

Machinable Parcels										
Entry	Price Category	Piece Price	Or Amount Affixed	No. of Pieces	Pieces Subtotal	Pound Price	Pounds	Pounds Subtotal	Total Postage	
C1	None NDC	0.879	x	= \$	0.990 x	= \$	= \$	= \$		
C2	None Mixed NDC	1.279	x	= \$	0.990 x	= \$	= \$	= \$		
C3	DNDC 5-Digit	0.440	x	= \$	0.775 x	= \$	= \$	= \$		
C4	DNDC NDC	0.879	x	= \$	0.775 x	= \$	= \$	= \$		
C5	DSCF 5-Digit	0.440	x	= \$	0.566 x	= \$	= \$	= \$		
C6	DDU 5-Digit	0.440	x	= \$	0.370 x	= \$	= \$	= \$		
C7	Nonbarcoded Surcharge		0.070	x				= \$		

For affixed postage mailings as described in DMM 443, compute and enter the price for each piece in the Amount Affixed column, multiply by No. of Pieces and total in the Total column.

Part C Total | \$ |

Part D - Nonautomation Letters Check box at left if prices are populated in this section.

Machinable Letters 3.3 oz. (0.2063 lbs.) or Less										
Entry	Price Category	Price	No. of Pieces	Total Postage						
D1	None AADC	0.256	x	= \$						
D2	None Mixed AADC	0.273	x	= \$						
D3	DNDC AADC	0.222	x	= \$						
D4	DNDC Mixed AADC	0.239	x	= \$						
D5	DSCF AADC	0.213	x 373	= \$ 79.4490						

Nonmachinable Letters 3.3 oz. (0.2063 lbs.) or Less										
Entry	Price Category	Price	No. of Pieces	Total Postage						
D6	None 5-Digit	0.330	x	= \$						
D7	None 3-Digit	0.447	x	= \$						
D8	None ADC	0.491	x	= \$						
D9	None Mixed ADC	0.578	x	= \$						
D10	DNDC 5-Digit	0.296	x	= \$						
D11	DNDC 3-Digit	0.413	x	= \$						
D12	DNDC ADC	0.457	x	= \$						
D13	DNDC Mixed ADC	0.544	x	= \$						
D14	DSCF 5-Digit	0.287	x	= \$						
D15	DSCF 3-Digit	0.404	x	= \$						
D16	DSCF ADC	0.448	x	= \$						

Part D Total | \$ 79.4490 |

Part E - Nonautomation Flats Check box at left if prices are populated in this section.

Flats 3.3 oz. (0.2063 lbs.) or Less										
Entry	Price Category	Price	No. of Pieces	Total Postage						
E1	None 5-Digit	0.367	x	= \$						
E2	None 3-Digit	0.464	x	= \$						
E3	None ADC	0.509	x	= \$						
E4	None Mixed ADC	0.558	x	= \$						
E5	DNDC 5-Digit	0.333	x	= \$						
E6	DNDC 3-Digit	0.430	x	= \$						
E7	DNDC ADC	0.475	x	= \$						
E8	DNDC Mixed ADC	0.524	x	= \$						
E9	DSCF 5-Digit	0.324	x	= \$						
E10	DSCF 3-Digit	0.421	x	= \$						
E11	DSCF ADC	0.466	x	= \$						

Flats Over 3.3 oz. but less than 16 oz.										
Entry	Price Category	Piece Price	Or Amount Affixed	No. of Pieces	Pieces Subtotal	Pound Price	Pounds	Pounds Subtotal	Total Postage	
E12	None 5-Digit	0.217	x	= \$	0.725 x	= \$	= \$	= \$		
E13	None 3-Digit	0.314	x	= \$	0.725 x	= \$	= \$	= \$		
E14	None ADC	0.359	x	= \$	0.725 x	= \$	= \$	= \$		
E15	None Mixed ADC	0.408	x	= \$	0.725 x	= \$	= \$	= \$		
E16	DNDC 5-Digit	0.217	x	= \$	0.562 x	= \$	= \$	= \$		
E17	DNDC 3-Digit	0.314	x	= \$	0.562 x	= \$	= \$	= \$		
E18	DNDC ADC	0.359	x	= \$	0.562 x	= \$	= \$	= \$		
E19	DNDC Mixed ADC	0.408	x	= \$	0.562 x	= \$	= \$	= \$		
E20	DSCF 5-Digit	0.217	x	= \$	0.517 x	= \$	= \$	= \$		
E21	DSCF 3-Digit	0.314	x	= \$	0.517 x	= \$	= \$	= \$		
E22	DSCF ADC	0.359	x	= \$	0.517 x	= \$	= \$	= \$		

For affixed postage mailings as described in DMM 343, compute and enter the price for each piece in the Amount Affixed column, multiply by No. of Pieces and total in the Total column.

Part E Total | \$ |

Madison MPO
 Madison, Mississippi
 391109998
 2737860110 -0098
 06/25/2010 (601)853-2403 10:25:41 AM

Product Description	Sales Receipt		Final Price
	Sale Qty	Unit Price	

Permit Type: Permit Imprint
 Permit Number: 23
 Customer Name: CITY OF MADISON

 Amount of Deposit: \$921.72
 New Balance: \$1,136.69
 Confirmation #: 201017610242640D

 Total: \$921.72

 Paid by: Personal Check \$921.72

Order stamps at USPS.com/shop or call 1-800-Stamp24. Go to USPS.com/clicknship to print shipping labels with postage. For other information call 1-800-ASK-USPS.

 Get your mail when and where you want it with a secure Post Office Box. Sign up for a box online at usps.com/poboxes.

Bill#: 1000201836045
 Clerk: 10

All sales final on stamps and postage
 Refunds for guaranteed services only
 Thank you for your business

 HELP US SERVE YOU BETTER

Go to: <https://postalexperience.com/Pos>
 TELL US ABOUT YOUR RECENT POSTAL EXPERIENCE
 VOID ADDITIONAL COPIES