

BUREAU OF PUBLIC WATER SUPPLY

2010 JUN -7 AM 9:10

CALENDAR YEAR 2009 CONSUMER CONFIDENCE REPORT
CERTIFICATION REPORT

WHEELER-FRANKSTOWN WATER ASSOCIATION
PWS ID # ('s):0590014

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill, or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: 6-1-10

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date mailed/distributed: _____

- CCR was published in local newspaper. *(Attach copy of published CCR and proof of publication)*
 - Name of Newspaper: The Banner Independent
 - Date Published: 6-3-10

- CCR was posted in public places. *(Attach list of locations)*

Date posted: 6-1-10

- CCR was posted on a publicly accessible internet site at the address: www: _____

CERTIFICATION:

I hereby certify that a Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

James Blower
Name/Title (President, Mayor, Owner, etc.)

6-1-10
Date

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Susan Boyette
Signature

5/21/10
Date

11

Annual Drinking Water Quality Report
Wheeler-Frankstown Water Association
PWS ID #0590014
July, 2010

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of four wells that draw from the Eutaw Formation Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. A report containing detailed information has been received by our office and will be made available for review upon request. The water supply for Wheeler-Frankstown Water Association received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Jimmy Glover at 662-365-8750. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at the Wheeler-Frankstown Water Association office at 6:00 p.m.

Wheeler-Frankstown Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2006. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria	Y	June, 09	Pos	One		0	presence of coliform bacteria in 5% of	Naturally present in the environment

10. Barium	N	2006*	0.13	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2006*	2	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2008*	2	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2006*	1.04	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfectants & Disinfection By-Products								
Chlorine (as Cl ₂)	N		0.69 to 0.85	None	ppm	4	4	Water additive used to treat microbes.

* Most recent sample results available

Total Coliform Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. The violation occurred in June 2009. It was resolved within one week. For each detect of total coliform, additional samples were collected at the sites where total coliform was detected, upstream of each site and downstream of each site. Results showed all samples free of total coliform; however, it was noted that the chlorine residual in this area was lower than usual. The amount of chlorine was increased to insure an adequate chlorine residual was maintained.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wheeler-Frankstown Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

2009 CCR Contact Information

Date: 7/27/10 Time: 8:45

PWSID: 590014

System Name: Wheeler Frankstown

Lead/Copper Language

Chlorine Residual (MRDL) RAA

Other Violation(S) 22-MCL (TCR) monthly 6/2009

Will correct report & mail copy marked "corrected copy" to MSDH.

Will notify customers of availability of corrected report on next monthly bill.

Kim will notify Susan Bouette to make correction
and notify customers of available corrected copy
on the water bill.

Spoke with Kim Jackson 662 365-8750
(Operator, Owner, Secretary)

Annual Drinking Water Quality Report
Wheeler-Frankstown Water Association
PWS ID # 0590014
May, 2010

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of four wells that draw from the Eutaw Formation Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. A report containing detailed information has been received by our office and will be made available for review upon request. The water supply for Wheeler-Frankstown Water Association received a low to moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Jimmy Glover at 662-365-8750. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at the Wheeler-Frankstown Water Association office at 6:00 p.m.

Wheeler-Frankstown Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2009. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2006*	0.13	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2006*	2	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2008*	2	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2006*	1.04	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
<i>Disinfectants & Disinfection By-Products</i>								
Chlorine (as Cl ₂)	N		0.69 to 0.85	None	ppm	4	4	Water additive used to control microbes

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wheeler-Frankstown Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

\$ 302.⁴⁰/₁₀₀

PROOF OF PUBLICATION

STATE OF MISSISSIPPI COUNTY OF PRENTISS

BEFORE ME, Teresa C. Smith
a Notary Public in and for said county, or other
official qualified to administer oaths, this day
personally came the undersigned official of
The Banner-Independent, a newspaper
published weekly in the City of Booneville, in
Prentiss County, State of Mississippi, who,
being duly sworn, states that the notice, a true
copy of which is hereto attached, was
published in the aforesaid newspaper
for one consecutive weeks to-wit

Vol. 113, Number 17, June 03, 20 10
Vol. _____, Number _____, _____, 20 _____
Vol. _____, Number _____, _____, 20 _____

Kenny H. Goode
Editor

Witness my signature this _____ day of _____, 20 _____



Teresa C. Smith
Notary Public
2-1-14
My Commission Expires

Filed this the _____ day of _____, 20 _____

By _____
Official Filing Title

Annual Drinking Water Quality Report
Wheeler-Frankstown Water Association
PWS ID #0590014
May 2010

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists four wells that draw from the Butaw Formation Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. A report containing detailed information has been received by our office and will be made available for review upon request. The water supply for Wheeler-Frankstown Water Association received a low to moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Jimmy Glover at 662-365-8750. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at the Wheeler-Frankstown Water Association office at 6:00 p.m.

Wheeler-Frankstown Water Association routinely monitors for constituents in your drinking water

according to Federal and State laws. This table shows (be results of our monitoring for the period of January 1 st to December 31 st, 2009. As water travels over the land or underground, it can pick up substances or contaminants such as: microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Yieldive Yr	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2006*	0.15	No Range	ppm	2	2	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2006*	2	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	0.1	None	ppm	1.3	AL=1.5	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2008*	2	None	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
21. Selenium	N	2006*	1.04	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfectants & Disinfection By-Products								
Chlorine (as Cl ₂)	N		0.69 to 0.85	None	ppm	4	4	Water additive used to control microbes

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wheeler-Frankstown Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or a <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions 662-365-8750.

RECEIVED-WATER SUPPLY
2010 JUL 30 AM 8:50

Wheeler Weather
59-0014

WATER BILL

WHEELER-FRANKTOWN WATER ASSOC.
P.O. BOX 157
WHEELER, MS 38860
365-8750

PRESENTED BY
FIRST CLASS MAIL
USPS PERMIT NO. 101
PERMIT NO. 101
WHEELER, MS 38860

DUEDATE	FILE DATE	FILE DATE	ADDRESS SERVICE REQUESTED	PREVIOUS METER READING
08-10-10	07-28-10	08-10-10	07-14-10	506000
DESCRIPTION	CHARGES	DESCRIPTION	CHARGES	CURRENT METER READING
WATER	14.00	WATER	14.00	506000
SEWER	0.25	SEWER	0.25	USAGE IN GALLONS
				AVERAGE DAILY USAGE
				USAGE SAME PERIOD LAST YR
ACCOUNT NO.	TOTAL DUE	ACCOUNT NO.	TOTAL DUE	IF NOT PAID BEFORE
002713	14.25	002713	14.25	08-10-10 PAY
AFTER 08-10-10 PAY	GROSS	SVC. ADDRESS	C.R. 1529	15.65
DEMAR, CHARLES R.	15.65	CORRECTED 2010 CCR REPORT AVAILABLE IN OFFICE UPON REQUEST.		

CHARLES R. DEMAR
11601 TERRACE DRIVE
WALDORF MARYLAND 20602-

Joan,
here is where we
put corrected copy of
CCR on water bill
Thank you
Rain
!!
59-0014

WATER BILL

WHEELER-FRANKSTOWN WATER ASSOC.
 P.O. BOX 157
 WHEELER, MS 38880
 665-8750

IF NOT PAID BY THE DATE INDICATED, THIS BILL WILL BE FORWARDED TO THE COLLECTION AGENCY. PAYMENT MUST BE MADE TO THE CITY OF WHEELER, MISSISSIPPI.

ACCOUNT NO.	06-10-10	05-26-10	06-10-10	05-07-10	677000
DATE	06-10-10	05-26-10	06-10-10	05-07-10	677000
DESCRIPTION	WATER	WATER	WATER	WATER	WATER
SEWER	0.25	SEWER	0.25	SEWER	0.25
ACCOUNT NO.	002859	002859	002859	002859	002859
DATE	06-10-10	06-10-10	06-10-10	06-10-10	06-10-10
DESCRIPTION	AUBREY MILLS				
AMOUNT	17.25	17.25	17.25	17.25	17.25
DATE	06-10-10	06-10-10	06-10-10	06-10-10	06-10-10
DESCRIPTION	CONSUMER CONFIDENCE REPORT				
AMOUNT	18.95	18.95	18.95	18.95	18.95
DATE	06-10-10	06-10-10	06-10-10	06-10-10	06-10-10
DESCRIPTION	AVAILABLE IN OFFICE UPON REQUEST				

AUBREY MILLS
 154 CR 5006
 ROONEVILLE MS 38829-



Wheeler-Frankstown Water Association

(002) 365-3750

P.O. Box 157
Wheeler, Mississippi 38880

1. George E Allen Libary, Booneville, Ms
2. Wheeler Post Office, Wheeler, Ms
3. Wheeler Water Office Lobby, Wheeler, Ms