

**MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CALENDAR YEAR 2009 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

Dennis Water Association

Public Water Supply Name

0710003

PWS ID#(s) (List ID #s for all Water Systems Covered by This CCR)

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by:

Advertisement in local paper

On water bills

Other

Date customers were informed: 6 / 1 / 2010

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: ___ / ___ / ___

CCR was published in local newspaper. (Attach copy of published CCR & proof of publication)

Name of Newspaper: Belmont/Tishomingo Journal

Date Published: 6 / 2 / 2010

CCR was posted in public places. (Attach list of locations)

Date Posted: ___ / ___ / ___

CCR was posted on a publicly accessible internet site at the address:

www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system official by the Mississippi State Department of Health, Bureau of Water Supply.

Robert Deaton, President

Name/Title (President, Mayor, Owner, etc.) Please type/print

Robert Deaton

Signature

6, 9, 10

Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2009 Annual Drinking Water Quality Report

Dennis Water Association

PWS ID #0710003

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards set for quality and safety. Local Water vigilantly safeguards its water supplies and once again we are very proud that our system has not violated a maximum contaminant level or any other water quality standard. This report shows the results for our monitoring for the period of January 1st to December 31st, 2009. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Where does my water come from?

Our water source consists of nine (9) wells; all nine draw from the Gordo Formation Aquifer.

Source water assessment and its availability:

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing at our office upon request. Listed below are the ratings for the wells of Dennis Water Association.

Well # 710003-01 – moderate rating on source water assessment
Well # 710003-02 – moderate rating on source water assessment
Well # 710003-03 – moderate rating on source water assessment
Well # 710003-04 – moderate rating on source water assessment
Well # 710003-05 – moderate rating on source water assessment
Well # 710003-06 – moderate rating on source water assessment
Well # 710003-07 – moderate rating on source water assessment
Well # 710003-08 – moderate rating on source water assessment
Well # 710003-09 – moderate rating on source water assessment

Why are there contaminants in my drinking water?

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Our board meets monthly on the second Monday at 7:00 P.M. at the Water Office. We encourage all customers with concerns or questions to meet with us. Our Association conducts its annual membership meeting on the first Monday night in August at 7:00 PM at the Water Office.

FOR MORE INFORMATION CONTACT:

| |
|---------------------------------------|
| <i>Dennis Water Association</i> |
| <i>ATTN: Robert Deaton, President</i> |
| <i>Po Box 305</i> |
| <i>Dennis MS 38838</i> |
| <i>Phone: 662-454-9862</i> |

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Dennis Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

Monitoring and reporting of compliance data violations

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system passed all of these monitoring requirements. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

The table below list all the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Dennis Water Association

PWS ID # 0710003

2009 WATER QUALITY DATA TABLE

| Contaminants (units) | MCLG or MRDLG | MCL, TT, or MRDL | Your Water | Range | | Sample Date | Violation | Typical Source |
|---|--|------------------|------------|---|------------|---|--|--|
| | | | | Low | High | | | |
| Disinfectants & Disinfection By-Products | | | | | | | | |
| Chlorine (ppm) | 4 | 4 | 2.28 | 0.70 | 2.28 | 2009 | No | Water additive used to control microbes |
| HAA5 {Haloacetic Acids} (ppb) | 0 | 60 | 9 | N/A | N/A | 2007 | No | By Product of drinking water chlorination |
| Inorganic Contaminants | | | | | | | | |
| Barium (ppm) | 2 | 2 | 0.014 | N/A | N/A | 2006 | No | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits |
| Nitrate {measured as Nitrogen} (ppm) | 10 | 10 | 0.87 | N/A | N/A | 2009 | No | Runoff from fertilizer user; Leaching from septic tanks, sewage; Erosion of natural deposits |
| Nitrite {measured as Nitrogen} (ppm) | 1 | 1 | 0.05 | N/A | N/A | 2009 | No | Runoff from fertilizer user; Leaching from septic tanks, sewage; Erosion of natural deposits |
| Contaminants (units) | MCLG | AL | Your Water | # Samples Exceeding AL | Exceeds AL | Sample Date | Typical Source | |
| Inorganic Contaminants (Lead and Copper) | | | | | | | | |
| Lead (ppb) | 0 | 15 | 1 | 0 | No | 2007 | Corrosion of household plumbing systems; Erosion of natural deposits | |
| Important Drinking Water Definitions | | | | | | | | |
| MCLG - Maximum Contaminant Level Goal | The level of a contaminant in drinking water below which there is no know or expected risk to health. MCLGs allow for a margin of safety. | | | | | | | |
| MCL - Maximum Contaminant Level | The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. | | | | | | | |
| AL - Action Level | The concentration of a contaminant which, if exceeded, triggers a treatment or other requirements which a water system must follow. | | | | | | | |
| TT-Treatment Technique | A required process intended to reduce the level of a contaminant in drinking water. | | | | | | | |
| MRDLG - Maximum Residual Disinfection Level Goal | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. | | | | | | | |
| MRDL - Maximum Residual Disinfection Level | The highest level of a disinfectant allowed in drinking water. Ther is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. | | | | | | | |
| MNR - Monitored Not Regulated | | | | | | | | |
| MPL - State Assigned Maximum Permissible Level | | | | | | | | |
| Unit Descriptions | | | | | | | | |
| ppb - Parts per billion, or micrograms per liter (ug/l) | | | | ppm - Parts per million, or milligrams per liter (mg/l) | | | | |
| pCi/L - Picocuries per liter (a measure of radioactivity) | | | | ppt - Parts per trillion, or nanograms per liter | | | | |
| NA - not applicable | | | | ND - not detected | | NR - Moitoring not required, but recommeded | | |

PROOF OF PUBLICATION

**STATE OF MISSISSIPPI
COUNTY OF TISHOMINGO**

Before the undersigned, a
Notary Public

in and for said state and county,

Catherine Mitchell

Editor, Publisher and Manager of

The Belmont and Tishomingo Journal
a newspaper published in the Town of Belmont in
said county and state, makes oath that the

Notice

of which the article here unto attached is a true copy,
was published in said newspaper as follows:

| | | | | | |
|------|----|-----|----|------|--------------|
| Vol. | 41 | No. | 16 | Date | June 2, 2010 |
| Vol. | | No. | | Date | |
| Vol. | | No. | | Date | |
| Vol. | | No. | | Date | |
| Vol. | | No. | | Date | |

And I hereby certify that the issues above mentioned
have been examined by me, and I find the publication
thereof to have been duly made, and that The Belmont
and Tishomingo Journal has been established and had a
bona fide circulation in said city, county and state for
more than one year next proceeding the first date written
above.

Catherine Mitchell

Editor, Publisher and Manager

Sworn to and subscribed before me this the 4

day of June, 2010

M. Wayne Mitchell

Notary Public

My Commission Expires December 9, 2010

2009 Annual Drinking Water Quality Report

Dennis Water Association
PWS ID #0710003

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards set for quality and safety. Local Water vigilantly safeguards its water supplies and once again we are very proud that our system has not violated a maximum contaminant level or any other water quality standard. This report shows the results for our monitoring for the period of January 1st to December 31st, 2009. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Where does my water come from?

Our water source consists of nine (9) wells; all nine draw from Gordo Formation Aquifer.

Source water assessment and its availability:

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing at our office upon request. Listed below are the ratings for the wells of Dennis Water Association.

- Well # 710003-01 - moderate rating on source water assessment
- Well # 710003-02 - moderate rating on source water assessment
- Well # 710003-03 - moderate rating on source water assessment
- Well # 710003-04 - moderate rating on source water assessment
- Well # 710003-05 - moderate rating on source water assessment
- Well # 710003-06 - moderate rating on source water assessment
- Well # 710003-07 - moderate rating on source water assessment
- Well # 710003-08 - moderate rating on source water assessment
- Well # 710003-09 - moderate rating on source water assessment

Why are there contaminants in my drinking water?

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive materials, and can pick up substances resulting from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Monday at 7:00 P.M. at the Water Office. We Association conducts

FOR MORE INFORMATION CONTACT:

Dennis Water Association
ATTN: Robert Deaton, President
PO Box 305
Dennis, MS 38838
Phone: 662-454-9862

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Dennis Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

Monitoring and reporting of compliance data violations

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/ test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system passed all of these monitoring requirements. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

The table below list all the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Dennis Water Association PWS ID #0710003
2009 WATER QUALITY DATA TABLE

| Contaminants (units) | MCLG or MRDLG | MCL, TT, or MRDL | Your Water | Range Low - High | Sample Date | Violation | Typical Source |
|---|--|------------------|------------|------------------------|-------------|-------------|--|
| Disinfectants & Disinfection By-Products | | | | | | | |
| Chlorine (ppm) | 4 | 4 | 2.28 | 0.70 - 2.28 | 2009 | No | Water additive used to control microbes |
| HAAs (Haloacetic Acids) (ppb) | 0 | 60 | 9 | N/A - N/A | 2007 | No | By Product of drinking water chlorination |
| Inorganic Contaminants | | | | | | | |
| Barium (ppm) | 2 | 2 | 0.014 | N/A - N/A | 2006 | No | Discharge of drilling wastes, Discharge from metal refineries, Erosion of natural deposits |
| Nitrates (measured as Nitrogen) (ppm) | 10 | 10 | 0.87 | N/A - N/A | 2009 | No | Runoff from fertilizer user, Leaching from septic tanks, sewage, Erosion of natural deposits |
| Nitrite (measured as Nitrogen) (ppm) | 1 | 1 | 0.05 | N/A - N/A | 2009 | No | Runoff from fertilizer user, Leaching from septic tanks, sewage, Erosion of natural deposits |
| Contaminants (units) | MCLG | AL | Your Water | # Samples Exceeding AL | Exceeds AL | Sample Date | Typical Source |
| Inorganic Contaminants (Lead and Copper) | | | | | | | |
| Lead (ppb) | 0 | 15 | 1 | 0 | No | 2007 | Corrosion of household plumbing systems, Erosion of natural deposits |
| Important Drinking Water Definitions | | | | | | | |
| MCLG - Maximum Contaminant Level Goal | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. | | | | | | |
| MCL - Maximum Contaminant Level | The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. | | | | | | |
| AL - Action Level | The concentration of a contaminant which, if exceeded, triggers a treatment or other requirements which a water system must follow. | | | | | | |
| TT - Treatment Technique | A required process intended to reduce the level of a contaminant in drinking water. | | | | | | |
| MRDLG - Maximum Residual Disinfection Level Goal | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. | | | | | | |
| MRDL - Maximum Residual Disinfection Level | The highest level of a disinfectant allowed in drinking water. This is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. | | | | | | |
| MNR - Monitored Not Regulated | | | | | | | |

Dennis Water Association Address Service
 P.O. BOX 305 Requested
 Dennis, MS 38838-
 (662)454-9862

PRESORT
 FIRST CLASS MAIL
 U.S. POSTAGE
 PAID
 DENNIS, MS
 Permit No. 2

| Account No. | | Service Address | | |
|-------------|---------------|-----------------|------------|--------|
| 103330 | | 23 CR 29 | | |
| Serv Type | Meter Reading | | Units Used | Amount |
| | Previous | Current | | |
| WTR | 396200 | 398900 | 2700 | 13.50 |

| Account No. | Due Date |
|----------------|-------------|
| 103330 | 06/15/2010 |
| Amount Due | |
| After Due Date | By Due Date |
| 14.85 | 13.50 |

Return This Stub With Payment

ABLES STEPHEN
 23 CR 29
 DENNIS, MS 38838-9750

| Billing Date | Due Date | After Due Date | By Due Date |
|--------------|------------|----------------|-------------|
| 05/26/2010 | 06/15/2010 | 14.85 | 13.50 |

Consumer Confidence Report Available @ Office

