



MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2009 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

LORMAN Waterworks Ass'n Inc.
Public Water Supply Name

320013

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper → *Jefferson & Claiborne*
- On water bills
- Other _____

Date customers were informed: 6/24/10 & 6/24/10

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Fayette Chronicle & Post News Perille

Date Published: / /

CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

CCR was posted on a publicly accessible internet site at www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

W.S. Phillips
Name/Title (President, Mayor, Owner, etc.)

11-11-10
Date

W S Phillips
Mail Completed Form to: Bureau of Public Water Supply/P.O. Box: 1760/Jackson, MS 39215
Phone: 601-576-7518

2010 JUN -8 AM 9:52

2009 Annual Drinking Water Quality Report
 Lorman Waterworks Association, Inc.
 PWS#: 320013
 June 2010

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Catahoula and Miocene Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Lorman Waterworks Association, Inc. have received a lower ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Dwayne Montgomery at 601.437.4006. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the second Thursday of the month at 7:00 PM at the Lorman Office.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2009. In cases where monitoring wasn't required in 2009, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	--------------------	------	-----	--------------------------------

MCL/ACL/MRDL									
Microbiological Contaminants									
1. Total Coliform Bacteria	Y	February	Positive	3	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment	
Inorganic Contaminants									
8. Arsenic	N	2009	.683	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes	
10. Barium	N	2009	.003	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
14. Copper	N	2008*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
16. Fluoride	N	2009	.43	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
17. Lead	N	2008*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	
Disinfection By-Products									
81. HAA5	N	2009	.003	No Range	ppb	0	60	By-Product of drinking water disinfection.	
82. TTHM [Total trihalomethanes]	N	2009	5.99	No Range	ppb	0	80	By-product of drinking water chlorination.	
Chlorine	N	2009	1.26	1.03 – 1.8	ppm	0	MRDL = 4	Water additive used to control microbes	

* Most recent sample. No sample required for 2009

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

As you can see by the table, our system violated a drinking water standard. We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During February of 2009, we took 13 samples for coliform bacteria, Three (3) of those samples showed the presence of coliform bacteria. In cooperation with the Mississippi Department of Health, the necessary measures were taken to return the system to compliance. We are pleased to report that the re-samples were free of the bacteria.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Lorman Waterworks Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

The Fayette Chronicle

P. O. Box 536
Fayette, MS 39069

"Serving Fayette, Mississippi and Jefferson County Since 1866"

Charles K. Sheppard
Owner/Publisher

Ph. (601) 786-3661

PUBLISHER'S OATH

STATE OF MISSISSIPPI,

Jefferson County

Personally appeared before the undersigned THE FAYETTE CHRONICLE

Editor, Charles K. Sheppard

of the County, JEFFERSON, THE CITY OF FAYETTE

one of the Publishers of the Fayette Chronicle, a weekly newspaper, printed and published in the town of Fayette and Jefferson County, in said county and State, who, being duly sworn deposes and says that said newspaper has been established for more than twelve months next prior to first publication mentioned below; and who further makes oath that publication of a notice, of which, the annexed is a copy, has been made in said paper consecutively, to-wit:

on the	<u>24th</u>	day of	<u>2010</u>
on the	_____	day of	_____
on the	_____	day of	_____
on the	_____	day of	_____
on the	_____	day of	_____

SHEPPHARD and Associates Sheppard and Associates/CDI, Publisher

And I, _____

do hereby certify that the papers containing said notice have been produced before me, and by be compared to the copy annexed, and that I find the proof of publication thereof to be correctly made.

Witness my hand and seal, 29th day of June
2010

Arnell Harris Circuit Clerk
By: Maxine White, D.C.
Notary Public

PUBLISHER'S OATH

STATE OF MISSISSIPPI,
CLAIBORNE COUNTY, MISSISSIPPI


Personally appeared before the undersigned NOTARY PUBLIC of said County, EMMA F. CRISLER, Publisher of The Reveille, a weekly newspaper, printed and published in the town of Port Gibson, in said county and state, who, being duly sworn deposes and says that said newspaper has been established for more than twelve months next prior to first publication mentioned below; and who further makes oath that publication of a notice, of which, the annexed is a copy, has been made in said paper consecutively, to wit:

On the 24th day of June, 2010
On the _____ day of _____, 2010
On the _____ day of _____, 2010
On the _____ day of _____, 2010

E. F. Crisler, Publisher

And I, Stacey G. Burk do hereby certify that the papers containing said notice have been produced before me, and by me compared with the copy annexed, and that I find the proof of publication thereof to be correctly made.

Witness my hand and seal, this 24 of JUNE 2010.
Stacey D. Burk, Notary Public
Fees and proof of publication, \$ 319.00



2009 Annual Drinking Water Quality Report
Lorman Waterworks Association, Inc.
 PWS#: 320013
 June 2010

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continuously improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Cretaceous and Miocene Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Lorman Waterworks Association, Inc. have received a lower ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Dwayne Montgomery at 601.437.4006. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the second Thursday of the month at 7:00 PM at the Lorman Office.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2009. In cases where monitoring wasn't required in 2009, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in 100,000.

parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in 100,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AQL/MRDL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
Coliform	Y	February	Positive	3	NA	0		presence of coliform bacteria in 5% of monthly samples Naturally present in the environment
Inorganic Contaminants								
As	N	2009	.003	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Cr	N	2009	.003	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Pb	N	2009*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fe	N	2009	.43	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge
Mn	N	2009*	2	0				