



MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Punkin Water Association

Public Water Supply Name

0360013 & 0360031

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
- Advertisement in local paper
- On water bills
- Other

Date customers were informed: 05 / 25 / 2011

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: The Oxford Eagle

Date Published: 05/26/2011

- CCR was posted in public places. (Attach list of locations)

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Thomas D. Sartor, Director & CCR Officer

Signature of Thomas D. Sartor
Name/Title (President, Mayor, Owner, etc.)

May 31, 2011

Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

Inorganic Contaminants

10. Barium	N	2009*	.023	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
16. Fluoride	N	2009*	.158	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2009*	1.11	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	1.15	.8 – 1.35	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2010.

PWS ID#: 0360031

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2009*	.006	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2008*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2009*	.165	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2006*	21.06	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2006*	18.9	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	1.29	1.15 – 1.4	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2010.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2

minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Punkin Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2011 JUN -2 AM 9:29

Punkin Water Association
C/O Thomas Sartor
22 County Road 407
Oxford, MS 38655

May 31, 2011

State of Mississippi
Bureau of Public Water Supply
P. O. Box 1700
Jackson, MS 39215

RE: 2010 Consumer Confidence Report Certification

Dear Bureau of Public Water Supply:

Enclosed please find our CCR certification form with all related documents for the year 2010. If there are any questions please call, (662)234-1680 or cell #(662)202-2840, or write me at the above address.

Sincerely,



Thomas D. Sartor
Punkin Water Association
Director / CCR Officer

ENCL: Certification Form
 Actual Water Bill
 Proof of Publication (Oxford Eagle Newspaper)
 Page from actual paper of article

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water supply to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Lower Vicksburg Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of the system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Purkin Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water safety, please contact John M. Davis at (662)234-2230. We want our valued customers to be informed about their water utility. If you need to learn more, please attend any of our regularly scheduled meetings. They are held on the third Tuesday of each month at 7:00 PM at the residence of Mrs. Ruby Gean at 11 County Road #17, Oxford, MS 38655.

We routinely monitor for constituents in your drinking water according to Federal and State law. The table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2010. In cases where monitoring wasn't required in 2010, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity. Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming, pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal(MCLG)" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one milligram in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/L) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID#: 0360013		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or if of Detects Exceeding MCL/GCL	Unit Measure	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2009	023	No Range	ppm	2	2	Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits
16. Fluoride	N	2009	158	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong leach; discharge from fertilizer and aluminum facilities
Disinfection By-Products								
02. THM4 (Total trihalomethanes)	N	2009	1.11	No Range	ppb	0	80	By-product of drinking water disinfection
Chlorine	N	2010	1.15	1 - 1.35	ppm	0	MORL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2010.

PWS ID#: 0360031		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or if of Detects Exceeding MCL/GCL	Unit Measure	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2009	000	No Range	ppm	2	2	Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits
14. Copper	N	2008	3	0	ppm	1.3	AL+1.3	Corrosion of household plumbing systems; erosion of natural deposits; leachate from roof materials
16. Fluoride	N	2006	166	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong leach; discharge from fertilizer and aluminum facilities
17. Lead	N	2009	1	0	ppb	0	AL+1.5	Corrosion of household plumbing systems; erosion of natural deposits
Disinfection By-Products								
01. HAAs	N	2009	21.08	No Range	ppb	0	80	By-product of drinking water disinfection
02. THM4 (Total trihalomethanes)	N	2009	18.9	No Range	ppb	0	80	By-product of drinking water disinfection
Chlorine	N	2010	1.29	1.15 - 1.4	ppm	0	MORL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2010.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected, however, the EPA has determined that your water is SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.678.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by using the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

The Purkin Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

May 26, 2011

PROOF OF PUBLICATION

PRINTER'S FEE \$ 461.40

THE STATE OF MISSISSIPPI
 LAFAYETTE COUNTY

Personally appeared before me, a notary public in and for said county and State, the undersigned

Tim Phillips

Who, after being duly sworn, deposes and says that he is the Co-Publisher of the Oxford Eagle, a newspaper published daily in the City of Oxford, in said county and State, and that the said newspaper has been published for more than one year and that *Purkin Water Association's 2010 Annual Drinking Water Report* a true copy of which is hereto attached was published for 7 consecutive weeks in said newspaper as follows:

VOLUME 143 NO. 171 DATE May 26, 2011

Tim Phillips
 Sworn to and subscribed before me this 26th day of May, 2011

Rita G. Vasilyev
 Notary Public, Lafayette County, MISSISSIPPI

My commission expires AUGUST 17, 2011



PUNKIN WATER ASSOCIATION
 P.O. Box 114, Oxford, MS 38655
 RETURN SERVICE REQUESTED,

FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID 172

2011 JUN -2 AM 9:29

PERMIT NO.
PUNKIN WATER ASSOCIATION

ROUTE	CUSTOMER	PAY GROSS AMOUNT
1	2	6/10/11
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID
20.00		22.00

TYPE OF SERVICE	METER READING PRESENT	METER READING PREVIOUS	USED	CHARGES
Water	450300	450300	0	20.00

The CCR is available upon request.

Service From 4/25/2011 TO 5/23/2011 ACCOUNT 2 5/25/11

METER READ MONTH	DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
5	23	1	20.00	2.00	22.00

Punkin Water Telephone (662) 234-1897
 PUNKIN WATER ANNUAL MEETING
 TUESDAY, JUNE 21, 2011, 7:00 P.M.
 MIDWAY CHURCH, HWY 6 EAST



MAIL THIS STUB WITH YOUR PAYMENT