



2011 JUN 23 AM 11:02

MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY
CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

Town of Taylorsville
Public Water Supply Name

0650011
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
Advertisement in local paper
On water bills
Other

Date customers were informed: 06/15/2011

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper:

Date Published: / /

- CCR was posted in public places. (Attach list of locations)

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above.

Rosslyn Glenn Mayor
Name/Title (President, Mayor, Owner, etc.)

06-21-2011
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2011 JUN -2 AM 8:13

2010 Annual Drinking Water Quality Report
 Town of Taylorsville
 PWS#: 0650011
 May 2011

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three drawing from the Catahoula Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Taylorsville have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Robert D. Stringer at 601-785-6531. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Thursday after the first Tuesday of each month at 6:00 PM at 202 Eureka Street, Taylorsville, MS.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2010. In cases where monitoring wasn't required in 2010, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria	Y	June	Positive	3	NA		0	presence of coliform bacteria in 5% of monthly samples Naturally present in the environment

Inorganic Contaminants

10. Barium	N	2010	.016	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2008*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2010	.119	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	5	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2010	1.3	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

Chlorine	N	2010	.81	.45 – 1.35	ppm	0	MDRL = 4	Water additive used to control microbes
----------	---	------	-----	------------	-----	---	----------	---

* Most recent sample. No sample required for 2010.

** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.8 - 1.2 mg/l.

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

As you can see by the table, our system violated a drinking water standard. In June 2010, 3 out of 11 samples tested positive for total coliform. We took the necessary measures to return the system to compliance. The re-samples showed no bacteria.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Town of Taylorsville works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. This CCR report will be published in local newspaper serving the area.

The State of Mississippi,
County of Smith

PERSONALLY CAME before me, the undersigned a Notary Public in and for SMITH COUNTY, MISSISSIPPI the OFFICE CLERK of the SMITH COUNTY REFORMER, a newspaper published in the Town of Raleigh, Smith County, in said State, who being duly sworn, deposes and says that the SMITH COUNTY REFORMER is a newspaper as defined and prescribed in §13-3-31 of the Mississippi Code 1972 Annotated and that the publication of a notice, of which the annexed is a copy, in the matter of

2010 Annual Drinking Water Quality Report
4 x 18 1/2

has been made in said paper 1 times consecutively, to-wit:

On the 15 day of June 2011

On the ___ day of ___ 20__

On the ___ day of ___ 20__

On the ___ day of ___ 20__

Terrel Turner
OFFICE CLERK

SWORN to and subscribed before me,

this the 15 day of June 2011

day of June 2011

Mary Cade Bower
NOTARY PUBLIC

Words

Cost

- BURKOW ...
- (CONTRACTOR FURNISHED) (CLASS 9)
- GRANULAR MATERIAL (L.V.M.), (CLASS 9), GROUP B)
- SIZE I STABILIZER AGGREGATE, COARSE (L.V.M.)
- HOT MIX ASPHALT, ST 12.5mm
- HOT MIX ASPHALT, ST 19mm
- 54" REINFORCED CONCRETE PIPE, CLASS III
- GUARD RAIL, W-BEAM
- GUARD RAIL, BRIDGE END SECTION, TYPE "T", THRIE-BEAM
- GUARD RAIL, TERMINAL END SECTION
- RIGHT-OF-WAY MARKERS (TYPE I)
- MAINTENANCE OF TRAFFIC
- ADDITIONAL CONSTRUCTION SIGNS
- 4" WIDE THERMOPLASTIC EDGE STRIPE (CONTINUOUS WHITE) (60 MIL)
- 4" WIDE THERMOPLASTIC TRAFFIC STRIPE (CONTINUOUS YELLOW) (90 MIL)
- REFLECTORIZED TRAFFIC OBJECT MARKER (ENCAPSULATED LENS)(TYPE 3)
- EROSION CONTROL ITEMS:
- AGRICULTURAL LIMESTONE
- COMMERCIAL FERTILIZER (13-13-13)
- AMMONIUM NITRATE
- SEEDING
- VEGETATIVE MATERIALS FOR MULCH
- SOLID SODDING
- PORTLAND CEMENT CONCRETE
- PAVED DITCH
- TEMPORARY SILT FENCE (TYPE II) (AOS 0.15-0.84)
- TEMPORARY EROSION CHECKS
- LOOSE RIPRAP (200 LB.)
- BRIDGE ITEMS:
- TEST PILES
- CONVENTIONAL STATIC PILE LOAD TEST
- 10" STEEL PILING
- BRIDGE CONCRETE, CLASS "B"
- 40' PRESTRESSED CONCRETE BEAM TYPE I & 2
- 80' PRESTRESSED CONCRETE BEAM TYPE I & 2
- REINFORCEMENT
- CONCRETE RAILING
- LOOSE RIPRAP (300 LB.)
- GEOTEXTILE UNDER 300 LB RIPRAP, TYPE V, AOS 0.21-0.43

NOTICE TO CONTRACTORS:
CONTRACT TIME: 120 Working Days
BASIS OF AWARD

The award, if made, will be made to the lowest qualified bidder. The attention of the BIDDER is directed to the State MINIMUM WAGE RATES for this project have been with the requirements of Federal regulations governing the regulations contained in the proposal.

The Board of Supervisors hereby notifies all bidders advertisement, minority business enterprise will be afforded discriminated against on the grounds of race, color, or national origin. PLANS AND SPECIFICATIONS are on file in the Office of the State Aid Engineer, 412 E. Woodrow Wilson with the latest edition of the Mississippi Standard Specifications. PLANS AND PROPOSALS may be secured from Terrel Meridian. The Cost is twenty-five dollars (\$25.00) for check or bid bond for five percent (5%) of the total bid, in proposal.

Bidders are hereby notified that any proposal accompanied by a check or bid bond for five percent (5%) of the total bid and such proposal tendered will be considered an irregular bid and such proposal will be rejected.

Terry L. Butler, President
Smith County Board of Supervisors

(3355)
June 15, 22

SUBSTITUTED TRUSTEE'S NOTICE OF SALE

WHEREAS, on the 7th day of August, 2007, Brenda Hester, executed a Deed of Trust in favor of Community Bank of Mississippi, Beneficiary, which Deed of Trust is recorded in Deed of Trust Book 535, at pages 184-192 on August 16, 2007, in the office of the Chancery Clerk of Smith County, Mississippi;

WITNE day of Jur
STANLE
SUBSTIT
PREPARI
STANLE
SOREY &
Attorneys
P.O. Box

We're pleased to present to you this year's and services we deliver to you every day. O want you to understand the efforts we mak are committed to ensuring the quality of you

EOE
362-8608 or visit AVERITTcareers.com
Great Benefits, Paid Holidays, Call 8
Year experience, REGULAR HOME TINI
Drivers start at 37 to 41.5 cpm with
Drivers - DRIVE RED1 Regional V
MS-100, HornadyTransportation.com
Experience required, 800-441-4277
TIME! Lease purchase available
MILE!! Sign-on Bonus! GREAT HOI
DRIVERS - CDL-A, START UP TO 430 P
driveforango.com 877-826-4605
and 15 months experience requir
miles, benefits, all new trucks. CDI
Operators, Solos and Teams. Consiste
ANNOUNCED! Company, Owr
DRIVER - PAY RAISE JU
leytransport.com
required, 877-882-6537 or www.o
regional, 1 year OTR/Good M
and Dry Van positions offering so
ny seeks Solo and Team Drivers. Te
CDL-A DRIVERS, Central Florida com
Employment-Trucking
John.lieberbach@inspheris.com
John or
branch office at 800-791-4914. Ask
earn \$50K-\$100K or more. Call
SALES PROFESSIONAL NEEDED, M
Employment-Insurance
Call 850-424-2622
per week. Sign up for training tod
around \$130 per day...that's over \$5
the Marine Industry? Positions st
Interested in becoming a deckhand
INTERCOASTAL WATERWAY
Employment-General
www.CenturaOnline.com
8 8 8 - 8 9 9 - 6 9 1 4
rent Beneficiary
OUGH CERTIF-
LIST 2006-NCS,
IAN STANLEY
COMPANY AS
TSCHB BANK
of Smith County,
www.CenturaOnline.com
ber 13, 2006 and
which Deed of
ENTURY MORT-
TRICK as Trustee
ecuted a Deed of
AS TENANTS
KIE SATHOFF,
16, 2006, STEVE
Institute of Maintenance 866-455-43
placement assistance, CALL AVAL
program, financial aid if qualified -

NC IN MS
d m
ent, lers,
Y!
11
ction
NOON
sum
TION
NOON
dated RECON-
ment Beneficiary
UGH CERTIF-
LIST 2006-NCS,
IAN STANLEY
COMPANY AS
TSCHB BANK
of Smith County,
www.CenturaOnline.com
ber 13, 2006 and
which Deed of
ENTURY MORT-
TRICK as Trustee
ecuted a Deed of
AS TENANTS
KIE SATHOFF,
16, 2006, STEVE
Institute of Maintenance 866-455-43
placement assistance, CALL AVAL
program, financial aid if qualified -