



2011 JUN -1 AM 9:18

MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Pineville Water Association, Public Water Supply Name
# 065006 # 065006-01 # 065006-02 List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper
On water bills
Other

Date customers were informed: 5/18/2011 5-31-2011

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: Smith Co Reformer

Date Published: 5/18/11

CCR was posted in public places. (Attach list of locations)

Date Posted: / /

CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above.

Wanda Craft, Clerk Name/Title (President, Mayor, Owner, etc.)

5-31-2011 Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215 Phone: 601-576-7518

2010 Annual Drinking Water Quality Report  
 Pineville Water Association, Inc.  
 PWS#: 0650006, 0650017 & 0650018  
 May 2011

2011 JUN -1 AM 9:19

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand & Meridian Upper Wilcox Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Pineville Water Association have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Wanda Craft at 601-789-5005. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 7:00 PM at the office located at 8305 HWY 501.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2010. In cases where monitoring wasn't required in 2010, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID#: 0650006		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2010	.03	.01 - .03	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2010	4.2	2.1 – 4.2	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2008*	8	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2010	1.2	.9 – 1.2	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

### Volatile Organic Contaminants

76. Xylenes	N	2010	.001	No Range	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
-------------	---	------	------	----------	-----	----	----	---

### Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2010	3.76	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	.64	.5 - 1	ppm	0	MDRL = 4	Water additive used to control microbes

## PWS ID#: 0650017

## TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	-------------------	------	-----	--------------------------------

### Inorganic Contaminants

10. Barium	N	2010	.003	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2010	5.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2008*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2010	.5	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

### Volatile Organic Contaminants

76. Xylenes	N	2010	.004	.0009 - .004	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
-------------	---	------	------	--------------	-----	----	----	---

### Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2010	17.43	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	.64	.5 - 1	ppm	0	MDRL = 4	Water additive used to control microbes

## PWS ID#: 0650018

## TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	-------------------	------	-----	--------------------------------

## Inorganic Contaminants

10. Barium	N	2010	.002	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2010	8.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2008*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2010	.7	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

## Volatile Organic Contaminants

74. Toluene	N	2010	.0005	No Range	ppm	1	1	Discharge from petroleum factories
76. Xylenes	N	2010	.0001	No Range	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories

## Disinfection By-Products

81. HAA5	N	2010	10	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2010	13.1	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	.64	.5 - 1	ppm	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2010.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Pineville Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Notice: This report will not be mailed to customers, however, copies are available upon request by calling 601-789-5005.

**2010 ANNUAL DRINKING WATER QUALITY REPORT  
PINEVILLE WATER ASSOCIATION  
PWS#: 0650006 & 0650017 & 0650018 • N**

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of your water every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make in the treatment process and to protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing Wilcox Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A copy of the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The water we received a lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Wanda Craft at 601.789.5005. We are held about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 8305 Hwy. 501.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all detected during for the period of January 1st to December 31st, 2010. In cases where monitoring wasn't required in 2010, the table reflects the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial and gas production, mining or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and other sources; synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production; and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water is reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not mean a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand the terms:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water utility must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards that apply to all public water systems. MCLs are set at a level that is as protective as feasible using the best available treatment technology.

21. Selenium	N	2010	.7	No Range	ppb	oil & metal discharge from
<b>Volatile Organic Contaminants</b>						
74. Toluene	N	2010	.0005	No Range	ppm	gasoline refineries
76. Xylenes	N	2010	.0001	No Range	ppm	gasoline refineries
<b>Disinfection By-Products</b>						
81. HAA5	N	2010	10	No Range	ppb	water disinfection.
82. THM (Total trihalomethanes)	N	2010	13.1	No Range	ppb	water
Chlorine	N	2010	.64	.5 - 1	ppm	control microbes.

\* Most recent sample. No sample required for 2010.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds the health standards set by the EPA. We've learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water is safe to drink.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. Monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water. Our plumbers are trained to identify and replace lead service lines. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. For more information on lead testing, visit <http://www.epa.gov/safewater/lead>. The Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances include inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain some of these substances. The presence of these substances does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects in drinking water is available from the Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised individuals, such as cancer patients, organ transplant recipients, people with HIV/AIDS or other immune system disorders, some elderly, and infants are at a higher risk from drinking water. EPA/CDC guidelines on appropriate water treatment and other information are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Pineville Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all customers who are the heart of our community, our way of life and our children's future. \*Notice: This report will not be mailed to customers, however you can call 601.789.5005.

room. When she went to the door again, that same man was just walking out and instead of acting like she had just got there, she started telling him very embarrassing. Mary Lou and Jerry Powell spent Friday night babysitting Andrea's dog, Dud. On Saturday they enjoyed Hailey's birthday party. They also attended Hailey's dance recital recently and early June. We will be re-

**Liberty**

By Yvonne Robinson

the meal war servicemen in Prints & He is still in the Honors Bar while training and day night. Go overseas. gram and a good supper at have some Tuesday night and a ented child of folks. Our pray and his family Harold Aren a week at Disney My grandw they are having good friends Lynn Arenderd Nicky Walker the funeral home, MS Satur-

of Mississippi, Smith

NALLY CAME before me, the ned a Notary Public in and for COUNTY, MISSISSIPPI the CLERK of the SMITH Y REFORMER, a newspaper ed in the Town of Raleigh, Smith in said State, who being duly deposes and says that the SMITH Y REFORMER is a newspaper ed and prescribed in §13-3-31 of sissippi Code 1972 Annotated the publication of a notice, of the annexed is a copy, in the

Annual Drinking Water Report

made in said paper 1 times

day of May 2011

OFFICE CLERK

and subscribed before me, Carol Bowers NOTARY PUBLIC



Contaminant	Year	Level	Range	Unit	MCLG	MCL	Likely Source of Contamination	
<b>Inorganic Contaminants</b>								
10. Barium	N	2010	.003	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
13. Chromium	N	2010	5.6	No Range	ppb	100	100	Discharge from steel & pulp mills; erosion of natural deposits.
14. Copper	N	2008*	2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems, erosion of natural deposits leaching from wood preservatives.
17. Lead	N	2008*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits.
21. Selenium	N	2010	.5	No Range	ppb	50	50	Discharge from petroleum & metal of natural deposits discharge from mines.

Contaminant	Year	Level	Range	Unit	MCLG	MCL	Likely Source of Contamination	
<b>Volatle Organic Contaminants</b>								
76. Xylenes	N	2010	.004	.0009 - .004	ppm	10	10	Discharge from petroleum factories discharge from chemical factories.
<b>Disinfection By-Products</b>								
27. THM5 (Total Trihalomethanes)	N	2010	17.43	No Range	ppb	0	50	By-product of drinking water chlorination.
7. Halonitrone	N	2010	.64	.5 - 1	ppm	0	MDRL =1	Water additive used to control microbes.

Contaminant	Year	Level	Range	Unit	MCLG	MCL	Likely Source of Contamination	
<b>Inorganic Contaminants</b>								
10. Barium	N	2010	.002	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
13. Chromium	N	2010	8.6	No Range	ppb	100	100	Discharge from steel & pulp erosion of natural deposits.
14. Copper	N	2008*	2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems, erosion of natural deposits leaching from wood preservatives, from septic tanks, sewage; erosion of natural deposits.
17. Lead	N	2008*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits.
21. Selenium	N	2010	.7	No Range	ppb	50	50	Discharge from petroleum & metal of natural deposits discharge from mines.

Contaminant	Year	Level	Range	Unit	MCLG	MCL	Likely Source of Contamination	
<b>Organic Contaminants</b>								
1. Benzene	N	2010	.0005	No Range	ppm	1	1	Discharge from petroleum factories discharge from chemical factories.
4. Xylenes	N	2010	.0001	No Range	ppm	10	10	Discharge from petroleum factories discharge from chemical factories.
<b>Disinfection By-Products</b>								
27. THM5 (Total Trihalomethanes)	N	2010	10	No Range	ppb	0	50	By-product of drinking water disinfection.
7. Halonitrone	N	2010	13.1	No Range	ppb	0	80	By-product of drinking water chlorination.

For next sample, 20 samples requested by 2010.

If you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We also complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, periodic elevated level of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components in the water supply system. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water to minimize exposure to available from the State Drinking Water Hotline or at <http://www.epa.gov/leadcontaminated>. The Mississippi State Department of Health, Public Health Division offers lead testing for \$10 per sample. Please contact 601-576-7523 if you wish to have your water tested.

If sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These vulnerable populations are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Private Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help to protect our water sources, which are the heart of our community, one way or the other and our children's future. \*Notice: This report will not be mailed to customers, however, copies are available upon request by calling 601-789-5005.

ACCOUNTING SERVICE FROM SERVICES TO  
 010001000 04/26 05/26  
 SERVICE ADDRESS  
 10994 HWY 501  
 WILKESBORO, NC 28696  
 6790 6759 31  
 CHARGE FOR SERVICE

RETURN THIS STUB WITH PAYMENT TO:  
 PENNELL WATER ASSN  
 P.O. BOX 1000  
 WILKESBORO, NC 28696  
 6790 6759 31  
 AMOUNT DUE  
 20.85  
 PAY DATE  
 06/15/2011  
 PAY OFF BY  
 20.00  
 AMOUNT PAID  
 40.85

CCR IS AVAILABLE UPON REQUEST  
 RETURN SERVICE REQUESTED  
 010001000  
 WILLIS R. VAUGHN  
 10994 HWY 501  
 FOREST, MS 39074

WTR 20.85  
 NET DUE >>> 20.85  
 SAVE THIS >>> 20.00  
 GROSS DUE >>> 40.85

011 APR 11 11 AM 9:18  
 WILKESBORO, NC

5/18/11

\*\* INVOICE \*\*

Page 1

Smith County Reformer  
Acctg. only 601-825-4004  
P.O. Box 103  
BRANDON, MS 39043-0103  
Telephone 601-782-4358

Invoice # 64785  
Invoice Date 5/18/11  
64785

Bill To: Pineville Water Assoc. 13  
P.O. Box 37

Deliver To: Pineville Water Assoc. 13  
P.O. Box 37

Raleigh, MS 39153

Raleigh, MS 39153

Customer #: 8119

Your PO:

Terms: due by the 10th

Item-#	Description	Qty	Unit	Price	Ext-price
	\$6.50 per column inch 4x21.5 column inch ad 2010 Annual Drinking Water Quality Report	84.0	EACH	6.50	546.00
	Proof	1.0	EACH	3.00	3.00

TOTAL	549.00
Sales Tax	0.00
Discount	
BALANCE DUE --->	549.00

SMITH COUNTY REFORMER  
5/18/11 4:18