



2011 JUN 13 AM 0:41

MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

Town of Liberty Water System
Public Water Supply Name

0030004
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: ___ / ___ / ___

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:
Date Mailed/Distributed: ___ / ___ / ___

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*
Name of Newspaper: Enterprise Journal
Date Published: 6 /21 / 2011

- CCR was posted in public places. *(Attach list of locations)*
Date Posted: ___ / ___ / ___

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

[Signature] Mayor
Name/Title (President, Mayor, Owner, etc.)

06/26/2011
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

10

2010 TOWN OF LIBERTY WATER SYSTEM CONSUMER CONFIDENCE REPORT

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Town of Liberty water comes from two wells in the Miocene series aquifer.

Source water assessment and its availability

Questions regarding the availability of a source water assessment should be directed to Liberty Town Hall at 601-657-8071.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment

runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Any interested individual may attend the monthly meeting of the Mayor and Board of Aldermen the first Tuesday of each month at 5:00 pm at Town Hall, 160 Clinic Drive, Liberty, MS.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your

community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Results of voluntary monitoring

The Town of Liberty completed all required monitoring.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. TOWN OF LIBERTY is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will

find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG	MCL,	Your	Range		Sample	Violation	Typical Source
	or	TT, or		Low	High			
	MRDLG	MRDL	Water			Date		
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	1.5	1	1.5	2010	No	Water additive used to control microbes
Inorganic Contaminants								
Nitrate [measured as Nitrogen] (ppm)	10	10	0.48	NA		2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.05	NA		2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Volatile Organic Contaminants								
1,2,4-Trichlorobenzene (ppb)	70	70	0.5	0.5	0.5	2010	No	Discharge from textile-finishing factories
cis-1,2-Dichloroethylene (ppb)	70	70	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Xylenes (ppm)	10	10	0.0005	0.0005	0.00147	2010	No	Discharge from petroleum factories; Discharge from chemical factories
Dichloromethane (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from pharmaceutical and chemical factories
o-Dichlorobenzene (ppb)	600	600	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Vinyl Chloride (ppb)	0	2	0.5	0.5	0.5	2010	No	Leaching from PVC piping; Discharge from plastics factories
1,1-Dichloroethylene (ppb)	7	7	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
1,1,1-Trichloroethane (ppb)	200	200	0.5	0.5	0.5	2010	No	Discharge from metal degreasing sites and other factories

Carbon Tetrachloride (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from chemical plants and other industrial activities
1,2-Dichloropropane (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Tetrachloroethylene (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from factories and dry cleaners
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	0.5	0.5	2010	No	Discharge from chemical and agricultural chemical factories
Benzene (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from factories; Leaching from gas storage tanks and landfills
Toluene (ppm)	1	1	0.5	0.5	0.5	2010	No	Discharge from petroleum factories
Ethylbenzene (ppb)	700	700	0.5	0.5	0.5	2010	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	0.5	0.5	0.5	2010	No	Discharge from rubber and plastic factories; Leaching from landfills
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Lead - action level at consumer taps (ppb)	0	15	1	2010	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Copper - action level at consumer taps (ppm)	1.3	1.3	0	2010	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Shawn B. Felder
Address:
PO Box 301
Liberty, MS 39645
Phone: 601-657-8071
Fax: 601-657-8078
E-Mail: townoflibertyms@yahoo.com

STATE OF MISSISSIPPI,
COUNTY OF PIKE

PERSONALLY CAME before me, the undersigned, a notary public in and for PIKE County, Mississippi, the CLERK of the McCOMB ENTERPRISE-JOURNAL, a newspaper published in the City of McComb, Pike County, in said state who being duly sworn, deposes and says that the McCOMB ENTERPRISE-JOURNAL is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858, of the Mississippi Code of 1942, and that the publication of a notice, of which the annexed is a copy in the

matter of _____

has been made in said paper 1 times consecutively, to wit:

On the 21 day of June, 20 11

On the _____ day of _____, 20 _____


On the _____ day of _____, 20 _____

On the _____ day of _____, 20 _____

On the _____ day of _____, 20 _____

On the _____ day of _____, 20 _____

On the _____ day of _____, 20 _____



SWORN TO and subscribed before me, this _____ day of _____, 20 _____

My Commission Expires _____

Clerk

McComb, Miss. _____, 20 _____

To McComb Enterprise-Journal

TO PUBLISHING _____

case of _____

_____ words space _____

_____ times and making proof, \$ 966.84

RECEIVED OF _____

payment in full of the above account.

_____, 20 _____

TOWN OF LIBERTY

2010 Consumer Confidence Report

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Most of Liberty water comes from two wells in the Mico area aquifer.

Source water assessment and its reliability

Questions regarding the availability of a source water assessment should be directed to Liberty Town Hall at 601-657-8071.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in surface water include sediment, silt, and bacteria. Contaminants that may be present in groundwater include pesticides, herbicides, and fertilizers. Other contaminants that may be present in surface water include: organic chemicals, such as solvents and herbicides, and inorganic chemicals, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, and farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential use; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Any interested individual may attend the monthly meeting of the Mayor and Board of Aldermen the first Tuesday of each month at 5:00 pm at Town Hall, 160 Clinic Drive, Liberty, MS.

Disinfection of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 140 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference—try one today and soon it will become second nature.

- Take shorter showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 20 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and use up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaks toilet and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as long as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill.
- Visit www.epa.gov/waterSense for more information.

Source Water Protection Tips

- Prevention of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways.
- Minimize excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly, take used motor oil to a recycling center.
- Volunteer in your community. Join a watershed or watershed protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain cleaning project with your local government or water supplier. Send a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. TOWN OF LIBERTY is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring substances may actually improve the taste of drinking water and are beneficial to you at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

MLL	Unit	Year	Range	Sample	Location	Tap or Source
Contaminant	ML/DG	MRO	Water	Tap	ML/DG	Location

Alice
 Bruce
 Mrs.
 198
 Mr.
 Ince
 rec.
 379

 Mrs.
 ng-
 ny
 ve.;
 Mrs.
 mel
 Mrs.
 St.

 and
 Lee-
 vice.
 301.
 and
 side
 ed
 ri-
 046

 Mrs.
 ewis
 and
 ewis
 3092
 Mrs.
 Mon-
 Club

 minor

 re 21,
 lls of
 chas-
 total
 tds.
 ting

 21,
 21
 9
 5

Residuals & Exceeds by Analyte
(Values compare against the published (or alternative) MCLG for each of the listed constituent)

Constituent (MCLG)	1	4	1.5	1	1.5	2010	Exceeds	Source
Chlorine gas (Cl2) (ppm)	4	4	1.5	1	1.5	2010	No	Water additive used to control microbes
Inorganic Organics								
Nitrate (measured as Nitrogen) (ppm)	10	10	0.48	NA		2010	No	Runoff from fertilizer use; Leaching from septic tanks; sewage; Proxion of natural deposits
Nitrite (measured as Nitrogen) (ppm)	1	1	0.05	NA		2010	No	Runoff from fertilizer use; Leaching from septic tanks; sewage; Proxion of natural deposits
Volatle Organic Compounds								
1,2,4-Trichloroethane (ppb)	70	70	0.5	0.5	0.5	2010	No	Discharge from textile-finishing factories
cis-1,2-Dichloroethane (ppb)	70	70	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Xylenes (ppm)	10	10	0.0005	0.0005	0.00147	2010	No	Discharge from petroleum factories; Discharge from chemical factories
1,1-Dichloroethane (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from pharmaceutical and chemical factories
o-Dichlorobenzene (ppb)	600	650	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Vinyl Chloride (ppb)	0	2	0.5	0.5	0.5	2010	No	Leaching from PVC piping; Discharge from plastics factories
1,1-Dichloroethylene (ppb)	7	7	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
1,1,1-Trichloroethane (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
1,1,1-Trichloroethane (ppb)	200	200	0.5	0.5	0.5	2010	No	Discharge from metal-depositing sites and other sites
Carbon Tetrachloride (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from chemical plants and other industrial activities
1,2-Dichloropropane (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from metal-depositing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Tetrahydrofuran (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from factories and dry cleaners
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	0.5	0.5	2010	No	Discharge from chemical and agricultural chemical factories
Bromine (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from factories; Leaching from gas storage tanks and fuelfills
toluene (ppm)	1	1	0.5	0.5	0.5	2010	No	Discharge from petroleum factories
Biphenylene (ppb)	200	250	0.5	0.5	0.5	2010	No	Discharge from petroleum refineries
styrene (ppb)	100	100	0.5	0.5	0.5	2010	No	Discharge from rubber and plastic factories; Leaching from landfills
Corrosion								
Corrosion of household lead-acid action level of consumer taps (ppb)	MCLG	MCLG	Year	Sample	# Samples	Exceeds	AL	Typical Source
Corrosion of household lead-acid action level of consumer taps (ppb)	0	15	1	1	2010	0	No	Corrosion of household plumbing systems; Proxion of natural deposits
Corrosion of household lead-acid action level of consumer taps (ppb)	1.3	1.3	0	2010	0	No	Corrosion of household plumbing systems; Proxion of natural deposits	
Drinking Water Disinfection								
Units	Definition							
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health.							
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.							
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.							
M	M: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.							
Variance and Exemption	Variance and Exemption: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.							
MRLG	MRLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.							
MRL	MRL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.							
MNR	MNR: Monitored Not Regulated							
MFL	MFL: State Assisted Maximum Permissible Level							

For more information please contact: Sharon B. DeAr
 Address: P.O. Box 301, Liberty, MS 39015
 Phone: 601-457-8071 or 601-457-8072
 Email: sharonb@cityofliberty.com

TOWN OF LIBERTY

County Seat of Amite County, MS



160 CLINIC DRIVE P.O. BOX 301
LIBERTY, MISSISSIPPI 39645
PHONE (601) 657-8071 FAX (601) 657-8078 EMAIL townoflibertyms@yahoo.com

July 11, 2011

Melissa Parker
Mississippi State Department of Health
Division of Water Supply
P.O. Box 1700
Jackson, MS 39215

RE: Town of Liberty 2010 Consumer Confidence Report

Dear Ms. Parker:

Please find enclosed the original certification form for the 2010 Town of Liberty Consumer Confidence Report along with a copy of the published report from the Enterprise Journal and the proof of publication. The 2010 Consumer Confidence report for the Town of Liberty Water System was published on June 21, 2011.

I had faxed a copy of the certification, the report and the proof on 6/30/2011, because I had not received the originals. I just received the proof of publication and the tear sheets today.

Should you have any questions, please feel free to contact me at the above referenced number.

Sincerely,

Shawn B. Felder
Town Clerk

Enclosure

LIBERTY---IT WORKS
SINCE 1809