



2011 JUN 27 AM 9:49

MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

SOUTH TERRY WATER
Public Water Supply Name
025 0023
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
Advertisement in local paper
On water bills
Other

Date customers were informed: 6/23/11

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: Hinds Co. Gazette

Date Published: 6/2/11

- CCR was posted in public places. (Attach list of locations)

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above.

Signature of official (Name/Title)

Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT  
CERTIFICATION REPORT  
SOUTH TERRY WATER ASSOCIATION  
PWS ID # ('s): 0250023

2011 JUN 27 AM 9:49

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

**Please Answer the Following Questions Regarding the Consumer Confidence Report**

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill, or other)*
- Advertisement in local paper  
 On water bills 6/23/11  
 Other \_\_\_\_\_

Date customers were informed: 6/2/11 Hinds Co. Gazette

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:  
Date mailed/distributed: \_\_\_\_\_

- CCR was published in local newspaper. *(Attach copy of published CCR and proof of publication)*  
Name of Newspaper: Hinds Co. Gazette  
Date Published: 6/2/11

- CCR was posted in public places. *(Attach list of locations)*  
Date posted: \_\_\_\_\_

- CCR was posted on a publicly accessible internet site at the address: www: \_\_\_\_\_

**CERTIFICATION:**

I hereby certify that a Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Sylvia M. Davis, J.D. (office manager) 6/23/11  
Name/Title (President, Mayor, Owner, etc.) Date

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Susan Bayliss 5-18-11  
Signature Date

**Mail completed form along with a copy of your CCR Report to:**  
**MS State Department of Health**  
**Division of Public Water Supply**  
**P O Box 1700**  
**Jackson, MS 39215**  
**Phone: 601-576-7518**

*Annual Drinking Water Quality Report*  
*South Terry Water Association*  
 PWS ID # 0250023  
 May, 2011

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells that draw from the Forest Hill Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination.. The water supply for South Terry Water Association received a lower susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Sylvia McDavid at 601-878-5308. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday every 3 (three) months at 2428 Old Hwy 51 in Terry, MS at 7:00 p.m.

South Terry Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31<sup>st</sup>, 2010. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2008*	0.009	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2008*	1	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	0.3	None	ppm	1.3	1.3	Corrosion of household plumbing

Contaminants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you...

which there is no known or expected risk to health. MCLs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2008*	0.009	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2008*	1	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	0.3	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2008*	0.5	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	2	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfectants &amp; Disinfection By-Products</b>								
Chlorine (as Cl <sub>2</sub> )	N	Jan-Dec	0.60 to 1.10	None	ppm	4	4	Water additive used to treat microbes
73. THM (Total trihalo-methanes)	N		36	None	ppb	0	80	By-product of drinking water chlorination
HAA5	N		30	None	ppb	0	60	By-product of drinking water chlorination

\* Most recent sample results available

#### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. South Terry Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

STATE OF MISSISSIPPI )  
 )  
COUNTY OF HINDS )

**PERSONALLY CAME** before me, a notary public in and for the State of Mississippi at Large, the **CLERK** of the *HINDS COUNTY GAZETTE*, a newspaper published in the City of Raymond, Second Judicial District of Hinds County, in said state, who being duly sworn, deposes and says that the *HINDS COUNTY GAZETTE* is a newspaper as defined and prescribed in the Mississippi Code of 1972, and the publication of a notice of which the annexed is a copy, in the matter of:

Annual Drinking Water Quality  
Report

South Terry Water Assn.

PWS ID# 0250023

Has been made in said paper 1 times consecutively, to-wit:

On the 2 day of June, 2011

On the \_\_\_\_\_ day of \_\_\_\_\_, 2011

On the \_\_\_\_\_ day of \_\_\_\_\_, 2011

On the \_\_\_\_\_ day of \_\_\_\_\_, 2011

**SWORN TO and SUBSCRIBED** before me, this

2 day of June, 2011

Mary Ann Keith  
Notary Public

Heather R Lupton  
Clerk

**TO PUBLISHING** To HINDS COUNTY GAZETTE Dr.  
Case of MARY ANN KEITH  
Word space \_\_\_\_\_ Weeks \_\_\_\_\_ Proof Charge \$3.00 -- Total \$ \_\_\_\_\_  
Commission Expires Sept 18, 2012

**RECEIVED OF** \_\_\_\_\_

Check No. \_\_\_\_\_ Date \_\_\_\_\_

South Terry Water Assoc.  
 POBox 298, Terry MS 39170  
 Bills & Accounts 878-8308

FIRST CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 7  
 PERMIT NO.

DATE	AMOUNT	DEBIT	CREDIT	BALANCE
Water	347000	344000	3,000	27.00

South Terry Water Assoc.

ACCOUNT NO.	107	DATE DUE	7/14/11
AMOUNT DUE	27.00	AMOUNT PAID	32.00

MAIL THIS STUFF WITH YOUR PAYMENT

2428 OLD HWY 51  
 IF PASTDUE 60 DAYS DUE FOR CUTOFF

DATE	AMOUNT	DEBIT	CREDIT	BALANCE
6	19	1		27.00
			5.00	32.00

SYLVIA McDAVID  
 2428 OLD HWY 51  
 TERRY MS 39170-9604

A COPY OF THE 2011 CONSUMER CONFIDENCE REPORT  
 IS AVAILABLE UPON REQUEST AT THE SOUTH TERRY WATER OFFICE  
 PLEASE CALL 601-878-8308 TO REQUEST A COPY.