



2011 JUN 22 AM 9:04

MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Cold Springs Water Association
Southwest Covington Water Association
Public Water Supply Name

160009; 160001
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
Advertisement in local paper
On water bills
Other

Date customers were informed: 6/8/11

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: The News Commercial

Date Published: / /

- CCR was posted in public places. (Attach list of locations)

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above.

James C. Ausok, President
Name/Title (President, Mayor, Owner, etc.)

6/20/11
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

5

2011-01-2 AM 9:13

2010 Annual Drinking Water Quality Report
 Southwest Covington Utility Association & Cold Springs Water Association
 PWS#: 160009 & 160001
 May 2011

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Southwest Covington Utility Association have received lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Barry Mayfield at 601-722-4447. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Tuesday of the month at 4:00 PM at the office building located at 597 Union Church Rd, Seminary, MS.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2010. In cases where monitoring wasn't required in 2010, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS# 160009		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2008*	.004	.003 - .004	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2010	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2008*	.151	.144 - 1.51	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2010	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products								
82. TTHM [Total trihalomethanes]	N	2008*	9.48	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	.55	.47 - .67	ppm	0	MDRL = 4	Water additive used to control microbes

PWS ID#: 160001 TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination

Inorganic Contaminants								
10. Barium	N	2008*	.007	.006 - .007	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2008*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2008*	.269	.222 - .269	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	6	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2008*	.559	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products								
82. TTHM [Total trihalomethanes]	N	2008*	12.68	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	.53	.4 - .8	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2010.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Southwest Covington Utility Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Notice: This report will not be mailed out to each customer, however a copy can be obtained at our office.

2011 JUN 22 AM 9:04

Proof of Publication

STATE OF MISSISSIPPI
COVINGTON COUNTY

PERSONALLY APPEARED before me, the undersigned authority, in and for said County and State, **Analyn Arrington Goff**, Publisher of **THE NEWS-COMMERCIAL**, a newspaper published in Collins, said County, who being duly sworn, says the publication of a certain notice, a true copy of which is hereto attached, was made in said paper on the hereinafter dates, as follows, to-wit:

Vol. 109 No. 47 Dated June 8, 2011
Vol. _____ No. _____ Dated _____
Vol. _____ No. _____ Dated _____
Vol. _____ No. _____ Dated _____

Analyn A. Goff Publisher

Sworn to and subscribed before me, this the 8 day of June, 2011.

James Arrington Goff Notary Public

Printer's Fee \$ 144.00
Proof of Publication \$ 3.00
TOTAL \$ 147.00



2010 Annual Drinking Water Quality Report
 Southeast Connecticut Utility Association & Cold Spring Water Association
 PWS# 160009 & 160001
 May 2011

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water you receive and to provide you with a clear and comprehensive picture of the drinking water supply in your area. We want you to understand the quality of the water you receive and to be able to make informed decisions about the quality of the water you receive. We are committed to ensuring the quality of your water. For more information, please contact the Connecticut Department of Public Health.

The water we supply is produced by our water treatment system. The water treatment system is designed to remove the contaminants that are naturally occurring in the water. The water treatment system is designed to remove the contaminants that are naturally occurring in the water. The water treatment system is designed to remove the contaminants that are naturally occurring in the water. The water treatment system is designed to remove the contaminants that are naturally occurring in the water.

If you have any questions about this report or concerning your water, please contact us at 1-800-455-6271. We want our water customers to be informed about the water they are using. If you want to learn more, please contact us at 1-800-455-6271. We want our water customers to be informed about the water they are using. If you want to learn more, please contact us at 1-800-455-6271.

TEST RESULTS

Contaminant	Unit	Level Detected	Range of Detectable Levels	Unit Measure	MCL	MCLG	Priority Contaminant	Priority Contaminant
15. Barium	ppm	0.04	0.01 - 0.04	ppm	2	1	2	Excessive of drinking water, primarily from natural sources, such as geologic deposits.
14. Copper	ppm	0.02	0 - 0.02	ppm	1.3	1.3	AL1-3	Corrosion of lead-containing plumbing systems, release of lead into drinking water from solder.
16. Lead	ppm	0.01	0 - 0.01	ppm	1.5	1.5	4	Excessive of natural deposits, water from lead-containing solder, and corrosion of lead-containing plumbing systems.
17. Nitrate	ppm	0	0 - 0	ppm	10	10	AL1-5	Excessive of natural deposits, water from lead-containing solder, and corrosion of lead-containing plumbing systems.

Disinfection By-Products

Contaminant	Unit	Level Detected	Range of Detectable Levels	Unit Measure	MCL	MCLG	Priority Contaminant
12. Trihalomethanes	ppm	0.02	0 - 0.02	ppm	0.1	0.1	0
13. Haloacetic Acids	ppm	0.01	0 - 0.01	ppm	0.07	0.07	0

TEST RESULTS

Contaminant	Unit	Level Detected	Range of Detectable Levels	Unit Measure	MCL	MCLG	Priority Contaminant
15. Barium	ppm	0.04	0.01 - 0.04	ppm	2	1	2
14. Copper	ppm	0.02	0 - 0.02	ppm	1.3	1.3	AL1-3
16. Lead	ppm	0.01	0 - 0.01	ppm	1.5	1.5	4
17. Nitrate	ppm	0	0 - 0	ppm	10	10	AL1-5

Disinfection By-Products

Contaminant	Unit	Level Detected	Range of Detectable Levels	Unit Measure	MCL	MCLG	Priority Contaminant
12. Trihalomethanes	ppm	0.02	0 - 0.02	ppm	0.1	0.1	0
13. Haloacetic Acids	ppm	0.01	0 - 0.01	ppm	0.07	0.07	0

The water we supply is produced by our water treatment system. The water treatment system is designed to remove the contaminants that are naturally occurring in the water. The water treatment system is designed to remove the contaminants that are naturally occurring in the water. The water treatment system is designed to remove the contaminants that are naturally occurring in the water.

If you have any questions about this report or concerning your water, please contact us at 1-800-455-6271. We want our water customers to be informed about the water they are using. If you want to learn more, please contact us at 1-800-455-6271. We want our water customers to be informed about the water they are using. If you want to learn more, please contact us at 1-800-455-6271.

Printed on: June 8, 2011