



2011 JUL 27 10:55

MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

KIPLING WATER ASSN
Public Water Supply Name

350002 350008 350019
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper
On water bills
Other

Date customers were informed: 6/16/11

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 1/1

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: KEMPER COUNTY MESSENGER

Date Published: 6/16/11

CCR was posted in public places. (Attach list of locations)

Date Posted: 6/15/11 EAST MS ELECTRIC POWER ASSN, DEKALB OFFICE
DEKALB PUBIC LIBRARY

CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above.

Art Ruster
Name/Title (President, Mayor, Owner, etc.)

6-27-2011
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

570 East Woodrow Wilson • Post Office Box 1700 • Jackson, Mississippi 39215-1700
601/576-7634 • Fax 601/576-7931 • www.HealthyMS.com

Equal Opportunity In Employment/Service

2

BREAKFAST

Monday Morning, June 19 at 8:30 AM will host a Courageous Breakfast. Great and helpful food. Wonderful fellowship and beneficial information for all men 13 years of age and up. We believe that most want the very best for their present and future families. It is courage to stand against odds and sacrificially do what is best for one's family. Whether attend BSBC, or not, I hope you will join us as we learn something about it and take a courageous stand for those we love. 1 young man and old will pose to be at BSBC at 8 a.m. June 19.

MS PECAN FESTIVAL
We are currently taking applications for Arts and Crafts, Antiques and Collectibles and Children's Activities for this year's festival. The 4th Annual Pecan Festival will hold on Sept. 23, 24, and 25. Richton. If interested call 601-4-8201 or 601-964-8222 or contact us at our Web site www.MsPecanFestival.com

WESTERFIELD, CLAY ORNE, AND RUSH FAMILY REUNION 2011
"The Gathering of the

Eagles" Isaiah 40:31, July 1-3, Biloxi. Any questions, comments, or concerns please contact: Antoinette Rush Cherry, P.O. Box 1043, DeKalb, MS 39328 601-677-2390 (home) or 601-507-7346 (cell) or at cherryantoinette@hotmail.com

DONALD & GRADY FAMILY REUNION
To the decedents of Inez Donald and Tom Grady, we are

pleased to announce that we are planning our first annual Donald/Grady Family Reunion. Please contact the following people for more information:
James Grady 601-743-9720 / 601-616-6731; Theotis Cole 601-751-0880 / 601-743-2335; Denise Scales 601-743-9545 / 601-490-1036; or Annie Pedon 601-577-2177 / 601-710-2606.
This event has been tentatively scheduled for July 2-3, 2011.

PUBLIC AUCTION
Annual Summer Contractors Public Auction

Friday, June 17 and Saturday, June 18, 2011 Begins 9 A.M. Each Day!

Day 1 Will Feature: Construction Equipment, Attachments, Trucks One Ton & Larger, Trailers.
Day 2 Will Feature: Farm Tractors, Farm Implements, Cars & Trucks, Campers and Miscellaneous Items.

Hwy 49 South of Hattiesburg, Brooklyn, MS
www.mmaofms.com



MARTIN & MARTIN
Auctioneers of MS, Inc.
Jeff Martin, MSAL# 1255 601-450-6200

2010 DRINKING WATER QUALITY REPORT
KIPLING WATER ASSOCIATION #1, 2 & 3

This report is a snapshot of last year's water quality. Included are details of where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).
Our water source for each system consists of two wells pumping groundwater from the Lower Witcox Aquifer. Our source water assessment has been reevaluated. This assessment details the systems' susceptibility to potential sources of contamination. A moderate to high susceptibility was found for System #1. A moderate susceptibility was found for System #2 and a lower susceptibility was found for System #3.
Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking

Our board members... We encourage all customers who have... DeKalb, MS. Our annual membership meeting will be held August 9 at 7 p.m. in the courtroom of the Kemper County Courthouse.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Kipling Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Lab offers lead testing for \$10 per sample. Please contact 1-601-576-7582 if you wish to have your water tested.

WATER QUALITY DATA TABLE

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data from this table is from testing done in the calendar year of the report. The EPA and/or the State requires us to monitor for certain contaminants less than once a year because the concentrations of the contaminants do not change frequently. In this table you will find many terms and abbreviations you may not be familiar with. To help you better understand these terms we've provided the following definitions:
Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Contaminant	Unit	Level	Frequency	Source	Health Effect
DRINKING WATER DISINFECTANTS					
Chlorine (as Cl ₂)	mg/L	0.05	None	ppm	4
Chlorine Dioxide (as ClO ₂)	mg/L	0.05	None	ppm	4
DRINKING WATER DISINFECTANTS BY-PRODUCTS					
Trihalomethanes (THMs)	mg/L	0.10	None	ppm	4
DRINKING WATER DISINFECTANTS BY-PRODUCTS					
Halocarbon	mg/L	0.10	None	ppm	4
DRINKING WATER DISINFECTANTS BY-PRODUCTS					
Chloroform	mg/L	0.10	None	ppm	4

"To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the Town of DeKalb is required to report certain results pertaining to fluoridation of their water which is supplied to Kipling Water Association #3. The number of months in the previous calendar year that average fluoride sample results were in the optimal range of 0.7-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was in the optimal range of 0.7-1.3 ppm was 100%.

As you can see by the table, our water systems had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. If you have any questions about this report or concerning your water utility, please contact our senior certified water operator, W.H. Dixon, Jr. at 1-601-743-5800. Copies of this report will not be mailed out individually, but are available at the DeKalb EM/EP/EA office. Further information, including the State Auditor's Report, is available at the DeKalb Public Library.