



MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Lincoln Rural Water Association
Public Water Supply Name

0430028, 0430030, 430031, 430032, 430003
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
Advertisement in local paper
On water bills
Other

Date customers were informed: 6/10/11

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: Daily Leader

Date Published: 6/10/11

- CCR was posted in public places. (Attach list of locations) Office

Date Posted: 6/10/11

- CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above.

Tommy Cupit
Name/Title (President, Mayor, Owner, etc.)

6/2
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

QUALITY ON Tap Report
LINCOLN RURAL WATER ASSOCIATION
PWI ID# 430028,430027,430030,430031,430032,430003
June 1, 2011

Lincoln Rural Water is pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well pumping from the Catahoula Aquifer. Lincoln Rural Water is pleased to report that our drinking water meets all federal and state requirements. The following reports show our water quality and what it means.

If you have any question about this report or concerning your water utility, please contact Billy Walker at 1536 Monticello St., Brookhaven, Ms. 601-833-6449. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regular scheduled meetings. They are held on the 3rd Tuesday of each month at the above location at 7:00 P.M. and our Annual meeting is held on the 3rd Monday of March at the Lincoln County Courthouse at 7:00 P.M.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detail information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for Lincoln Rural Water have received a moderate and lower ranking in terms of susceptibility to contamination.

Lincoln Rural Water Association routinely monitors for as many as 154 constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st 2010. All drinking water, including bottled drinking water, may be reasonably expected to contain at least a small amount of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health, MCLGs allow for a margin of safety.

Addition information for Lead

If present elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/sagewater/lead>. The Mississippi State Department of Health Laboratory offers lead testing for \$20. per sample. Please contact 601.576.7582 if you wish to have your water tested.

PSI:#430028

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl2) (ppm)	4	4	1.15	1.05	1.38	2010	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	.03	NA		2007	No	By-product of drinking water chlorination
Inorganic Contaminants								
Arsenic (ppm)	5	5	.000509	NA		2009	No	Erosion of natural deposits, runoff from metal refineries; Erosion of natural deposits
Barium (ppm)	2	2	0.004091	NA		2009	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	1	2010		1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	0.015	2010		2	No	Corrosion of household plumbing systems; Erosion of natural deposits

PSI:#430027

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl2) (ppm)	4	4	.98	.98	1.33	2010	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	.03	NA		2007	No	By-product of drinking water chlorination
Barium (ppm)	2	2	0.030483	NA		2009	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Nitrate [measured as Nitrogen] (ppm)	10	10	0.71	NA		2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.72	NA		2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Copper - action level at consumer taps (ppm)	1.3	1.3	0.109	2008		1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	.015	0.001	2008		2	No	Corrosion of household plumbing systems; Erosion of natural deposits

SI#430030

<u>Contaminants</u>	<u>MCLG</u>	<u>MCL,</u>	<u>Your</u> <u>Water</u>	<u>Range</u>		<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
	<u>or</u> <u>MRDLG</u>	<u>TT, or</u> <u>MRDL</u>		<u>Low</u>	<u>High</u>			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl ₂) (ppm)	4	4	1.09	.99	1.47	2010	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	12	NA		2010	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	18	NA		2010	No	By-product of drinking water disinfection
Inorganic Contaminants								
Arsenic (ppb)	0	10	0.000868	NA		2009	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.002153	NA		2009	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	100	100	0.000759	NA		2009	No	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	4	4	2.49	NA		2009	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Copper - action level at consumer taps (ppm)		1.3	1	0.2	2007	1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)		0	11	0.002	2007	2	No	Corrosion of household plumbing systems; Erosion of natural deposits

Test Results

PSI:#430031

<u>Contaminants</u>	<u>MCLG or MRDLG</u>	<u>MCL, TT, or MRDL</u>	<u>Your Water</u>	<u>Range Low High</u>	<u>Sample Date</u>	<u>Violation</u>	<u>Typical Source</u>
Disinfectants & Disinfection By-Products							
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)							
Chlorine (as Cl ₂) (ppm)	4	4	.98	.98 1.10	2010	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	.03	NA	2007	No	By-product of drinking water chlorination
Inorganic Contaminants							
Nitrite [measured as Nitrogen] (ppm)	1	1	0.1	NA	2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Arsenic (ppm)	5	5	.003314	NA	2009	No	Erosion of natural deposits, runoff from metal refineries: Erosion of natural deposits
Barium (ppm)	2	2	0.062805	NA	2009	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.109	NA	2009	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Selenium (ppm)	5	5	.013206	NA	2009	No	Discharge from petroleum and metal refineries: erosion of natural deposits, discharge from mines
Copper - action level at consumer taps (ppm)	1.3	1.3	.1	2010	1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	.1	2010	2	No	Corrosion of household plumbing systems; Erosion of natural deposits

PSI #430032

Contaminants	MCLG	MCL,	Your	Range		Sample	Violation	Typical Source
	or	TT, or		Lo	High			
	MRDL	MRDL	Water	w		Date		
	G							
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl2) (ppm)	4	4	1.05	.97	1.15	2010	No	Water additive used to control microbes
TTHMS (Total Trihalomethanes)(ppb)	NA	80	8.16			2009	No	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	NA	60	0	NA		2009	No	By-product of drinking water chlorination
Barium (ppm)	2	2	0.00169 2	NA		2006	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	100	100	0.001110	NA		2009	No	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	4	4	.144	NA		2009	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and
Nitrate [measured as Nitrogen] (ppm)	10	10	.2	NA		2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.25	NA		2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	1	2010		1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	3	2010		2	No	Corrosion of household plumbing systems; Erosion of natural deposits

PSI: #430003

<u>Contaminants</u>	<u>MCLG or MRDLG</u>	<u>MCL, TT, or MRDL</u>	<u>Your Water</u>	<u>Range Low High</u>	<u>Sample Date</u>	<u>Violation</u>	<u>Typical Source</u>
Disinfectants & Disinfection By-Products							
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)							
Chlorine (as Cl ₂) (ppm)	4	4	1.06	1.00 1.06	2010	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	.8	NA	2007	No	By-product of drinking water chlorination
Inorganic Contaminants							
Barium (ppm)	2	2	0.038859	NA	2009	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.1	NA	2007	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	.2	NA	2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	.2	NA	2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Copper - action level at consumer taps (ppm)	1.3	1.3	0.1	2008	1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	0.003	2008	2	No	Corrosion of household plumbing systems; Erosion of natural deposits

As you can see by the table our system had no violations. We are proud that your drinking water meets or exceeds all Federal and State requirements.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have any questions.

PROOF OF PUBLICATION
THE STATE OF MISSISSIPPI
LINCOLN COUNTY

2011 JUN 27 AM 9:50

PERSONALLY appeared before me, the undersigned notary public in and for Lincoln County, Mississippi, WILLIAM O. JACOBS, an authorized representative of a newspaper as defined and described in Sections 13-3-31 and 13-3-32 of the Mississippi Code of 1972, as amended, who being duly sworn, states that the notice, a true copy of which hereto attached, appeared in the issues of said newspaper as follows:

Date JUNE 10, 2011
Date _____, 20____
Date _____, 20____
Date _____, 20____
Date _____, 20____
Date _____, 20____

Number of Words _____

Published 1 (ONE) Times

Total \$ 1362.24

Signed _____

Authorized Representative of
THE DAILY LEADER

SWORN to and subscribed before me the 13TH day of JUNE, 2011.

My Commission Expires:

OCTOBER 17, 2014



Amanda S. Dann
Notary Public

QUALITY ON Tap Report
LINCOLN RURAL WATER ASSOCIATION
PWI ID# 430028, 430030, 430031, 430032, 430003
June 1, 2011

Lincoln Rural Water is pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well pumping from the Catahoula Aquifer. Lincoln Rural Water is pleased to report that our drinking water meets all federal and state requirements. The following reports show our water quality and what it means.

If you have any question about this report or concerning your water utility, please contact Billy Walker at 1536 Monticello St., Brookhaven, Ms. 601-833-6449. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regular scheduled meetings. They are held on the 3rd Tuesday of each month at the above location at 7:00 P.M. and our Annual meeting is held on the 3rd Monday of March at the Lincoln County Courthouse at 7:00 P.M.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detail information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for Lincoln Rural Water have received a moderate and lower ranking in terms of susceptibility to contamination.

Lincoln Rural Water Association routinely monitors for as many as 154 constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st 2010. All drinking water, including bottled drinking water, may be reasonably expected to contain at least a small amount of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health, MCLGs allow for margin of safety.

Addition information for Lead
 If present elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Laboratory offers lead testing for \$20. per sample. Please contact 601.576.7582 if you wish to have your water tested.

PSI#430028	MCL		Year	Barrel	Sample	Location	Description
	MCLG	MCL					
Chloride (as Cl) (ppm)	4	4	1.17	1.15	2010	No	Water additive used to control odors.
Halocarbon 2,2,4,4-tetra (HAA3) (ppm)	NA	60	0.3	NA	2007	No	By product of drinking water disinfection.
Hexachlorocyclopentadiene (HxCCD) (ppm)	1	5	0.0250	NA	2007	No	Breakdown product of insecticides, herbicides, and other pesticides. Exposed to ground water.
Iron (ppm)	2	2	0.00491	NA	2009	No	Discharge of drilling water. Discharge from metal refineries. Exposed to ground water.
Organic Carbon (ppm)	1.3	1.3	1	2010	1	No	Concentration of household plumbing systems. Discharge of ground water.
Lead (ppm)	0	15	0.011	2010	2	No	Concentration of household plumbing systems. Discharge of ground water.

PSI#430030	MCL		Year	Barrel	Sample	Location	Description
	MCLG	MCL					
Chloride (as Cl) (ppm)	4	4	1.17	1.15	2010	No	Water additive used to control odors.
Hexachlorocyclopentadiene (HxCCD) (ppm)	1	5	0.0250	NA	2007	No	Breakdown product of insecticides, herbicides, and other pesticides. Exposed to ground water.
Iron (ppm)	2	2	0.00491	NA	2009	No	Discharge of drilling water. Discharge from metal refineries. Exposed to ground water.
Organic Carbon (ppm)	1.3	1.3	1	2010	1	No	Concentration of household plumbing systems. Discharge of ground water.
Lead (ppm)	0	15	0.011	2010	2	No	Concentration of household plumbing systems. Discharge of ground water.

PSI #43001

Contaminant	MCLG or MCL	MCL	Year	Range	Sample	Violation	Critical Path
	MCLG	MCL	MCL	Low	High	Date	
Disinfectant & Disinfection By-Products							
<i>(There is no drinking water disinfection by-product monitoring for total trihalomethanes.)</i>							
Chlorine (as Cl ₂) (ppm)	4	4	98	91	110	2010	No
Inorganic Acids (HAAs)							
Halooxetic Acids (HAA5) (ppb)	NA	60	05	NA	2007	No	By-products of drinking water chlorination
Inorganic Contaminants							
Nitrate (measured as Nitrogen) (ppm)	1	1	1	NA	2009	No	Runoff from fertilizer use; Leaching from septic tanks; Leaching from onsite sewage disposal systems; Erosion of natural deposits
Arsenic (ppm)	3	3	00314	NA	2009	No	Erosion of natural deposits; Runoff from agricultural activities; Leaching from natural deposits
Fluoride (ppm)	4	4	0.00002	NA	2009	No	Erosion of natural deposits; Discharge from natural deposits; Erosion of natural deposits
Radon (ppm)	4	4	0.000	NA	2009	No	Radon from natural deposits; Erosion of natural deposits
Selenium (ppm)	5	5	0.0000	NA	2009	No	Discharge from natural deposits; Erosion of natural deposits
Copper - action level at consumer tap (ppm)	1.3	1.3	1	1	2010	1	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer tap (ppm)	0	15	1	1	2010	2	Corrosion of household plumbing systems; Erosion of natural deposits

PSI #43001

Contaminant	MCLG or MCL	MCL	Year	Range	Sample	Violation	Critical Path
	MCLG	MCL	MCL	Low	High	Date	
Disinfectant & Disinfection By-Products							
<i>(There is no drinking water disinfection by-product monitoring for total trihalomethanes.)</i>							
Chlorine (as Cl ₂) (ppm)	4	4	98	91	110	2010	No
Inorganic Acids (HAAs)							
Halooxetic Acids (HAA5) (ppb)	NA	60	05	NA	2007	No	By-products of drinking water chlorination
Inorganic Contaminants							
Nitrate (measured as Nitrogen) (ppm)	1	1	1	NA	2009	No	Runoff from fertilizer use; Leaching from septic tanks; Leaching from onsite sewage disposal systems; Erosion of natural deposits
Arsenic (ppm)	3	3	0.00314	NA	2009	No	Erosion of natural deposits; Runoff from agricultural activities; Leaching from natural deposits
Fluoride (ppm)	4	4	0.00002	NA	2009	No	Erosion of natural deposits; Discharge from natural deposits; Erosion of natural deposits
Radon (ppm)	4	4	0.000	NA	2009	No	Radon from natural deposits; Erosion of natural deposits
Selenium (ppm)	5	5	0.0000	NA	2009	No	Discharge from natural deposits; Erosion of natural deposits
Copper - action level at consumer tap (ppm)	1.3	1.3	1	1	2010	1	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer tap (ppm)	0	15	1	1	2010	2	Corrosion of household plumbing systems; Erosion of natural deposits

PSI #43003

Contaminant	MCLG or MCL	MCL	Year	Range	Sample	Violation	Critical Path
	MCLG	MCL	MCL	Low	High	Date	
Disinfectant & Disinfection By-Products							
<i>(There is no drinking water disinfection by-product monitoring for total trihalomethanes.)</i>							
Chlorine (as Cl ₂) (ppm)	4	4	1.06	1.00	1.06	2010	No
Inorganic Acids (HAAs)							
Halooxetic Acids (HAA5) (ppb)	NA	60	8	NA	2007	No	By-products of drinking water chlorination
Inorganic Contaminants							
Nitrate (measured as Nitrogen) (ppm)	1	1	0.01819	NA	2009	No	Runoff from fertilizer use; Leaching from septic tanks; Leaching from onsite sewage disposal systems; Erosion of natural deposits
Fluoride (ppm)	4	4	0.1	NA	2007	No	Erosion of natural deposits; Discharge from natural deposits; Erosion of natural deposits
Nitrate (measured as Nitrogen) (ppm)	10	10	2	NA	2010	No	Runoff from fertilizer use; Leaching from septic tanks; Leaching from onsite sewage disposal systems; Erosion of natural deposits
Nitrite (measured as Nitrogen) (ppm)	1	1	2	NA	2010	No	Runoff from fertilizer use; Leaching from septic tanks; Leaching from onsite sewage disposal systems; Erosion of natural deposits
Copper - action level at consumer tap (ppm)	1.3	1.3	0.1	2009	1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer tap (ppm)	0	15	0.003	2009	2	No	Corrosion of household plumbing systems; Erosion of natural deposits

As you can see by the table our system had no violations. We are proud that your drinking water meets or exceeds all Federal and State requirements.

Some people may be more vulnerable to contaminants in drinking water than the general population. Infants and young children, pregnant women, the elderly, and those with compromised immune systems are particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA's "Protect Your Drinking Water" guidelines provide more information on how to protect your drinking water. EPA's "Protect Your Drinking Water" guidelines are available from the Safe Drinking Water Hotline (800-426-4791).

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have any questions.

Copiah County Courier

NEWSPAPER ADVERTISING — PRINTING — OFFICE SUPPLIES — GRAPHIC DESIGN
 P.O. Drawer 351 • 103 S. Roggata Ave. • Hazlehurst, MS 39033 • 601-494-3141 • Fax 601-495-3144

2011 JUN 27 AM 9:50

PROOF OF PUBLICATION

STATE OF MISSISSIPPI
 COUNTY OF COPIAH
 Personally came before me, the undersigned, authority in and for COPIAH COUNTY, Mississippi the CLERK of the COPIAH COUNTY COURIER, a newspaper published in the City of Hazlehurst, Copiah County, in said state, who being duly sworn, depose and say that the COPIAH COUNTY COURIER is a newspaper published in the State of Mississippi, 2002 qualified in the regular session of the Mississippi Legislature of 1918, amended Section 186, of the Mississippi Code of 1922, and that the publication of a notice of which the annexed is a true copy appeared in this issue of said newspaper to follow.

DATE: 6-22-11
 DATE:
 DATE:
 DATE:
 DATE:
 DATE:

Number of Words: 405
 Published: 1 times
 Printed fee: \$ 275.40
 Proof fee: \$ 3.00
 TOTAL: \$ 278.40

Signature: [Signature]
 Title: [Title]
 SWORN TO and solemnly sworn to, this 22nd day of June, 2011, at Hazlehurst, Copiah County, Mississippi.
 [Signature]
 Notary Public

QUALITY CONTROL REPORT
 LINCOLN RURAL WATER ASSOCIATION
 PWS ID# 48021248993
 Date: 7/20/11

This Ground Water is provided to you this year Annual Water Quality Report. This report is designed to let you know about the quality water and service levels of your water supply. Our overall goal is to provide you with a safe and clean and protect your water resources. We are committed to ensuring the quality of your water. Our water quality standards are well recognized from the National Sanitation Foundation Water Quality Institute to protect our drinking water from potential health and taste problems. The following reports show your water quality and what it means:

If you have any questions about this report or arranging your water utility, please contact Holly Walker at 4346 Mendocino, Hazlehurst, MS. 601-494-3249. We would like to schedule a meeting for the following: Monthly water utility meeting at the Hazlehurst office, please contact Holly Walker at 4346 Mendocino, Hazlehurst, MS. 601-494-3249. They are held on the 1st Monday of each month at the Hazlehurst office at 7:00 P.M. and our Annual Meeting is held on the 1st Monday of March at the County Courthouse at 7:00 P.M.

The service water assessment has been completed for our public water system to determine the correct responsibility of its drinking water supply. It includes a detailed review of a water system, a report detailing a list of information which has the responsibility of determining what has been furnished to our public water system and is available for carrying out its purpose. The results for Lincoln Rural Water have revealed a number of water quality problems of concern.

Lincoln Rural Water Association routinely monitors for as many as 154 constituents in your drinking water according to federal and state laws. This table shows the results of our monitoring for the month of January 2011. All drinking water is tested for lead in drinking water. Lead is a naturally occurring metal in soil and rock. Lead is not a health risk. It is important to remember that the presence of lead in drinking water does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other actions which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as strict as the MCLGs to protect public health using the best available treatment technology.

Maximum Contaminant Level Goal - The "MCLG" is the level of a contaminant in drinking water, below which there are no known or expected risks to health. MCLGs do not enforce a numeric water quality standard.

Additional information for Lead
 Lead is a naturally occurring metal in soil and rock. Lead is not a health risk. It is important to remember that the presence of lead in drinking water does not necessarily pose a health risk. Lead is not a health risk. It is important to remember that the presence of lead in drinking water does not necessarily pose a health risk. Lead is not a health risk. It is important to remember that the presence of lead in drinking water does not necessarily pose a health risk.

Contaminant	MCLG	MCL	Year	Range	Sample	Violations	Explain Source
	MCLG	MCL	Year	Low	High	Rate	
There is no maximum contaminant level goal for radon in drinking water.							
Chlorine (as Cl ₂) (ppm)	0	4	NA	0.00	0.11	0.00	None within need or exceed threshold.
Disinfection By-Products (DBPs) (ppm)	NA	NA	NA	NA	2.00	NA	By-product of drinking water treatment.
Fluoride (ppm)	2	4.00 (MCL)	NA	0.00	0.00	0.00	Discharge from natural sources. Excess of natural deposits.
Nitrate (expressed as Nitrogen) (ppm)	10	10	03/11	NA	2000	NA	Runoff from fertilizer use. Excess of natural deposits.
Nitrite (expressed as Nitrogen) (ppm)	1	1	03/11	NA	2000	NA	Excess of natural deposits. Leaking from water tanks, septic, Excess of natural deposits.
Copper - detected in customer tap water	1.3	1.3	01/11	NA	0.00	0.00	Excess of household plumbing systems. Excess of natural deposits.
Lead - not detected in customer tap water	0	0.01	01/11	NA	0.00	0.00	Excess of household plumbing systems. Excess of natural deposits.

Contaminant	MCLG	MCL	Year	Range	Sample	Violations	Explain Source
	MCLG	MCL	Year	Low	High	Rate	

There is no maximum contaminant level goal for radon in drinking water.

Chlorine (as Cl₂) (ppm) 0 4 NA NA 0.00 0.11 0.00 None within need or exceed threshold.

Disinfection By-Products (DBPs) (ppm) NA NA NA NA NA 2.00 NA By-product of drinking water treatment.

Fluoride (ppm) 2 4.00 (MCL) NA NA 0.00 0.00 0.00 Discharge from natural sources. Excess of natural deposits.

Nitrate (expressed as Nitrogen) (ppm) 10 10 03/11 NA 2000 NA Runoff from fertilizer use. Excess of natural deposits.

Nitrite (expressed as Nitrogen) (ppm) 1 1 03/11 NA 2000 NA Excess of natural deposits. Leaking from water tanks, septic, Excess of natural deposits.

Copper - detected in customer tap water 1.3 1.3 01/11 NA 0.00 0.00 0.00 Excess of household plumbing systems. Excess of natural deposits.

Lead - not detected in customer tap water 0 0.01 01/11 NA 0.00 0.00 0.00 Excess of household plumbing systems. Excess of natural deposits.

As you can see by the table our system had no violations. We are proud that your drinking water meets or exceeds all Federal and State requirements.

If you have any questions about this report or arranging your water utility, please contact Holly Walker at 4346 Mendocino, Hazlehurst, MS. 601-494-3249. We would like to schedule a meeting for the following: Monthly water utility meeting at the Hazlehurst office, please contact Holly Walker at 4346 Mendocino, Hazlehurst, MS. 601-494-3249. They are held on the 1st Monday of each month at the Hazlehurst office at 7:00 P.M. and our Annual Meeting is held on the 1st Monday of March at the County Courthouse at 7:00 P.M.

Thank you for your cooperation in providing us with a safe and clean water supply. We are committed to ensuring the quality of your water. Our water quality standards are well recognized from the National Sanitation Foundation Water Quality Institute to protect our drinking water from potential health and taste problems. The following reports show your water quality and what it means:

June 22, 2011

43103