



2011 JUN 16 AM 8:38

MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Star Water Co., Inc.

Public Water Supply Name

MS0610027

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
- Advertisement in local paper
- On water bills
- Other

Date customers were informed: 6/1/11

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: Rankin Co. News

Date Published: 6/1/11

- CCR was posted in public places. (Attach list of locations)

Date Posted: 6/1/11 Star Water Office

- CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Debra Jean Whitley, Pres
Name/Title (President, Mayor, Owner, etc.)

4-28-11
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

Inorganic Contaminants

| | | | | | | | | |
|--------------|---|-------|------|-------------|-----|-----|--------|---|
| 10. Barium | N | 2010 | .008 | .007 - .008 | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 13. Chromium | N | 2010 | 2 | 1.4 - 2 | ppb | 100 | 100 | Discharge from steel and pulp mills; erosion of natural deposits |
| 14. Copper | N | 2008* | .4 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2010 | .326 | .314 - .326 | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead | N | 2008* | 6 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |

Volatile Organic Contaminants

| | | | | | | | | |
|-------------|---|------|-------|----------|-----|----|----|---|
| 76. Xylenes | N | 2010 | .0005 | No Range | ppm | 10 | 10 | Discharge from petroleum factories; discharge from chemical factories |
|-------------|---|------|-------|----------|-----|----|----|---|

Disinfection By-Products

| | | | | | | | | |
|-------------------------------------|---|------|-------|----------|-----|---|----------|--|
| 81. HAA5 | N | 2010 | 10 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2010 | 52.42 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2010 | .71 | .6 - .8 | ppm | 0 | MDRL = 4 | Water additive used to control microbes |

* Most recent sample. No sample required for 2010.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Star Water Company, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

AFFIDAVIT

15 JUN 2011 8:33
2/27

PROOF OF PUBLICATION

RANKIN COUNTY NEWS • P.O. BOX 107 • BRANDON, MS 39043

STATE OF MISSISSIPPI COUNTY OF RANKIN

THIS 2ND DAY OF JUNE, 2011, personally came Marcus Bowers, publisher of the Rankin County News,

a weekly newspaper printed and published in the City of Brandon, in the County of Rankin and State aforesaid, before me the undersigned officer in and for said County and State, who being duly sworn, deposes and says that said newspaper has been published for more than 12 months prior to the first publication of the attached notice and is qualified under Chapter 13-3-31, Laws of Mississippi, 1936, and laws supplementary and amendatory thereto, and that a certain

ANNUAL DRINKING WATER QUALITY REPORT

STAR WATER COMPANY

a copy of which is hereto attached, was published in said newspaper One (1) week, as follows, to-wit:

Vol 163 No. 45 on the 1st day of June, 2011

Marcus Bowers

MARCUS BOWERS, Publisher

Sworn to and subscribed before me by the aforementioned Marcus Bowers this 2nd day of June, 2011

Frances Conger Notary Public
FRANCES CONGER
My Commission Expires: January 25, 2014

PRINTER'S FEE:

3 column by 13.5 inch ad at \$6.50 per column inch..... \$263.25

Proof of Publication..... 3.00

TOTAL..... \$266.25



2010 Annual Drinking Water Quality Report Star Water Company, Inc. PWS# 0610027 May 2011

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Cookfield Formation and the

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Star Water Company, Inc. have received moderate susceptibility rankings to contamination.

If you have any questions about the report or concerning your water utility, please contact Dara Jean Whitley at 601-845-1415. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of each month at 7:00 PM at the water office.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2010. In cases where monitoring regularly occurring nuisance and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity, microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or residential use; organic chemical contaminants, including volatile organic compounds, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radionuclide contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, we follow bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs do not enforce a numeric drinking water standard.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

| Contaminant | Method | Date Collected | Level Detected | Range of Detects or # of Detects Exceeding MCL/MCLG | Unit Measure | MCLG | MCL | Likely Source of Contamination |
|-------------|--------|----------------|----------------|---|--------------|------|-----|--------------------------------|
|-------------|--------|----------------|----------------|---|--------------|------|-----|--------------------------------|

Inorganic Contaminants

| | | | | | | | | |
|--------------|---|------|-----|-----------|-----|-----|--------|---|
| 10. Barium | N | 2010 | 608 | 607 - 608 | ppm | 2 | 2 | Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits |
| 13. Chloride | N | 2010 | 2 | 1.4 - 2 | ppb | 100 | 100 | Discharge from steel and pig iron, erosion of natural deposits |
| 14. Copper | N | 2008 | 4 | 0 | ppm | 1.5 | AL=1.5 | Corrosion of household plumbing systems, erosion of natural deposits, leaching from wood preservatives |
| 16. Fluoride | N | 2010 | 318 | 314 - 320 | ppm | 4 | 4 | Erosion of natural deposits, water softening which processes strong leach, discharge from fertilizer and insecticides |
| 17. Lead | N | 2008 | 0 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |

Volatile Organic Contaminants

| | | | | | | | | |
|-------------|---|------|------|----------|-----|----|----|--|
| 16. Xylenes | N | 2010 | 6082 | No Range | ppm | 10 | 10 | Discharge from petroleum refineries, discharge from chemical factories |
|-------------|---|------|------|----------|-----|----|----|--|

Disinfection By-Products

| | | | | | | | | |
|------------------------------|---|------|--------|----------|-----|---|--------|---|
| 61. HAA5 | N | 2010 | 10 | No Range | ppb | 0 | 60 | By-product of drinking water disinfection |
| 62. THM5 (haloacetonitriles) | N | 2010 | \$2.42 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination |
| Chlorine | N | 2010 | 71 | .8 - 8 | ppm | 0 | MRDL=4 | Water additive used to control microbes |

Maximum Residual Disinfectant Level Goal (MRDLG) 2010
As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling but showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When you have lead service lines or lead pipes in your home, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.876.7592 if you wish to have your water tested.

As sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4761.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cysts and parasites in drinking water are available from the Safe Drinking Water Hotline at 1-800-426-4761.

The Star Water Company, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us