

Rec'd 7/1/11

2010 Consumer Confidence Report
Minter City Water & Sewer District
PWS ID# MS0420035

Spanish (Español)

Este informe contiene informacion muy importante sobre la calidad de su agua potable. Por favor lea este informe o comuniquese con alguien que pueda traducir la informacion.

French (Français)

Ce rapport contient des informations importantes sur votre eau potable. Traduisez-le ou parlez en avec quelqu'un qui le comprend bien.

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, & how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, & infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium & other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

According to the MS Department of Environmental Quality Office of Land & Water Resource PWS Report, the two water wells draw water from the Meridian Upper Wilcox Aquifer & the Winona-Tallahata Aquifer. Well one has been abandoned.

Availability of the Consumer Confidence Report & the Source water assessment

The Consumer Confidence Report will not be mailed to the water system customer. However, it is available upon request.
The PWS Report from the MS Dept. of Environmental Quality Office of Land & Water PSW Report shows the final susceptibility ranking as follows:
Source ID #1 - Moderate (This well has been abandoned.) Source ID #2 - Lower Source ID #3 - Moderate.
The Source Water Assessment will not be mailed to the customer. However, it is available upon request.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants & potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water & bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, & wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals &, in some cases, radioactive material, & can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses & bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, & wildlife; inorganic contaminants, such as salts & metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil & gas production, mining, or farming; pesticides & herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, & residential uses; organic Chemical Contaminants, including synthetic & volatile organic chemicals, which are by-products of industrial processes & petroleum production, & can also come from gas stations, urban storm water runoff, & septic systems; & radioactive contaminants, which can be naturally occurring or be the result of oil & gas production & mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food & Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Minter City Water & Sewer District works to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life & our children's future. Minter City Water & Sewer District regular board meetings are held on the second Tuesday of each month. For further information, please contact Hugh Arant, Chairman.

Description of Water Treatment Process

Your water is treated by filtration & disinfection. Filtration removes particles suspended in the source water. Particles typically include clays & silts, natural organic matter, iron & manganese, & microorganisms. Your water is also treated by disinfection. Disinfection involves the addition of chlorine or other disinfectants to kill bacteria & other microorganisms (viruses, cysts, etc.) that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost & no-cost ways to conserve water. Small changes can make a big difference - try one today & soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair & shaving & save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, & can save you up to 750 gallons a month.
- Run your clothes washer & dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets & faucets. Faucet washers are inexpensive & take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank & wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it & during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn & garden fertilizers & pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community & volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce & distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women & young children. Lead in drinking water is primarily from materials & components associated with service lines & home plumbing. Minter City Water & Sewer District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, & steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, & in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water & have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms & abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfectant By-Products								
<i>(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)</i>								
Chlorine (as Cl ₂) (ppm)	4	4	0.6	0.41	0.6	2010	No	Water additive used to control microbes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	80	NA		2010	No	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	NA	60	60	NA		2010	No	By-product of drinking water chlorination
Volatile Organic Contaminants								
Xylenes (ppm)	10	10	0.0026	0.00176	0.0026	2010	No	Discharge from petroleum factories; Discharge from chemical factories

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL or MRDL	Your Water	Violation	Typical Source
Nitrite [measured as Nitrogen] (ppm)	1	1	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Unit Descriptions

Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances & Exemptions	Variances & Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level
For more information please contact:	

Contact Name: Hugh Arant
Address:
POB 73
Minter City, MS 38944
Phone: 662-756-2034



Dawn Whitaker, Asst. Manager
& William Lott, Manager

Telephone: (662) 453-6800

Greenwood, MS 38930

2109 Hwy. 82 West • Suite C

Loans, Inc.

• Cattlemen

2010 Consumer Confidence Report

Minter City Water & Sewer District

PWS ID# MS0420035

2011 JUL 22 AM 8:30

Spanish (Español)

Este informe contiene información muy importante sobre la calidad de su agua potable. Por favor lea este informe o comuníquese con alguien que pueda traducir la información.

French (Français)

Ce rapport contient des informations importantes sur votre eau potable. Traduisez-le ou parlez en avec quelqu'un qui le comprend bien.

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, & how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, & infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium & other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

According to the MS Department of Environmental Quality Office of Land & Water Resource PWS Report, the two water wells draw water from the Meridian Upper Wilcox Aquifer & the Winona-Tallahata Aquifer. Well one has been abandoned.

Availability of the Consumer Confidence Report & the Source water assessment

The Consumer Confidence Report will not be mailed to the water system customer. However, it is available upon request.

The PWS Report from the MS Dept. of Environmental Quality Office of Land & Water PSW Report shows the final susceptibility ranking as follows:

Source ID #1 - Moderate (This well has been abandoned.)

Source ID #2 - Lower

Source ID #3 - Moderate.

The Source Water Assessment will not be mailed to the customer. However, it is available upon request.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants & potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water & bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, & wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals &, in some cases, radioactive material, & can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses & bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, & wildlife; inorganic contaminants, such as salts & metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil & gas production, mining, or farming; pesticides & herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, & residential uses; organic Chemical Contaminants, including synthetic & volatile organic chemicals, which are by-products of industrial processes & petroleum production, & can also come from gas stations, urban storm water runoff, & septic systems; & radioactive contaminants, which can be naturally occurring or be the result of oil & gas production & mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food & Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

- Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:
- Eliminate excess use of lawn & garden fertilizers & pesticides – they contain hazardous chemicals that can reach your drinking water source.
 - Pick up after your pets.
 - If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
 - Dispose of chemicals properly; take used motor oil to a recycling center.
 - Volunteer in your community. Find a watershed or wellhead protection organization in your community & volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
 - Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce & distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women & young children. Lead in drinking water is primarily from materials & components associated with service lines & home plumbing. Minter City Water & Sewer District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, & steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, & in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water & have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms & abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	0.6	0.41	0.6	2010	No	Water additive used to control microbes
THMs [Total Trihalomethanes] (ppb)	NA	80	80	NA		2010	No	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	NA	60	60	NA		2010	No	By-product of drinking water chlorination
Volatile Organic Contaminants								
Xylenes (ppm)	10	10	0.0026	0.00176	0.0026	2010	No	Discharge from petroleum factories; Discharge from chemical factories

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL or MRDL	Your Water	Violation	Typical Source
Nitrite [measured as Nitrogen] (ppm)	1	1	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Unit Descriptions

Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances & Exemptions	Variances & Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level