

2011 JUL -1 PM 2:15



MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Golden Triangle Water
Public Water Supply Name

0130018 0130019
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper
On water bills
Other

Date customers were informed: / /

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: Daily Times Leader

Date Published: 6/30/11

CCR was posted in public places. (Attach list of locations)

Date Posted: / /

CCR was posted on a publicly accessible internet site at the address: www.

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Barrett Baggett
Name/Title (President, Mayor, Owner, etc.)

June 30, 2011
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

570 East Woodrow Wilson • Post Office Box 1700 • Jackson, Mississippi 39215-1700
601/576-7634 • Fax 601/576-7931 • www.HealthyMS.com

Equal Opportunity in Employment/Service

Handwritten initials and checkmark

Handwritten number 6

2010 Annual Drinking Water Quality Report
 Golden Triangle Water Association
 PWS#: 130018 & 130019
 June 2011

REC'D - WATER DIV.
 2011 JUN 14 PM 3:52

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Eutaw McShan & Tuscaloosa Aquifers and purchased from the City of West Point that has wells drawing from the Eutaw Formation & the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Golden Triangle Water Association and the City of West Point have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Barrett Baggett at 662-436-7329. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 7:00 PM at the office G. T. office.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2010. In cases where monitoring wasn't required in 2010, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID# 130018		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria	N	March	Positive	2	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment

Inorganic Contaminants

8. Arsenic	N	2008*	.8	.7 - .8	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2008*	.041	.026 - .041	ppm		2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2008*	1.7	No Range	ppb		100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	1.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2008*	1.68	.182 - 1.68	ppm		4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	5	0	ppb		0	AL=15 Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2008*	2.9	2.7 - 2.9	ppb		50	50 Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2008*	12.82	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	.76	.74 - .79	ppm	0	MDRL = 4	Water additive used to control microbes

PWS ID # 130019

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	------	-----	--------------------------------

Radioactive Contaminants

5. Gross Alpha	N	2008*	1.91	.165 - 1.91	pCi/L	0	15	Erosion of natural deposits
6. Radium 226 Radium 228	N	2008* 2008*	.371 .552	.047- .371 .104 - .552	pCi/l	0	5	Erosion of natural deposits
7. Uranium ¹	N	2008*	.005	No Range	µg/L	0 ¹	30 ¹	Erosion of natural deposits

Inorganic Contaminants

10. Barium	N	2008*	.074	.37 - .74	ppm		2	2 Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2008*	1.4	.8 - 1.4	ppb		100	100 Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2010	.91	.70 - .91	ppm		4	4 Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	3	0	ppb		0	AL=15 Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2008*	1.5	.9 - 1.5	ppb		50	50 Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

Chlorine	N	2010	.74	.63 - .74	ppm	0	MDRL = 4	Water additive used to control microbes
----------	---	------	-----	-----------	-----	---	----------	---

*Most recent sample. No sample required for 2010.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

Significant Deficiencies

System # 130018

During a sanitary survey conducted on 9/27/10 the Mississippi State Department of Health cited the following deficiency:

Inadequate internal cleaning/maintenance of storage tanks

Corrective actions: The system is currently under a Bilateral Compliance Agreement with the Mississippi State Department of Health to complete the inspection of the storage tanks and to clean and paint where needed. All deficiencies are scheduled to be completed by 7/31/2011.

System # 130008 – City of West Point

Significant Deficiencies

During a sanitary survey conducted on 5/20/10 the Mississippi State Department of Health cited the following deficiency:

Inadequate internal cleaning/maintenance of storage tanks

Corrective actions: The system is currently under a Bilateral Compliance Agreement with the Mississippi State Department of Health to complete the cleaning and painting of the tanks. All deficiencies are scheduled to be completed by 12/31/2011.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the CITY OF WEST POINT is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 92%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Golden Triangle Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2011 Annual Drinking Water Quality Report
 Spokane Tri-County Water Association
 PWSID: 130018 & 130019
 May 2011

We pleased to present to you this year's Annual County Water Report. This report is designed to inform you about the quality water services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We'd like you to understand the office we refer to continuously improve the water treatment process and protect our water resources. We committed to ensuring the quality of your water. Our water source is from water drawn from the Bitter Root and Teton basins. Water is pumped from the City of West Point and the water drawn from the Bitter Root and Teton basins.

Recent water treatment has been completed for our public water system to determine the overall susceptibility of its drinking or supply to identify potential sources of contamination. The primary responsibility remains assigned to each part of the system and the responsibility to ensure the quality of your water. Our water source is from water drawn from the Bitter Root and Teton basins. Water is pumped from the City of West Point and the water drawn from the Bitter Root and Teton basins.

To share any questions about this report or concerning your water utility, please contact Todd Dizon at 509-494-1000, via voice or via conference to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 7:00 PM at the office Q, 7, office in Spokane.

routinely collect for constituents in your drinking water according to Federal and State laws. This table below lists all of the tap-water constituents that were detected during the period of January 1st to December 31st, 2009. In cases where maximum contaminant level (MCL) required in 2009, the table reports the most recent results. As water travels over the surface of land or underground, it dissolves naturally-occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of plants or from animals activity. Microbial contaminants, such as bacteria and parasites, feed raw sewage from sewage treatment plants, farms, and other sources. Inorganic contaminants, such as nitrates, nitrites, and other inorganic compounds, which can be naturally occurring or result from industrial, domestic, and agricultural activities, and other sources. Volatile organic compounds, which can be naturally occurring or result from the use of solvents, such as gasoline, paint, and other products. Pesticides, which can be naturally occurring or result from the use of pesticides and other agricultural products. Radionuclides, which can be naturally occurring or result from the use of radon gas. Other contaminants, which can be naturally occurring or result from the use of other products. All drinking water, including drinking water, may be naturally occurring or result from the use of other products. It is important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we added the following definitions:

Maximum Contaminant Level (MCL) - The "Maximum Allowable" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set to protect the MCLG as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is continuing work that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

1 part per million (ppm) or milligrams per liter (mg/L) - one part per million corresponds to one minute in two years or a single penny in 100,000.

1 part per billion (ppb) or micrograms per liter (µg/L) - one part per billion corresponds to one minute in 1,000 years, or a single penny in 100,000,000.

VS ID# 130018 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measurement	MCLG	MCL	Health Source of Contamination
-------------	---------------	----------------	----------------	---	------------------	------	-----	--------------------------------

Microbiological Contaminants

Contaminant	Unit	Violation	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measurement	MCLG	MCL	Health Source of Contamination
-------------	------	-----------	----------------	---	------------------	------	-----	--------------------------------

Organic Contaminants

Contaminant	Unit	Violation	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measurement	MCLG	MCL	Health Source of Contamination
Arsenic	ppb		0	0 - 0	ppb	10	10	Exposure to natural deposits (e.g. of iron, manganese, runoff from glass and electronics, and other sources)
Beryllium	ppm		0.04	0.04 - 0.04	ppm	2	2	Discharge from metal refineries; discharge from metal refineries; discharge from metal refineries
Chromium	ppm		1.7	No Range	ppm	100	100	Discharge from steel and pulp mills; runoff from natural deposits
Copper	ppm		1.1	0	ppm	1.3	MCLG: 1.3	Corrosion of household plumbing systems; corrosion of natural deposits; leaching from water treatment equipment
Fluoride	ppm		1.00	1.02 - 1.04	ppm	4	4	Exposure to natural deposits; water utility which, sometimes from large discharge from fertilizer and phosphate fertilizers
Lead	ppb		0	0	ppb	15	MCL: 15	Corrosion of household plumbing systems; corrosion of natural deposits
Nitrate	ppm		2.9	2.7 - 2.9	ppm	10	10	Discharge from fertilizers and animal manure; leaching of natural deposits; leaching from manure

Inorganic By-Products

Contaminant	Unit	Violation	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measurement	MCLG	MCL	Health Source of Contamination
-------------	------	-----------	----------------	---	------------------	------	-----	--------------------------------

VS ID# 130019 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measurement	MCLG	MCL	Health Source of Contamination
-------------	---------------	----------------	----------------	---	------------------	------	-----	--------------------------------

Inorganic Contaminants

Contaminant	Unit	Violation	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measurement	MCLG	MCL	Health Source of Contamination
-------------	------	-----------	----------------	---	------------------	------	-----	--------------------------------

Organic Contaminants

Contaminant	Unit	Violation	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measurement	MCLG	MCL	Health Source of Contamination
-------------	------	-----------	----------------	---	------------------	------	-----	--------------------------------

13. Chromium	N	2008*	1.7	No Range	ppm	100	100	Discharge from coal and pulp mill effluent or natural deposits.
14. Copper	N	2008*	1.1	0	ppm	1.5	AL-1.3	Discharge of industrial processing effluents, weathering of natural deposits, leaching from wood preservatives.
15. Fluoride	N	2008*	1.01	1.02 - 1.08	ppm	4	4	Discharge of natural deposits, water soluble salts, leaching from fertilizer and discharge from fertilizer manufacturing facilities.
17. Lead	N	2008*	5	0	ppm	5	AL-1.5	Discharge of industrial processing effluents, weathering of natural deposits.
21. Selenium	N	2008*	2.9	2.7 - 2.9	ppm	80	80	Discharge from petroleum and metal refineries, weathering of natural deposits, discharge from mines.

Disinfection By-Products

As. Trihalomethanes	N	2008*	12.0*	No Range	ppm	0	25	Apparatus of drinking water disinfection.
Chlorine	N	2014	.70	.74 - .79	ppm	0	MDEQ - 4	Water additive used to control microbes.

PWS ID # 130819

TEST RESULTS

Contaminant	Violation Y/N	Sample Collected	Level Detected	Range of EPA or Secondary Maximum Limits	Unit of Measurement	MCLG	MCL	Health Status of Contaminant
-------------	---------------	------------------	----------------	--	---------------------	------	-----	------------------------------

Radioactive Contaminants								
6. Gross Alpha	N	2008*	1.31	100 - 101	pCi/L	0	15	Product of natural deposits.
8. Radium 226	N	2008*	.379	.049 - .371	pCi/L	0	5	Product of natural deposits.
8. Radium 228	N	2008*	.565	.124 - .372	pCi/L	0	5	Product of natural deposits.
7. Uranium	N	2008*	1.05	No Range	ppm	150	30	Product of natural deposits.

Inorganic Contaminants								
10. Barium	N	2008*	.974	.37 - .74	ppm	2	2	Discharge of mining wastes, discharge from animal enterprises, weathering of natural deposits.
13. Chromium	N	2008*	1.4	3 - 1.4	ppm	100	100	Discharge from steel and pulp mills, discharge from natural deposits.
14. Copper	N	2008*	1.1	0	ppm	1.5	AL-1.3	Discharge of industrial processing effluents, weathering of natural deposits, leaching from wood preservatives.
15. Fluoride	N	2010	.91	.90 - .98	ppm	4	4	Discharge of natural deposits, water soluble salts, leaching from fertilizer and discharge from fertilizer manufacturing facilities.
17. Lead	N	2008*	5	0	ppm	5	AL-1.5	Discharge of industrial processing effluents, weathering of natural deposits.
21. Selenium	N	2008*	2.9	2.7 - 2.9	ppm	80	80	Discharge from petroleum and metal refineries, weathering of natural deposits, discharge from mines.

Disinfection By-Products

Chlorine	N	2010	.79	.65 - .74	ppm	0	MDEQ - 4	Water additive used to control microbes.
----------	---	------	-----	-----------	-----	---	----------	--

*First annual sample. No sample required for SDWA.

As you can see by the table, our system had no violations. However, on system # D130819 we violated a drinking water standard. We took 2 samples in March that showed the presence of certain bacteria. We did follow up testing and did not find any bacteria present in the subsequent testing. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have taken these steps to ensure that your drinking water is safe and that some contaminants have been detected because the EPA has determined that your water is SAFE at these levels.

We are required to monitor your drinking water for specific constituents at a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems compliance all monitoring requirements, MDEQ now collects samples of any drinking water prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the leaching of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing procedures, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4761 or at www.epa.gov/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 662-328-7082 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be inorganic, organic, synthetic, or radioactive substances. All drinking water, including bottled water, may occasionally be exposed to contaminants at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4761.

Some people may be more susceptible to contaminants in drinking water than the general population. Infants, compromised persons such as patients with certain underlying chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should work with their doctor to ensure that their health care providers. EPA's D.C. guidelines on appropriate actions to human the risk of infection by cryptosporidium and other parasitological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4761.

The Golden Triangle Water Association works around the clock to provide top quality water to every tap. We are that all our customers help us protect our water source, which is the heart of our community, our way of life and our children's future.