



MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

Reform Water Users Assn
Public Water Supply Name

100007
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: / /

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: The Choctaw Plaindealer

Date Published: 6/15/11

- CCR was posted in public places. (*Attach list of locations*)

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Richard Wood
Name/Title (President, Mayor, Owner, etc.)

6-20-11
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

Annual Drinking Water Quality Report
Reform Water Users Association
PWS ID # 0100007
June 30, 2011

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater, and our 4 wells draw from the Lower Wilcox Aquifer.

If you have any questions about this report or concerning your water utility, please contact Coyt Hunt at (662)387-4360. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Monday of each month at 7P.M. in the Sherwood Community Center.

Reform Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2010. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Our source water assessment has been completed. Our wells were ranked **Moderate** in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662.387-4360.

To help you better understand these terms we've provided the following definitions. In this table you will find many terms and abbreviations you might not be familiar with.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCL G	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	-------	-----	--------------------------------

Inorganic Contaminants

Cadmium	N	2008*	.0001	0	ppm	5	5	Corrosion of galvanized pipe ; refineries; from waste batteries & paint
Arsenic	N	2008*	<0.0005	No Range	Ppb	n/a	50	Erosion of natural deposits ; Runoff from orchards , glass and electronics production wastes
Selenium	N	2008*	<0.0005	0	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Barium	N	2008*	0003619	No Range	Ppm	2	2	Discharge of drilling wastes; refineries; erosion of natural deposits
Nitrate (as Nitrogen)	N	2010	0.25	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion from natural deposits
Antimony	N	2008*	<0.0005	No Range	ppb	6	4	Discharge from petroleum ; fire retardants; ceramics; solder test addition
Chromium	N	2008*	<.0005	No Range	Ppb	100	100	Discharge from steel and pulp of natural deposits
Cyanide	N	2008*	<0.005	0	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride	N	2008*	0.12	0.670-1.080	ppm	4	4	Erosion of natural deposits; additive which water promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (inorganic)	N	2008*	<.0002	No Range	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland

Beryllium	N	2008*	,0.0001	No Range	ppb	4	14	Discharge from metal refineries factories; Discharge aerospace
Thallium	N	2008*	<0.0005	No Range	ppb	0.5	2	Discharge from electronics ; ore-processing

Disinfectants & Disinfection By Products

Chlorine [asC12]	N	2010	0.42	0.27-1.40	ppm	4	4	water additive used to control microbes
TTHMs Total	N	2007*	1.44	No Range	ppb	0	100	By- product of drinking water chlorination
HAA5 Total	N	2007*	2.1	No Range	ppb	0	80	By- product of drinking water chlorination

* Most recent sample None required in 2010

Monitoring & Reporting Of Compliance Data Violations

Reform water assn. failed the **Coliform** requirement for monitoring period 8/01/2010-8/31/2010 all requirements have been met to correct the monitoring violation.

Significant Deficiencies

During a sanitary survey conducted on 2/24/2010, the Mississippi State Department of Health cited the following significant deficiency(s):

Inadequate internal cleaning/maintenance of storage tanks

Corrective actions: The system is currently under a Bilateral Compliance Agreement with the Mississippi State Department of Health to have the tanks inspected and if necessary cleaned and painted.

Inadequate security measures.

Corrective actions: The system is currently under a Bilateral Compliance Agreement with the Mississippi State Department of Health to have the fences installed.

All deficiencies are scheduled to be completed by 7/15/2012.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. The Bureau of Public Water Supply is taking action to resolve this issue as quickly as possible. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Please call our office if you have questions. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. **This CCR report will not be mailed. A copy of this report is available at our office upon request.**

Annual Drinking Water Quality Report
Reform Water Users Association
PWS ID # 0100007
June 30, 2011

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater, and our 4 wells draw from the Lower Wilcox Aquifer.

If you have any questions about this report or concerning your water utility, please contact Cory Hain at (662)387-4360. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Monday of each month at 7PM, in the Sherwood Community Center.

Reform Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2010. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of these constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Our source water assessment has been completed. Our wells were tested. Maximums in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662-387-4360.

To help you better understand these terms we've provided the following definitions. In this table you will find many terms and abbreviations you might not be familiar with.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 4,000 years, or a single penny in \$10,000,000.

PicoCuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGLs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Contaminant	Unit	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding	Unit Maximum	MCL	MCLG	Likely Source of Contaminant
Inorganic Constituents								
Calcium	ppm	2008	200	0	ppm	75	75	Concentration of calcium varies with water hardness & pH
Arsenic	ppb	2008	<0.005	No Range	ppb	10	10	Residue of natural deposits, leached from earth, glass and ceramic, production wastes
Selenium	ppb	2008	<0.005	0	ppb	50	50	Discharge from petroleum and metal refineries, residue of natural deposits, discharge from metal
Chlorine	ppm	2008	0.005	No Range	ppm	2	2	Discharge from petroleum refineries, residue of natural deposits, leached from earth, glass and ceramic, production wastes
Nitrate (as Nitrogen)	ppm	2010	0.23	No Range	ppm	10	10	Residue of natural deposits, leached from earth, glass and ceramic, production wastes
Amblypnea	ppb	2008	0.005	No Range	ppb	6	6	Discharge from petroleum refineries, residue of natural deposits, leached from earth, glass and ceramic, production wastes
Chloride	ppm	2008	0.005	No Range	ppm	100	100	Discharge from steel mill, residue of natural deposits
Cyanide	ppb	2008	<0.005	0	ppb	200	200	Discharge from chemical facilities, discharge from plants and facilities
Fluoride	ppm	2008	0.13	0.075-1.000	ppm	4	4	Residue of natural deposits, which which were present in the earth, discharge from facilities and
Iron	ppm	2008	<0.005	No Range	ppm	1	1	Residue of natural deposits, discharge from refineries and facilities, from facilities, except from treatment
Beryllium	ppb	2008	0.005	No Range	ppb	4	4	Discharge from metal refineries, discharge from facilities, except from treatment
Thallium	ppb	2008	<0.005	No Range	ppb	0.5	0.5	Discharge from refineries, except from treatment
Radionuclides								
Chloride [MCLG]	ppm	2010	0.42	0.27-1.40	ppm	4	4	Water additive used to control hardness
TRM Total								No exceed of drinking water chlorination
HAAS Total								No exceed of drinking water chlorination

* Most tested samples were treated in 2010. Monitoring & Reporting Of Compliance Data Violations. Reform water users, failed the California requirement for monitoring period 8/01/2010-8/31/2010 all requirements have been met to correct the monitoring violation.

During a routine survey conducted on 2/24/2010, the Mississippi State Department of Health cited the following significant deficiencies:

1. Inadequate internal disinfection/sterilization of storage tanks.

2. Inadequate internal disinfection/sterilization of storage tanks.

3. Inadequate internal disinfection/sterilization of storage tanks.

4. Inadequate internal disinfection/sterilization of storage tanks.

5. Inadequate internal disinfection/sterilization of storage tanks.

6. Inadequate internal disinfection/sterilization of storage tanks.

7. Inadequate internal disinfection/sterilization of storage tanks.

8. Inadequate internal disinfection/sterilization of storage tanks.

9. Inadequate internal disinfection/sterilization of storage tanks.

10. Inadequate internal disinfection/sterilization of storage tanks.

11. Inadequate internal disinfection/sterilization of storage tanks.

12. Inadequate internal disinfection/sterilization of storage tanks.

13. Inadequate internal disinfection/sterilization of storage tanks.

14. Inadequate internal disinfection/sterilization of storage tanks.

15. Inadequate internal disinfection/sterilization of storage tanks.

16. Inadequate internal disinfection/sterilization of storage tanks.

17. Inadequate internal disinfection/sterilization of storage tanks.

18. Inadequate internal disinfection/sterilization of storage tanks.

19. Inadequate internal disinfection/sterilization of storage tanks.

20. Inadequate internal disinfection/sterilization of storage tanks.

21. Inadequate internal disinfection/sterilization of storage tanks.

22. Inadequate internal disinfection/sterilization of storage tanks.

23. Inadequate internal disinfection/sterilization of storage tanks.

24. Inadequate internal disinfection/sterilization of storage tanks.

25. Inadequate internal disinfection/sterilization of storage tanks.