



MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

Central YAZOO WATER Association Inc
Public Water Supply Name

820004, 820029, 820030, 820031, 820033
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: 5 / 21 / 2011

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The YAZOO HERALD

Date Published: 5 / 21 / 2011

- CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Polly Carter - Secretary
Name/Title (President, Mayor, Owner, etc.)

6-3-2011
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2010 Annual Drinking Water Quality Report
 Central Yazoo Water Association, Inc.
 PWS#: 0820004, 0820029, 0820030, 0820031 & 0820033
 May 2011

2011 MAY 19 PM 1:03

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand and the Meridian Upper Wilcox Aquifer.

If you have any questions about this report or concerning your water utility, please contact Michael Laborde at 662-746-7531. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of each month at 5:00 PM at the main office located at 37 Witherspoon Rd.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Central Yazoo Water Association, Inc. have received lower to moderate susceptibility rankings to contamination.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2010. In cases where monitoring wasn't required in 2010, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS#:0820004		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2010	.016	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2010	2.7	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2006/08*	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2006/08*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2009*	9	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2009*	14	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	1.18	.97 – 1.43	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2010

PWS#:0820029

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2010	.003	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2010	2.2	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2006/08*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2010	.11	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2006/08*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2010	15.	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	1.37	.8 – 1.6	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2010

PWS#:0820030

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	------	-----	--------------------------------

Inorganic Contaminants

8. Arsenic	N	2010	.6	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
------------	---	------	----	----------	-----	-----	----	--

10. Barium	N	2010	.001	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2010	3.3	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
16. Fluoride	N	2010	.131	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2006/08*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2006*	13.3	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2010	1.28	.85– 1.9	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2010

PWS#:0820031

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2010	.011	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2010	3.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2006/08*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2010	.566	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2006/08*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2006*	43	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2010	1.22	.9 – 1.5	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2010

PWS#:0820033

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2010	.01	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2010	1.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2009*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2009*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
82. TTHM [Total trihalomethanes]	N	2010	1.1	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	1.11	.9 – 1.5	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2010.

As you can see by the table, our system had no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

Significant Deficiencies
System ID 08240004

During a sanitary survey conducted on 9/29/10, the Mississippi State Department of Health cited the following deficiency:

Failure to meet water supply demands (overloaded)

Corrective actions: The system is in a Bilateral Compliance Agreement with the Mississippi State Department of Health to construct a new well to increase source capacity. All deficiencies are scheduled to be completed by 3/01/2013.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Central Yazoo Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION OF NOTICE
The State of Mississippi
County of YAZOO

2011 JUN -6 AM 10:41

Personally appeared before me, the undersigned Notary Public in and for the County and State aforesaid GARY ANDREWS, who being by me first duly sworn state on oath, that he is PUBLISHER of the YAZOO HERALD, a newspaper published in the City of Yazoo City, State and County aforesaid, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper 1 times as follows.

Vol. No. 140
Number 3
Dated May 21, 2011

Vol. No. _____
Number _____
Dated _____, 20____

Vol. No. _____
Number _____
Dated _____, 20____


Vol. No. _____
Number _____
Dated _____, 20____

Affiant further states that said newspaper has been established for at least twelve months next prior to the first publication of said notice.

(Signed) [Signature]
Gary Andrews, Publisher

Sworn to and subscribed before me, this 3RD day of June, 2011

(Signed) [Signature]
Sheila D. Trimm-Young
Notary Public or Justice of the Peace



Words 48" Display
Time 1
Amount of ~~Legal~~ \$ 393.60
Proof of Publication \$ 3.00
Total Amount \$ 396.60

~~Legal #~~ _____

2011 Annual Drinking Water Quality Report
Central Yazoo Water Association, Inc.
P.O. Box 200004, Jackson, Mississippi 39202-1004
2011-2012

Water delivered to customers in the Yazoo River's Central Yazoo Water Region. This report is designed to inform you about the quality of water delivered to your tap. The information provided is for informational purposes only and does not constitute an offer of insurance. The information is provided for informational purposes only and does not constitute an offer of insurance. The information is provided for informational purposes only and does not constitute an offer of insurance.

If you have any questions about this report or information about your water quality, please contact your local utility or the Yazoo River Authority. The information provided is for informational purposes only and does not constitute an offer of insurance. The information is provided for informational purposes only and does not constitute an offer of insurance.

The monthly water consumption has been provided for and public water utilities. This report is designed to inform you about the quality of water delivered to your tap. The information provided is for informational purposes only and does not constitute an offer of insurance. The information is provided for informational purposes only and does not constitute an offer of insurance.

Annual Drinking Water Quality Report. This report is designed to inform you about the quality of water delivered to your tap. The information provided is for informational purposes only and does not constitute an offer of insurance. The information is provided for informational purposes only and does not constitute an offer of insurance.

FWW00000001 TEST RESULTS

Parameter	Unit	Result	Standard	Notes
Total Hardness	mg/L	180	1000	
Total Dissolved Solids	mg/L	150	500	
Calcium	mg/L	100	1000	
Magnesium	mg/L	50	1000	
Total Chloride	mg/L	100	1000	
Total Sulfate	mg/L	50	1000	
Total Nitrate	mg/L	10	100	
Total Phosphate	mg/L	0.5	1.0	
Total Ammonia Nitrogen	mg/L	0.5	1.0	
Total Suspended Solids	mg/L	10	100	
Total Organic Carbon	mg/L	1.0	2.0	
Total Organic Halogen	mg/L	0.5	1.0	
Lead	ppb	0.1	15	
Copper	ppb	0.1	1.3	
Chlorine Residual	mg/L	1.0	2.0	
Fluoride	mg/L	1.0	4.0	
Iron	mg/L	0.5	1.0	
Manganese	mg/L	0.1	0.3	
Nitrite	mg/L	0.1	1.0	
Nitrogen	mg/L	1.0	10	
Phosphate	mg/L	0.5	1.0	
Sulfate	mg/L	50	1000	
Selenium	ug/L	1.0	10	
Zinc	mg/L	0.5	1.0	

FWW00000002 TEST RESULTS

Parameter	Unit	Result	Standard	Notes
Total Hardness	mg/L	180	1000	
Total Dissolved Solids	mg/L	150	500	
Calcium	mg/L	100	1000	
Magnesium	mg/L	50	1000	
Total Chloride	mg/L	100	1000	
Total Sulfate	mg/L	50	1000	
Total Nitrate	mg/L	10	100	
Total Phosphate	mg/L	0.5	1.0	
Total Ammonia Nitrogen	mg/L	0.5	1.0	
Total Suspended Solids	mg/L	10	100	
Total Organic Carbon	mg/L	1.0	2.0	
Total Organic Halogen	mg/L	0.5	1.0	
Lead	ppb	0.1	15	
Copper	ppb	0.1	1.3	
Chlorine Residual	mg/L	1.0	2.0	
Fluoride	mg/L	1.0	4.0	
Iron	mg/L	0.5	1.0	
Manganese	mg/L	0.1	0.3	
Nitrite	mg/L	0.1	1.0	
Nitrogen	mg/L	1.0	10	
Phosphate	mg/L	0.5	1.0	
Sulfate	mg/L	50	1000	
Selenium	ug/L	1.0	10	
Zinc	mg/L	0.5	1.0	

FWW00000003 TEST RESULTS

Parameter	Unit	Result	Standard	Notes
Total Hardness	mg/L	180	1000	
Total Dissolved Solids	mg/L	150	500	
Calcium	mg/L	100	1000	
Magnesium	mg/L	50	1000	
Total Chloride	mg/L	100	1000	
Total Sulfate	mg/L	50	1000	
Total Nitrate	mg/L	10	100	
Total Phosphate	mg/L	0.5	1.0	
Total Ammonia Nitrogen	mg/L	0.5	1.0	
Total Suspended Solids	mg/L	10	100	
Total Organic Carbon	mg/L	1.0	2.0	
Total Organic Halogen	mg/L	0.5	1.0	
Lead	ppb	0.1	15	
Copper	ppb	0.1	1.3	
Chlorine Residual	mg/L	1.0	2.0	
Fluoride	mg/L	1.0	4.0	
Iron	mg/L	0.5	1.0	
Manganese	mg/L	0.1	0.3	
Nitrite	mg/L	0.1	1.0	
Nitrogen	mg/L	1.0	10	
Phosphate	mg/L	0.5	1.0	
Sulfate	mg/L	50	1000	
Selenium	ug/L	1.0	10	
Zinc	mg/L	0.5	1.0	

FWW00000004 TEST RESULTS

Parameter	Unit	Result	Standard	Notes
Total Hardness	mg/L	180	1000	
Total Dissolved Solids	mg/L	150	500	
Calcium	mg/L	100	1000	
Magnesium	mg/L	50	1000	
Total Chloride	mg/L	100	1000	
Total Sulfate	mg/L	50	1000	
Total Nitrate	mg/L	10	100	
Total Phosphate	mg/L	0.5	1.0	
Total Ammonia Nitrogen	mg/L	0.5	1.0	
Total Suspended Solids	mg/L	10	100	
Total Organic Carbon	mg/L	1.0	2.0	
Total Organic Halogen	mg/L	0.5	1.0	
Lead	ppb	0.1	15	
Copper	ppb	0.1	1.3	
Chlorine Residual	mg/L	1.0	2.0	
Fluoride	mg/L	1.0	4.0	
Iron	mg/L	0.5	1.0	
Manganese	mg/L	0.1	0.3	
Nitrite	mg/L	0.1	1.0	
Nitrogen	mg/L	1.0	10	
Phosphate	mg/L	0.5	1.0	
Sulfate	mg/L	50	1000	
Selenium	ug/L	1.0	10	
Zinc	mg/L	0.5	1.0	

FWW00000005 TEST RESULTS

Parameter	Unit	Result	Standard	Notes
Total Hardness	mg/L	180	1000	
Total Dissolved Solids	mg/L	150	500	
Calcium	mg/L	100	1000	
Magnesium	mg/L	50	1000	
Total Chloride	mg/L	100	1000	
Total Sulfate	mg/L	50	1000	
Total Nitrate	mg/L	10	100	
Total Phosphate	mg/L	0.5	1.0	
Total Ammonia Nitrogen	mg/L	0.5	1.0	
Total Suspended Solids	mg/L	10	100	
Total Organic Carbon	mg/L	1.0	2.0	
Total Organic Halogen	mg/L	0.5	1.0	
Lead	ppb	0.1	15	
Copper	ppb	0.1	1.3	
Chlorine Residual	mg/L	1.0	2.0	
Fluoride	mg/L	1.0	4.0	
Iron	mg/L	0.5	1.0	
Manganese	mg/L	0.1	0.3	
Nitrite	mg/L	0.1	1.0	
Nitrogen	mg/L	1.0	10	
Phosphate	mg/L	0.5	1.0	
Sulfate	mg/L	50	1000	
Selenium	ug/L	1.0	10	
Zinc	mg/L	0.5	1.0	

Water delivered to customers in the Yazoo River's Central Yazoo Water Region. This report is designed to inform you about the quality of water delivered to your tap. The information provided is for informational purposes only and does not constitute an offer of insurance. The information is provided for informational purposes only and does not constitute an offer of insurance.