



MISSISSIPPI STATE DEPARTMENT OF HEALTH

**BUREAU OF PUBLIC WATER SUPPLY**

**CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM**

McNair Stampsy Waterworks Ass.  
Public Water Supply Name

#0320003 + #0320010  
List PWS ID #s for all Water Systems Covered by this CCR

RECEIVED - WATER SUPPLY  
2011 JUN 16 AM 10:33

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

*Please Answer the Following Questions Regarding the Consumer Confidence Report*

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper
  - On water bills
  - Other \_\_\_\_\_

Date customers were informed:    /   /   

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed:    /   /   

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Fayette Chronicle

Date Published: 6/9/2011

- CCR was posted in public places. *(Attach list of locations)*

Date Posted:    /   /   

- CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

*Reasey D. Green*  
Name/Title (President, Mayor, Owner, etc.)

6-10-2011  
Date

**Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518**



<b>Inorganic Contaminants</b>								
10. Barium	N	2009*	.025	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2009*	.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2008*	4	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

<b>Disinfection By-Products</b>								
82. TTHM [Total trihalomethanes]	N	2008*	1.08	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2010	1.63	1.07– 1.95	ppm	0	MDRL = 4	Water additive used to control microbes

\*Most recent sample. No sample required for 2010

<b>PWS ID #: 0320010</b>		<b>TEST RESULTS</b>						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2009*	.011	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2009*	.58	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2009*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2009*	9	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
Chlorine	N	2010	1.65	1.19 – 2.05	ppm	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2010.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water is safe at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water

tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

#### Significant Deficiencies

System ID 0320003

During a sanitary survey conducted on 5/18/10, the Mississippi State Department of Health cited the following deficiency(s):

1.) Improperly constructed well (ex. not properly grouted)

Corrective actions: Screens have been placed on the blow-off valves of the well and a new master meter has been installed. All deficiencies are scheduled to be completed by 12/31/11.

2.) Inadequate internal cleaning/maintenance of storage tanks

Corrective actions: The system is in a Bilateral Compliance Agreement with the Mississippi State Department of Health to have the storage tanks inspected and cleaned or painted if needed. All deficiencies are scheduled to be completed by 6/03/2011.

3.) Failure to meet water supply demands (overloaded)

Corrective actions: The system is currently in the process of getting approval for a new well and treatment plant to remedy the system overload. All deficiencies are scheduled to be completed by 6/08/2013.

System ID 0320010

During a sanitary survey conducted on 5/18/10, the Mississippi State Department of Health cited the following deficiency:

2.) Inadequate internal cleaning/maintenance of storage tanks

Corrective actions: The system is in a Bilateral Compliance Agreement with the Mississippi State Department of Health to have the storage tanks inspected and cleaned or painted if needed. All deficiencies are scheduled to be completed by 6/03/2011.

3.) Failure to meet water supply demands (overloaded)

Corrective actions: The system is currently in the process of getting approval for a new well and treatment plant to remedy the system overload. All deficiencies are scheduled to be completed by 6/08/2013.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The McNair Stampley Waterworks works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

RECEIVED WATER SUPPLY  
2011 JUN 24 AM 9:53

# The Fayette Chronicle

P. O. Box 536  
Fayette, MS 39069

*"Serving Fayette, Mississippi and Jefferson County Since 1866"*

Charles K. Sheppard  
Owner/Publisher

Ph. (601) 786-3661

## PUBLISHER'S OATH

STATE OF MISSISSIPPI,

Jefferson County

Personally appeared before the undersigned THE FAYETTE CHRONICLE

Editor, Charles K. Sheppard

of the County, JEFFERSON, THE CITY OF FAYETTE

one of the Publishers of the Fayette Chronicle, a weekly newspaper, printed and published in the town of Fayette and Jefferson County, in said county and State, who, being duly sworn deposes and says that said newspaper has been established for more than twelve months next prior to first publication mentioned below; and who further makes oath that publication of a notice, of which, the annexed is a copy, has been made in said paper consecutively, to-wit:

on the 9<sup>th</sup> day of June 2011

on the \_\_\_\_\_ day of \_\_\_\_\_

on the \_\_\_\_\_ day of \_\_\_\_\_

on the \_\_\_\_\_ day of \_\_\_\_\_

on the \_\_\_\_\_ day of \_\_\_\_\_

SHEPPHARD and Associates Sheppard and Associates/COJ, Publisher

And I, \_\_\_\_\_

do hereby certify that the papers containing said notice have been produced before me, and by be compared to the copy annexed, and that I find the proof of publication thereof to be correctly made.

Witness my hand and seal, 14<sup>th</sup> day of June

2011

Arnell Harned Circuit Clerk  
By: Maxine White, D.C.  
Notary Public

Fees and proof of publication \$5.00 Plus Cost of Mailing MY COMMISSION EXPIRES JANUARY 2012

# 2010 Annual Drinking Water Quality Report

## McNair Stampley Waterworks

PWS#: 0320003 & 0320010

### May 2011

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Formation Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility rankings assigned to identified potential sources of contamination. The general susceptibility rankings completed for each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the McNair Stampley Water Association have received lower to moderate susceptibility rankings to contamination. If you have any questions about this report or concerning your water utility, please contact Elbert Dixon at 601-786-1158. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of each month at 7:00 PM at the main office. We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2010. In cases where monitoring wasn't required in 2010, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production; and radon, which is a naturally occurring radioactive gas that enters the water through the ground. In addition, radon can also come from gas stations and geologic mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk. In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

- Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. One part per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Inorganic Contaminants									
10	Barium	N	2009*	0.05	No Range	ppm	2	2	Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits
13	Chromium	N	2009*	8	No Range	ppb	100	100	Discharge from steel and pulp mills, erosion of natural deposits
14	Copper	N	2008*	3	0	ppm	1.3	AL+1.3	Corrosion of household plumbing systems, erosion of natural deposits, leaching from wood preservatives
17	Lead	N	2008*	4	0	ppb	0	AL+15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products									
52	Trihalo Methanes (THMs)	N	2008*	1.08	No Range	ppb	0	80	By product of drinking water chlorination
	Chlorine	N	2010	1.63	1.07 - 1.95	ppm	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2010

PWS ID #: 0320010 TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCL	Unit Measurement	MCLG	MCL	AL	Likely Source of Contamination
Inorganic Contaminants									
10	Barium	N	2009*	011	No Range	ppm	2	2	Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits
13	Chromium	N	2009*	58	No Range	ppb	100	100	Discharge from steel and pulp mills, erosion of natural deposits
14	Copper	N	2009*	2	0	ppm	1.3	AL+1.3	Corrosion of household plumbing systems, erosion of natural deposits, leaching from wood preservatives
17	Lead	N	2009*	9	0	ppb	0	AL+15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products									
	Chlorine	N	2010	1.63	1.19 - 2.05	ppm	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2010


As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water is safe at these levels. We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for all bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7682 if you wish to have your water tested.

**Significant Deficiencies**  
System ID 0320003  
During a sanitary survey conducted on 5/18/10, the Mississippi State Department of Health cited the following deficiencies:  
1.) Improperly constructed well (ex. not properly grouted)  
**Corrective actions:** Screens have been placed on the blow-off valves of the well and a new master meter has been installed. All deficiencies are scheduled to be completed by 12/31/11.  
2.) Inadequate internal cleaning/maintenance of storage tanks  
**Corrective actions:** The system is in a Bilateral Compliance Agreement with the Mississippi State Department of Health to have the storage tanks inspected and cleaned or painted if needed. All deficiencies are scheduled to be completed by 6/03/2011.  
3.) Failure to meet water supply demands (overloaded)  
**Corrective actions:** The system is currently in the process of getting approval for a new well and

PWS ID #: 0320003 TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCL	Unit Measurement	MCLG	MCL	AL	Likely Source of Contamination

UNITED STATES POSTAL SERVICE



First-Class Mail  
Postage & Fees Paid  
USPS  
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •

MS State Dept Health  
Bureau of Public Water Supply  
Attn: Ciara King  
P O Box 1700  
Jackson, MS 39215-1700

2011 MAY -5 PM 8:52

SEVEN-WATERS

80

