

2012 MAY 21 AM 10:34

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORMTown of Mathiston
Public Water Supply Name0780007
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
- Advertisement in local paper
 On water bills
 Other _____

Date customers were informed: 5/17/12

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 1/1

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Webster ~~Progress~~ Progress TimesDate Published: 5/17/12

- CCR was posted in public places. *(Attach list of locations)*

Date Posted: 5/17/12

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Jimmy P. Carlson MAYOR
Name/Title (President, Mayor, Owner, etc.)

5-17-12
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2012 MAY 21 AM 10:34

Annual Drinking Water Quality Report
Town of Mathiston
PWS ID: 0780007
May 8, 2012

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is two wells. Our wells draw from the Coker and the Gordo Formations Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are **moderate susceptibility**. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request.

I'm pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mike Sheffield at 662-263-4898. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of every month at 6 PM. They will be at The Town Hall.

The Town of Mathiston routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2011. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detect # of Samples E MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
Chlorine (as Cl ₂) (ppm)	N	2011	.70	.03—1.5	Ppm	4	4	Water additive used to control microbes
Inorganic Contaminants								
Arsenic	N	2011	.9	No-range	Ppb	n/a	50	Erosion of natural deposits; runoff from glass and electronics production
Barium	N	2011	.142	No-range	Ppm	2	2	Discharge of drilling wastes; discharge from refineries; erosion of natural deposits
Copper	N	2011	.2	No-range	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead	N	2011	3.0	No-range	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Selenium	N	2011	3.0	No-range	ppb	50	50	Discharge from petroleum and natural gas production; erosion of natural deposits; discharge from refineries

***** A MESSAGE FROM MSHD CONCERNING RADIOLOGICAL SAMPLING *****

In accordance with the Radionuclides Rule, all community water supplies were required to sample quarterly for radionuclides beginning January 2007- December 2007. Your public water supply completed sampling by the deadline; however, during an audit of the Ms. State Dept. of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. **Although this was not the result of inaction by the public water supply,** MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Mathiston is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Your CCR will not be mailed to you however; you may obtain a copy from the Town Hall. Please call 662-263-4898 if you have any questions.

Annual Drinking Water Quality Report
Town of Mathiston
PWS ID: 0780007
May 8, 2012

RECEIVED - WATER SUPPLY
MAY 31 AM 10:34

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water supply is from two wells. Our wells draw from the Coker and the Gordo Formations Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are moderate susceptibility. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request.

I'm pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mike Sheffield at 662-263-4898. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of every month at 6 PM. They will be at The Town Hall.

The Town of Mathiston routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2011. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detect # of Samples E MCL/ACL	Unit Measurement	MCL0	MCL	Likely Source of Contamination
Microbiological Contaminants								
Chlorine (as Cl2) (ppm)	N	2011	.70	.03—1.5	Ppm	4	4	Water additive used to control microbes
Inorganic Contaminants								
Arsenic	N	2011	.9	No-range	Ppb	n/a	50	Erosion of natural deposits; orchards; runoff from glass production wastes
Barium	N	2011	.142	No-range	Ppm	2	2	Discharge of drilling wastes; metal refineries; erosion of natural deposits
Copper	N	2011	.2	No-range	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead	N	2011	3.0	No-range	ppb	0	AL=15	Corrosion of household plumbing; erosion of natural deposits
Selenium	N	2011	3.0	No-range	ppb	50	50	Discharge from petroleum and erosion of natural deposits; mines

******* A MESSAGE FROM MSHD CONCERNING RADIOLOGICAL SAMPLING *******

In accordance with the Radionuclides Rule, all community water supplies were required to sample quarterly for radionuclides beginning January 2007- December 2007. Your public water supply completed sampling by the deadline; however, during an audit of the Ms. State Dept. of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. **Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation.** This is to notify you that as of this date, your water system has not completed the monitoring requirements. The bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

*****Additional Information for Lead*****

Present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Mathiston is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. Please contact 601-576-582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Your CCR will not be mailed to you however; you may obtain a copy from the Town Hall. Please call 662-263-4898 if you have any questions.

Publish: 5/17 2012