

CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT  
CERTIFICATION REPORT  
CITY OF MOUND BAYOU  
PWS ID # 0060013  
JUNE, 2012

2012 JUN 12 AM 8:59

In accordance to the Federal Safe Drinking Water Act, the 2011 Consumer Confidence Report was prepared and distributed to the customers of the above Water System as follows:

- Customers were informed of availability of CCR by:
  - Advertisement in local paper
  - On water bills
  - Other Public Places
 Date customers were informed: 6/8/2012
- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods: \_\_\_\_\_  
Date mailed/distributed: \_\_\_\_\_
- CCR was published in local newspaper. (Attach copy of published CCR and proof of publication)  
Name of Newspaper: \_\_\_\_\_  
Date Published: \_\_\_\_\_
- CCR was posted in public places. (Attach list of locations)  
Date posted: 6/8/2012
- CCR was posted on a publicly accessible internet site at the address: \_\_\_\_\_  
www. \_\_\_\_\_

CERTIFICATION:

I hereby certify that a Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above.

Kennedy V. Johnson/Mayor  
Name/Title (President, Mayor, Owner, etc.) (Please type)

6/8/12  
Date

[Signature]  
Signature

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Susan Boyette  
Signature

6-1-12  
Date

**Mail completed form along with a copy of your CCR BEFORE July 1, 2012 to:  
MSDH ~ Division of Water Supply ~ P O Box 1700 ~ Jackson, MS 39215**

*Annual Drinking Water Quality Report*  
*City of Mound Bayou*  
*PWS ID # 0060013*  
*June, 2012*

RECEIVED - WATER SUPPLY  
2012 JUN 12 AM 8:59

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells that draw from the Winona-Tallahatta Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination.. The water supply for the City of Mound Bayou received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Robert Andrews at 662-741-2194. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at Mound Bayou City Hall at 5:30 p.m.

The City of Mound Bayou routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31<sup>st</sup>, 2011. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

## TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
8. Arsenic	N		1.20	No Range	Ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N		0.0527	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N		3.70	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N		0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N		0.218	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N		1	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N		5	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
<b>Disinfectants &amp; Disinfection By-Products</b>								
Chlorine (as Cl <sub>2</sub> )	N	01/01/11 to 12.31.11	0.90	0.45 to 1.00	ppm	4	4	Water additive used to control microbes
73. TTHM Total trihalo-methanes]	N		39.2	None	ppb	80	80	By-product of drinking water chlorination
HAA5	N		10	None	ppb	60	60	By-product of drinking water chlorination

**\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007-December 2007. Your public water supply completed the sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.


### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Mound Bayou is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested..

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.



RECEIVED-WATER SUPPLY

2012 JUN 12 AM 8:59

**CITY OF MOUND BAYOU**  
106 South Green Avenue  
P.O. Box 680  
Mound Bayou, MS 38762

June 8, 2012

# NOTICE

**From: City of Mound Bayou Public Works Department**  
**To: Customers of the Mound Bayou Water System**

The 2012 Consumer Confidence Certification Report for the City of Mound Bayou Public Water System ID# 0060013 is available for review at the Mound Bayou City Hall. To review a copy of this report, please come by the Mound Bayou City Clerk's office at 106 South Green Avenue, room 109, Mound Bayou.

Sincerely,

Kennedy V. Johnson, Mayor

## **PUBLIC NOTICE LOCATIONS**

Mound Bayou City Hall Bulletin Board  
106 South Green Avenue  
Mound Bayou, Ms. 38762

U S Post Office  
308 South Dr. T. R. M. Howard Avenue  
Mound Bayou, Ms. 38762

Bob's Express  
101 North Dr. T. R. M. Howard Avenue  
Mound Bayou, Ms. 38762

Tradeway Convenience Store  
117 North Dr. T. R. M. Howard Avenue  
Mound Bayou, Ms. 38762

New Deal Grocery Store  
503 W. South Street  
Mound Bayou, Ms. 38762

TGS Community Quick Stop  
103 North Rayner Ave  
Mound Bayou, Ms. 37862