

RECEIVED-WATER SUPPLY  
2012 JUL -2 AM 9:10

## BUREAU OF PUBLIC WATER SUPPLY

### CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Blackland Water Assoc.  
Public Water Supply Name

0590003  
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

#### Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
- Advertisement in local paper
  - On water bills
  - Other \_\_\_\_\_

Date customers were informed: 6/28/12

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed:  / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Banner Independent

Date Published: 6/28/12

- CCR was posted in public places. *(Attach list of locations)*

Date Posted:  / /

- CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

#### CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Fred Clamer  
Name/Title (President, Mayor, Owner, etc.)

6-28-12x  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

RECEIVED-WATER SUPPLY  
2012 JUL -2 AM 9:10

\$ 302.40 <sup>40</sup>  
~~24~~ <sub>4009</sub>

**PROOF OF PUBLICATION**

0107

**Annual Drinking Water Quality Report  
Blackland Water Association  
PWS ID# MS 0590003  
May 21, 2012**

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is two wells drawing from the Eutaw Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Blackland Water Association have received a **lower susceptibility** ranking to contamination.

I'm pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact James Worley at (662)-720-6065. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Thursday of each month at 7:00 P.M. at the water office.

The Blackland Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2011. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MRDL**: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants

**Parts per million (ppm)** - Milligrams per liter (mg/L).

**Parts per billion (ppb)** - Micrograms per liter (ug/L).

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>								
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl <sub>2</sub> ) (ppm)	N	2011	0.90	0.70 - 1.0	Ppm	4	4	Water additive used to control microbes
<b>Inorganic Contaminants</b>								
Barium	N	*2010	.192	.090 - .192	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	N	*2008	2.8	.69 - 2.8	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper	N	2011	0.4	No-range	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead	N	2011	1.0	No-range	Ppb	AL=15	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

\*Most recent sample. No sample was required in 2011

STATE OF MISSISSIPPI

CITY OF PRENTISS

I, Teresa C. Smith  
Public in and for said county, or other  
authorized to administer oaths, this day  
certify that the undersigned official of the  
Booneville Independent, a newspaper published  
in the City of Booneville, in Prentiss  
County, Mississippi, who, being duly  
sworn, has published the notice, a true copy of  
which is attached, was published in the  
newspaper for one consecutive

Number 21, June 28, 2012

Number \_\_\_\_\_, \_\_\_\_\_, 20\_\_

Sapperton  
Editor

Day of June, 2012

T. C. Smith  
Notary Public

2-1-14

My Commission Expires

\_\_\_\_\_, 20\_\_

**\*\*\*\*\* A MESSAGE FROM MSHD CONCERNING RADIOLOGICAL SAMPLING \*\*\*\*\***

In accordance with the Radionuclides Rule, all community water supplies were required to sample quarterly for radionuclides beginning January 2007- December 2007. Your public water supply completed sampling by the deadline; however, during an audit of the Ms. State Dept. of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

**\*\*\* Additional Information for Lead\*\*\***

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Blackland Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV / AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA AICDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Your CCR will not be mailed to you however; you may obtain a copy by calling the water office at 662-720-4212 if you have questions.