

2012 JUN 25 AM 10: 24

## BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM

Southwest Covington Water Association  
Public Water Supply Name  
Cold Springs Water Association  
160009; 160001  
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

## Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper

On water bills

Other In CCR report

Date customers were informed: 6/13/12

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed:  / /

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The News Commercial

Date Published: 6/13/12

CCR was posted in public places. *(Attach list of locations)*

Date Posted:  / /

CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

James C. Aycock / President  
Name/Title (President, Mayor, Owner, etc.)

6/19/12  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

5m

2011 Annual Drinking Water Quality Report  
 Southwest Covington Utility Association & Cold Springs Water Association  
 PWS#: 160009 & 160001  
 May 2012

MAY 31 PM 4:53  
2012

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Southwest Covington Utility Association have received lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Barry Mayfield at 601-722-4447. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Tuesday of the month at 4:00 PM at the office building located at 597 Union Church Rd, Seminary, MS.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2011. In cases where monitoring wasn't required in 2011, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS# 160009		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2011	.005	.003 - .005	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2008/10*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2011	.12	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008/10*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

22. Thallium	N	2011	.6	No Range	ppb	0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
<b>Disinfection By-Products</b>								
81. HAA5	N	2011	3	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2011	6.1	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2011	.5	.4 - .67	ppm	0	MDRL = 4	Water additive used to control microbes

<b>PWS ID#: 160001</b>		<b>TEST RESULTS</b>						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2011	.008	.006 - .008	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2009/11	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2011*	.158	.104 - .158	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009/11	6	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
81. HAA5	N	2011	6	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2011	6.74	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2011	.7	.4 - 1	ppm	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2011.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

**\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water suppliers were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological health laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The Southwest Covington Utility Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Notice: This report will not be mailed out to each customer, however a copy can be obtained at our office.

RECEIVED-WATER SUPPLY  
2012 JUN 25 AM 10:24

# Proof of Publication

STATE OF MISSISSIPPI  
COVINGTON COUNTY

PERSONALLY APPEARED before me, the undersigned authority, in and for said County and State, Analyz A. Goff, Publisher of THE NEWS-COMMERCIAL, a newspaper published in Collins, said County, who being duly sworn, says the publication of a certain notice, a true copy of which is hereto attached, was made in said paper on the hereinafter dates, as follows, to-wit:

Vol. 110 No. 48 Dated June 13, 2012  
Vol. \_\_\_\_\_ No. \_\_\_\_\_ Dated \_\_\_\_\_  
Vol. \_\_\_\_\_ No. \_\_\_\_\_ Dated \_\_\_\_\_  
Vol. \_\_\_\_\_ No. \_\_\_\_\_ Dated \_\_\_\_\_

Analyz A. Goff Publisher

Sworn to and subscribed before me, this the 13 day of June, 2012.

James Arrington Goff Notary Public

Printer's Fee \$ 180.00  
Proof of Publication \$ 3.00  
TOTAL \$ 183.00



Please Fold Open  
LEGAL Inside

**Covington County Utility Association & Covington Water Association**  
PWS# 100009 & 100011  
May 2012

This document is intended to provide you with information regarding your water supply. It is not intended to provide you with a guarantee of the quality of your water. The water supply in this area is provided by the Covington County Utility Association and the Covington Water Association. A recent water quality report was published by the Environmental Protection Agency (EPA) and the Mississippi Department of Health (MDH) in March 2012. This report provides information regarding the quality of the water supply in this area. The water supply in this area is provided by the Covington County Utility Association and the Covington Water Association. A recent water quality report was published by the Environmental Protection Agency (EPA) and the Mississippi Department of Health (MDH) in March 2012. This report provides information regarding the quality of the water supply in this area.

TEST RESULTS									
Contaminant	Volume	Date	Method	Range of Values or Detection Limit	MDH	MSL	MSL	MSL	MSL
<b>Inorganic Contaminants</b>									
16. Barium	10	2011	MS	0.03-0.06	0.05	0	0	0	0
18. Cadmium	10	2011-12	MS	0.0001-0.0002	0.0005	1.5	AL-13	0	0
19. Fluoride	10	2011	MS	1.0-1.5	4.0	0	0	0	0
17. Lead	10	2011-12	MS	0.001-0.002	0.01	0	AL-15	0	0
15. Turbidity	10	2011	MS	0.1-0.2	0.5	0	0	0	0
<b>Disinfection By-Products</b>									
21. Trihalomethanes (THM)	10	2011	MS	0.1-0.2	0.5	0	0	0	0
22. Haloacetic Acids (HAA)	10	2011	MS	0.1-0.2	0.5	0	0	0	0
23. Haloacetonitriles (HAN)	10	2011	MS	0.1-0.2	0.5	0	0	0	0

**TEST RESULTS**

Contaminant	Volume	Date	Method	Range of Values or Detection Limit	MDH	MSL	MSL	MSL	MSL
<b>Inorganic Contaminants</b>									
16. Barium	10	2011	MS	0.03-0.06	0.05	0	0	0	0
18. Cadmium	10	2011-12	MS	0.0001-0.0002	0.0005	1.5	AL-13	0	0
19. Fluoride	10	2011	MS	1.0-1.5	4.0	0	0	0	0
17. Lead	10	2011-12	MS	0.001-0.002	0.01	0	AL-15	0	0
15. Turbidity	10	2011	MS	0.1-0.2	0.5	0	0	0	0
<b>Disinfection By-Products</b>									
21. Trihalomethanes (THM)	10	2011	MS	0.1-0.2	0.5	0	0	0	0
22. Haloacetic Acids (HAA)	10	2011	MS	0.1-0.2	0.5	0	0	0	0
23. Haloacetonitriles (HAN)	10	2011	MS	0.1-0.2	0.5	0	0	0	0