

2012 JUN 15 AM 8:45

**BUREAU OF PUBLIC WATER SUPPLY****CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM**

City of Hattiesburg  
Public Water Supply Name

0180008  
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

***Please Answer the Following Questions Regarding the Consumer Confidence Report***

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
- Advertisement in local paper  
 On water bills  
 Other \_\_\_\_\_

Date customers were informed: 6/13/12

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 6/12/12

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_ / \_\_\_ / \_\_\_

- CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_ / \_\_\_ / \_\_\_

- CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Paul D. Hoffer Operator  
Name/Title (President, Mayor, Owner, etc.)

6/14/12  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Hattiesburg is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health laboratory offers lead testing for \$20 per sample. Please contact 601.576.7582 if you wish to have your water tested.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). Please call our office if you have questions.

Please be assured that those of us, who work with the City of Hattiesburg Water System, work hard every day to provide quality drinking water to every customer. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PRSRT STD  
U.S. Postage  
PAID  
Hattiesburg, Ms. 39402  
Permit No. 4

## Frequently Called Phone Numbers

Billing Inquiries, Turn-ons, Cut-offs:	545-4533
Request For Service	545-4500
After Hour Problems	545-4635
Water Plant #1	545-4636
Water Plant #2	545-4635
System Operator's Office	545-4531

Hattiesburg Water & Sewer Dept.  
900 James Street  
Hattiesburg, MS 39401

RECEIVED-WATER SUPPLY


2012 JUN 15 AM 8:45

CITY OF  
**HATTIESBURG**

PWS ID# 180008

## 2011 Annual Drinking Water Quality Report

Report prepared May 3 2012



Hattiesburg Water & Sewer Dept. Phone: (601) 545-4530  
Water Plant #2 Fax: (601) 545-4689  
900 James Street www.hattiesburgms.com  
Hattiesburg, Mississippi 39401

Office hours: 7:00 a.m. to 3:30 p.m. Monday thru Friday



+We are very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is groundwater from fourteen (14) wells using water from the Middle Catahoula Formation and the Upper Catahoula Formation aquifers.

\*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007-December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

To Comply with the "Regulation Governing Fluoridation of Community Water Supplies," the CITY OF HATTIESBURG is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 66%.

The City of Hattiesburg routinely monitors for up to 154 constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2011. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some constituents. It is important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions:

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

WATER QUALITY TEST RESULTS							
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AL	Unit of Measurement	MCLG MCL	Likely Source of Contamination
<b>Radioactive Contaminants</b>							
4. Beta/Photon emitters	N	2002	3.60	No Range	PC/l	0 50	Decay of natural and man-made deposits
<b>Inorganic Contaminants</b>							
10. Barium	N	2011	.051	No Range	ppm	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
12. Cadmium	N	2011	.0005	No Range	ppb	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
14. Copper	N	2009	.0170	0	ppm	1.3 AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2011	.677	*	ppm	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009	.0008	0	ppb	0 AL=15	Corrosion of household plumbing systems, erosion of natural deposits
73. TTHM [Total trihalomethanes]	N	2011	8.0	1.5 - 7.1	ppb	0 100	By-product of drinking water chlorination
<b>Disinfection and it's by-products</b>							
Chlorine (as Cl2)	N	2011	1.03	0	ppm	4 4	Water additive used to control microbes

\* The City of Hattiesburg routinely adjusts the fluoride level in the finished water to 0.8 - 1.2 mg/l.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.